

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0265594
APS ID 1074207
Authorization ID 1415094

Applicant, Facility and Project Information

Applicant Name	<u>Allen Hawthorne</u>	Facility Name	<u>Allen Hawthorne SRSTP</u>
Applicant Address	<u>1024 Mission Drive</u> <u>Erie, PA 16509-2968</u>	Facility Address	<u>9411 Eureka Road</u> <u>Edinboro, PA 16412</u>
Applicant Contact	<u>Allen Hawthorne</u>	Facility Contact	<u></u>
Applicant Phone	<u>(814) 449-3402</u>	Facility Phone	<u></u>
Applicant E Mail	<u>allenh.bhre@gmail.com</u>	Facility E Mail	<u></u>
Client ID	<u>335089</u>	Site ID	<u>825031</u>
Municipality	<u>Franklin Township</u>	County	<u>Erie</u>
SIC Code	<u>8800</u>	SIC Code	<u>4952</u>
SIC Description	<u>Private Households,</u>	SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>
Date Application Received	<u>October 17, 2022</u>	WQM Required	<u>Present permit is adequate</u>
Date Application Accepted	<u>November 10, 2022</u>	WQM App. No.	<u></u>
Project Description	<u>NPDES permit renewal/</u>		

Summary of Review

Outstanding NOV for annual fee payment. *(There are no open violations in WMS for the subject Client ID (335089) as of December 7, 2022. JCD)*

June 9, 2020 AMR reported not constructed. No engineer's certification on file. Discussed with Allen Hawthorne on November 21, 2022. The facility has not been built, he reports only to the ECHD and annual fee has been paid. I informed him that the regional office should be copied and if the address is not on the current form, it be on the AMR form enclosed with the issued permit.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania*

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	November 21, 2022
X		Vacant Environmental Engineer Manager	Okay to Draft JCD 12/7/2022

Summary of Review

Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude	<u>41° 58' 6.00"</u>	Longitude	<u>-80° 11' 59.00"</u>
Latitude	<u>41° 58' 14.69"</u>	Longitude	<u>-80° 7' 59.00"</u>
Quad Name	<u>Edinboro North</u>	Quad Code	<u>0304</u>
Wastewater Description: <u>Treated single residence domestic wastes</u>			
Receiving Waters	<u>Unnamed Tributary to Porter Run</u>	Stream Code	<u>unknown</u>
NHD Com ID	<u>123922500</u>	RMI	<u>0.26</u>
Drainage Area	<u>31.1 acres 0.05 square miles</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>Dry stream</u>
Elevation (ft)	<u>1170.00</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>15-A</u>	Chapter 93 Class.	<u>CWF, MF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>Dry swale discharge to tributary 52555 RMI 0.35</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>City of Erie</u>		
PWS Waters	<u>Lake Erie</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>915.01</u>	Distance from Outfall (mi)	<u>54.40</u>

Changes Since Last Permit Issuance: none

Other Comments: Canada is 63,33 miles downstream in mid lake Erie

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection

Other Comments: See AMR for UV radiation disinfection requirements