

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0265675
APS ID 1074522
Authorization ID 1415577

Applicant, Facility and Project Information

Applicant Name	<u>David T Parish</u>	Facility Name	<u>David T Parish SRSTP</u>
Applicant Address	<u>3860 Frew Mill Road</u> <u>New Castle, PA 16101-8114</u>	Facility Address	<u>3860 Frew Mill Road</u> <u>New Castle, PA 16101-8114</u>
Applicant Contact	<u>David Parish</u>	Facility Contact	<u></u>
Applicant Phone	<u></u>	Facility Phone	<u></u>
Applicant E Mail	<u>NA</u>	Facility E Mail	<u></u>
Client ID	<u>340394</u>	Site ID	<u>820104</u>
Municipality	<u>Slippery Rock Township</u>	County	<u>Lawrence</u>
SIC Code	<u>8800</u>	SIC Code	<u>4952</u>
SIC Description	<u>Private Households,</u>	SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>
Date Application Received	<u>October 26, 2022</u>	WQM Required	<u>Present permit is adequate</u>
Date Application Accepted	<u>November 9, 2022</u>	WQM App. No.	<u>3718401</u>
Project Description	<u>NPDES renewal</u>		

Summary of Review

No violations reported. Facility design was by Advanced Design, John DeLacio and Dominic Munizza, P.E. No Engineer's certification is on file. The only AMR submitted was received on June 6, 2019 stated the house was under construction and additional monitoring forms needed. Normally the permittee is expected to copy the issued AMR for their use. The renewal did not provide a current telephone number or e mail address. No sludge removal should be necessary before mid-2023.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	November 10, 2022
X		Vacant Environmental Engineer Manager	Okay to Draft JCD 12/8/2022

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude DP	<u>40° 59' 26.07"</u>	Longitude DP	<u>-80° 11' 36.21"</u>
Latitude NHD	<u>40° 59' 26.07"</u>	Longitude NHD	<u>-80° 11' 36.21"</u>
Quad Name	<u>Portersville</u>	Quad Code	<u>1104</u>
Wastewater Description: <u>Treated single residence domestic wastes</u>			
Receiving Waters	<u>Brush Run</u>	Stream Code	<u>35035</u>
NHD Com ID	<u>126216606</u>	RMI	<u>0.5100none</u>
Drainage Area	<u>5/34</u>	Yield (cfs/mi ²)	<u>0.1</u>
Q ₇₋₁₀ Flow (cfs)	<u>0,534</u>	Q ₇₋₁₀ Basis	<u>default</u>
Elevation (ft)	<u>1038.16</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>20-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments <u></u>			
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Pa Wm Ellwood</u>		
PWS Waters	<u>Connoquenessing Creek</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>0.01</u>	Distance from Outfall (mi)	<u>18.5</u>

Changes Since Last Permit Issuance: none

Other Comments: none

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
TRC	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection