

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0266086
APS ID 868141
Authorization ID 1311292

Applicant and Facility Information

Applicant Name	<u>Spring Grove Borough York County</u>	Facility Name	<u>Spring Grove Borough STP</u>
Applicant Address	<u>1 Campus Avenue</u> <u>Spring Grove, PA 17362-1412</u>	Facility Address	<u>1 Campus Avenue</u> <u>Spring Grove, PA 17362-1412</u>
Applicant Contact	<u>Andrew Shaffer</u>	Facility Contact	<u>Andrew Shaffer</u>
Applicant Phone	<u>(717) 225-5791</u>	Facility Phone	<u>(717) 225-5791</u>
Client ID	<u>64892</u>	Site ID	<u>451699</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Spring Grove Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>York</u>
Date Application Received	<u>April 7, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 1, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

ARRO Consulting, Inc., on behalf of the Spring Grove Borough, has applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. This facility is located at 201 East Railroad Street, Spring Grove, PA. The permit was reissued on September 23, 2015 and became effective on October 1, 2015. The permit expired on September 30, 2020 but the terms and conditions of the permit have been extended since that time.

This facility serves the areas of Spring Grove Borough (98.4%), and Jackson Township (1.6%). The flow design is 0.33 MGD.

The WQM Part II No. 6715403 issued on September 23, 2015, and amendment 6715403 A-1 issued on September 30, 2015.

Sludge use and disposal description and location(s): N/A due to the sludge is hauled away by Kline's Services.

Changes from the previous permit:

- Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml. The E. Coli. monitoring and report requirements will add to the proposed permit.
- The sampling frequency changed from twice per week to one per week for Ammonia-Nitrogen, Total Phosphorus, Kjeldahl-Nitrogen and Nitrate-Nitrite as Nitrogen (N) in the proposed permit.
- Section C, items # II – Schedule of Compliance will be removed for the proposed permit due to the facility upgrade and expansion project was completed on June 30, 2017 (via email from Kim Hackett, regarding Spring Grove Borough, on 6/23/2021).

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	July 7, 2021
X		Maria D. Bebenek for Danial W. Martin Daniel W. Martin, P.E. / Environmental Engineer Manager	July 19, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.33
Latitude	39° 52' 24.00"	Longitude	-76° 51' 28.00"
Quad Name	Seven Valleys	Quad Code	
Wastewater Description: Treated Sewage			
Receiving Waters	Codorus Creek (WWF, MF)	Stream Code	08032
NHD Com ID	57472067	RMI	26.14 miles
Drainage Area	74.0 mi. ²	Yield (cfs/mi ²)	0.12
Q ₇₋₁₀ Flow (cfs)	8.51	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	434.7	Slope (ft/ft)	
Watershed No.	7-H	Chapter 93 Class.	WWF, MF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Wrightsville Water Company, York County		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	44 miles	Distance from Outfall (mi)	Approximate 34 miles

Changes Since Last Permit Issuance:

Drainage Area

The drainage area upstream of the point of discharge was determined to be 74.0 mi² through the use of USGS PA StreamStats application (<http://water.usgs.gov/osw/streamstats/pennsylvania.html>).

Streamflow

According to StreamStats, the point of first use has a Q₇₋₁₀ of 8.51 cfs and a drainage area of 74.0 mi², which results in a Q₇₋₁₀ low flow yield of 0.12 cfs/mi². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 8.51 \text{ cfs} \\
 \text{Low Flow Yield} &= 8.51 \text{ cfs} / 74.0 \text{ mi}^2 = 0.12 \text{ cfs/mi}^2 \\
 Q_{30-10} &= 1.36 * 8.51 \text{ cfs} = 11.57 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 8.51 \text{ cfs} = 5.45 \text{ cfs}
 \end{aligned}$$

The resulting Q₇₋₁₀ dilution ratio is: $Q_{\text{stream}} / Q_{\text{discharge}} = 8.51 \text{ cfs} / [0.33 \text{ MGD} * (1.547 \text{ cfs/MGD})] = 16.6:1$

Codorus Creek

25 Pa. Code § 93.9o classifies Codorus Creek as Warm Water and Migratory Fishes (WWF & MF) surface water. Based on the 2020 Integrated Report, Codorus Creek, assessment unit IDs 3581 & 19023, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Public Water Supply

The nearest downstream public water supply intake is the Wrightsville Water Supply Co. on Susquehanna River in York County, approximately 34 miles downstream of this discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Spring Grove STP				
WQM Permit No.		Issuance Date		
6715403		9/23/2015		
6715403 A-1		9/30/2015		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Phosphorus Reduction	Sequencing Batch Reactor	Ultraviolet	0.33
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.57	1811	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance:

The current treatment process is as follows:

Bar screen → Grit Removal System → Sequencing Batch Reactors (2) → Post EQ tank → UV Disinfection → Post Aeration → Discharge to Codorus Creek.

The chemical uses such as aluminum salt for phosphorus removal, flocculation, and settling, polymer for flocculation & settling, and sodium hypochlorite for maintaining chlorine residual are in the utility water system only.

Compliance History	
Summary of DMRs:	The DMRs reported from May 1, 2020 to April 30, 2021 are summarized in the Table below (Pages # 5, 6, & 7).
Summary of Inspections:	5/01/2019: Austen Randecker, DEP Water Quality Specialist, conducted a compliance evaluation inspection and indicated that no issues were found. The recommendation was to maintain a secondary thermometer in the influent and effluent composite samplers. Samples collected during the inspection show all results were in permitted range.
Other Comments:	There are currently no open violations associated to the permittee or the facility.

Other Comments:

The table below summarizes the influent/effluent testing results submitted along with the application.

<i>Influent Testing Results</i>			<i>Effluent Testing Results</i>		
Parameter	Min/Max Value	Average Value	Parameter	Min/Max Value	Average Value
BOD ₅ (mg/L)	630 mg/L	300.68 mg/L	pH (minimum)	6.88 S.U.	
BOD ₅ (lbs/day)	2563.7 lbs/day	921.41 lbs/day	pH (maximum)	7.81 S.U.	
TSS (mg/L)	602 mg/L	194.05 mg/L	D.O (minimum)	6.91 mg/L	8.89 mg/L
TSS (lbs/day)	1661.3 lbs/day	579.43 lbs/day	TRC	<0.1 mg/L	<0.1 mg/L
TN (mg/L)	<58 mg/L	<54.5 mg/L	Fecal Coliform	96 No./100mL	2.88 No./100mL
TN (lbs/day)	115.88 lbs/day	108.82 lbs/day	CBOD ₅	3.25 mg/L	3.02 mg/L
TP (mg/L)	15 mg/L	5.51 mg/L	TSS	15 mg/L	3.23 mg/L
TP (lbs/day)	33.26 lbs/day	33.26 lbs/day	NH ₃ -N	0.39 mg/L	0.12 mg/L
NH ₃ -N (mg/L)	36 mg/L	18.9 mg/L	TN	3.8 mg/L	1.9 mg/L
NH ₃ -N (lbs/day)	88.31 lbs/day	52.75 lbs/day	TP	2.4 mg/L	0.51 mg/L
TDS (mg/L)	484 mg/L	484 mg/L	Temp	39.02 F	39.02 F
TDS (lbs/day)	975.39 lbs/day	975.39 lbs/day	TKN	1.3 mg/L	0.61 mg/L
TKN	56 mg/L	32.89 mg/L	NO ₂ -N + NO ₃ -N	3.3 mg/L	1.29 mg/L
NO ₂ -N + NO ₃ -N	1.5 mg/L	1.5 mg/L	TDS	352 mg/L	352 mg/L
			Chloride	94 mg/L	94 mg/L
			Bromide	< 0.5 mg/L	< 0.5 mg/L
			Sulfate	29 mg/L	29 mg/L
			Oil and Grease	< 5.0 mg/L	< 5.0 mg/L
			Total Copper	<0.005 mg/L	<0.005 mg/L
			Total Lead	< 0.001 mg/L	< 0.001 mg/L
			Total Zinc	0.061 mg/L	0.061 mg/L

Compliance History

DMR Data for Outfall 001 (from May 1, 2020 to April 30, 2021)

Parameter	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20
Flow (MGD) Average Monthly	0.3112	0.4117	0.2814	0.2904	0.2632	0.2458	0.2418	0.2183	0.2674	0.2022	0.2431	0.3555
Flow (MGD) Daily Maximum	0.4782	0.7576	0.4265	0.3956	0.6614	0.3656	0.3705	0.2556	0.5357	0.3746	0.3936	0.5729
pH (S.U.) Minimum	7.43	7.41	7.31	7.41	7.50	7.31	7.19	7.29	7.22	7.42	7.43	7.46
pH (S.U.) Instantaneous Maximum	7.82	7.90	7.57	7.81	7.71	7.65	7.70	7.54	7.74	7.68	7.75	7.79
DO (mg/L) Minimum	7.91	9.08	9.99	9.83	8.81	8.01	7.64	6.88	6.82	6.25	7.8	8.75
CBOD5 (lbs/day) Average Monthly	7.06	8.89	5.37	7.74	36.51	5.83	6.21	5.70	8.17	11.28	6.06	9.15
CBOD5 (lbs/day) Weekly Average	9.57	12.18	6.15	9.86	7.48	6.27	7.70	5.91	13.40	20.05	7.64	10.61
CBOD5 (mg/L) Average Monthly	2.4	2.52	2.70	3	3	3	3	3	3.00	6.25	3	3
CBOD5 (mg/L) Weekly Average	2.4	3.00	3.0	3	3	3	3	3.00	3.00	11	3	3
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	1086.63	832.61	792.35	851.02	553.94	684	883.78	569.54	1007.12	768.57	773.26	736.25
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	1703.03	1196.20	968.54	1024.14	660.37	828.33	1029.13	726.08	1636.04	1046.69	905.5	1119.69
BOD5 (mg/L) Raw Sewage Influent Average Monthly	371.25	234.90	329.50	307.5	239.40	313.75	400.00	286.60	353.50	426.25	366	224.25
TSS (lbs/day) Average Monthly	10.84	21.55	4.52	21.61	10.08	15.71	16.43	8.36	29.17	12.62	12.43	9.16
TSS (lbs/day) Raw Sewage Influent Average Monthly	840.55	376.78	305.89	365.38	163.03	153.26	251.38	247.65	287.98	240.70	219.66	257.04
TSS (lbs/day) Raw Sewage Influent Daily Maximum	2203.30	544.03	359.82	499.42	213.41	228.06	294.04	364.06	484.75	422.05	250.41	339.52
TSS (lbs/day) Weekly Average	13.60	45.67	6.15	9.70	13.27	33.26	30.97	16.98	89.35	30.99	35.18	13.52

**NPDES Permit Fact Sheet
Spring Grove Borough STP**

NPDES Permit No. PA0266086

TSS (mg/L) Average Monthly	3.75	5.60	2.25	4.0	4.80	8.25	8.5	4.40	8.25	7	6.2	3
TSS (mg/L) Raw Sewage Influent Average Monthly	300	106.40	129.50	97.0	70.40	70.50	114.0	124.40	100.00	135	105.20	79
TSS (mg/L) Weekly Average	5.0	10.0	3.0	9.00	7	17	17	9.00	20.00	17	18	4
Fecal Coliform (CFU/100 ml) Geometric Mean	1.57	1.64	1.50	1.41	2.40	5.83	5.67	1.57	8.24	12.86	1.26	1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	3	3.00	5	2	5	16.00	146	6.00	770.00	117	2	1
UV Intensity (mW/cm ²) Minimum	383	202	281	336	255	172	183	82	99	62	282	394
Nitrate-Nitrite (mg/L) Average Monthly	2.14	1.81	1.73	2.16	2.07	2.20	1.71	1.21	0.84	0.81	1.07	1.38
Nitrate-Nitrite (lbs) Total Monthly	174.33	186.85	95.11	168.16	139.14	137.62	110.07	2.30	2.15	46.92	64.38	131.95
Total Nitrogen (mg/L) Average Monthly	3.29	2.42	2.23	2.77	3.18	3.78	3.39	2.64	2.76	7.86	1.84	1.91
Total Nitrogen (lbs) Effluent Net Total Monthly	277.34	252.70	122.93	217.44	213.44	235.25	216.55	151.26	206.43	470.71	109.86	182.46
Total Nitrogen (lbs) Total Monthly	277.34	252.70	122.93	217.44	213.44	235.25	216.55	151.26	6.66	470.71	109.86	182.46
Total Nitrogen (lbs) Effluent Net Total Annual								2026.14				
Total Nitrogen (lbs) Total Annual								2026.14				
Ammonia (lbs/day) Average Monthly	0.37	0.37	0.20	0.25	0.22	0.35	1.39	1.37	1.92	8.16	0.22	0.3
Ammonia (mg/L) Average Monthly	0.14	0.11	0.10	0.10	0.10	0.17	0.67	0.70	0.82	4.18	0.11	0.1
Ammonia (lbs) Total Monthly	11.10	11.42	5.55	7.79	6.76	10.37	43.11	41.04	52.96	252.92	6.61	9.44
Ammonia (lbs) Total Annual								700.22				
TKN (mg/L) Average Monthly	1.15	0.61	0.50	0.61	1.11	1.57	1.68	1.43	1.92	7.05	0.77	0.53
TKN (lbs) Total Monthly	103.02	65.85	27.82	49.28	74.30	97.63	106.47	82.31	139.69	423.79	45.48	50.51

**NPDES Permit Fact Sheet
Spring Grove Borough STP**

NPDES Permit No. PA0266086

Total Phosphorus (lbs/day) Average Monthly	0.30	0.63	0.21	0.32	0.34	0.68	0.31	0.21	0.59	4.03	2.84	1.51
Total Phosphorus (mg/L) Average Monthly	0.11	0.17	0.11	0.13	0.16	0.33	0.15	0.11	0.24	2.13	1.44	0.49
Total Phosphorus (lbs) Effluent Net Total Monthly	9.09	19.61	5.94	9.78	10.39	20.54	9.74	6.40	18.44	124.98	85.32	46.90
Total Phosphorus (lbs) Total Monthly	9.09	19.61	5.94	9.78	10.39	20.54	9.74	6.40	18.44	124.98	85.32	46.90
Total Phosphorus (lbs) Effluent Net Total Annual								541.97				
Total Phosphorus (lbs) Total Annual								541.97				

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.33</u>
Latitude <u>39° 52' 24.00"</u>	Longitude <u>-76° 51' 28.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing limits of 21.0 mg/L monthly average (AML), 32.0 mg/L weekly average, and 42.0 mg/L instantaneous maximum (IMAX) will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 21 \text{ mg/L} \times 0.33 \text{ MGD} \times 8.34 = 57.8 \text{ (57.0) lbs/day} \\ \text{Average weekly mass limit: } & 32 \text{ mg/L} \times 0.33 \text{ MGD} \times 8.34 = 88.1 \text{ lbs/day} \end{aligned}$$

Ammonia (NH₃-N):

NH₃-N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	20°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	25°C	(Default)
*	Background NH ₃ -N	=	0 mg/L	(Default)

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 25.0 mg/L as a monthly average and 50.0 mg/L IMAX are necessary to protect the aquatic life from toxicity effects at the point of discharge. However, the existing limits of 7.5 mg/L monthly average & 15.0 mg/L IMAX will remain in the proposed permit. The winter effluent limit will be set at three-times the summer limits. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\text{Average monthly mass limit: } 7.5 \text{ mg/L} \times 0.33 \text{ MGD} \times 8.34 = 20.64 \text{ (20.0) lbs/day}$$

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BPNPSM-PMT-033 and has been applied to other point source dischargers throughout the state.

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:

As recommended by DEP's SOP no. BPNPSM-PMT-033, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa Code §92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/week will be included in the permit to be consistent with the recommendation from this SOP.

UV:

The UV system monitor and report the UV intensity (mW/cm²) after update to replace chlorine disinfection to UV disinfection system will remain in the proposed permit.

Total Suspended Solids (TSS):

The existing technology-based limits of 30.0 mg/L average monthly, 45.0 mg/L weekly average, and 60.0 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 30 \text{ mg/L} \times 0.33 \text{ MGD} \times 8.34 = 82.57 \text{ (82.0) lbs/day} \\ \text{Average weekly mass limit: } & 45 \text{ mg/L} \times 0.33 \text{ MGD} \times 8.34 = 123.8 \text{ (123.0) lbs/day} \end{aligned}$$

Total Phosphorus:

Previous permit had average monthly concentration monitoring requirement 2.0 mg/l and instantaneous maximum limit of 4.0 mg/l. Accordingly, existing TP limits will remain in the proposed permit. See the EPA guidance, Nutrient Criteria Technical Guidance Manual – Rivers and Streams, 07/2000 EPA-822-B-00-002, for more information about nutrient impacts on streams. Mass limits are calculated as follows:

$$\text{Average monthly mass limit: } 2.0 \text{ mg/L} \times 0.33 \text{ MGD} \times 8.34 = 5.5 \text{ lbs/day}$$

Toxics:

DEP utilizes a Toxics Management Spreadsheet (last modified on March 2021 ver. 1.3) to facilitate calculations necessary for completing a reasonable potential analysis and determining WQBELs for toxic pollutants. The worksheet output indicates that there are no toxic pollutants of concern.

Chesapeake Bay TMDL:

In the Phase 2 WIP Wastewater Supplement revised on December 17, 2019, Attachment C-Non Significant Discharges with Cap Loads in NPDES Permits (pages # 27-28) of this document shows that Spring Grove Borough has been allocated 7,306 lbs/year of TN and 974 lbs/year of TP. This approach is consistent with the Chesapeake Bay TMDL and was based on the actual performance data previously evaluated by the Department. Since the permittee is easily capable of achieving compliance with these loads, the Department determines that no "compliance schedule" for the requirements associated with the Chesapeake Bay Strategy is necessary. Accordingly, the Chesapeake Bay nutrient existing limitations and monitoring requirements will remain in the proposed permit.

However, the facility design flow is 0.33 MGD less than 0.4 MGD and the discharge from facility is non-significant; then the Chesapeake Bay nutrient monitoring frequency will be one per week. Therefore, the monitoring frequency of Chesapeake Bay nutrient (i.e., Ammonia-N, Kjeldahl-N, Nitrate-Nitrite as N, and Total Phosphorus) will change from two (2) per week to one (1) per week in the proposed permit.

Biosolids Management

Sludge is digested on-site, via an aerobic sludge digester, and removed by a certified hauler.

Stormwater

There is no known stormwater outfall associated with this facility.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

303(d) Listed Streams:

This discharge is not located on a 303(d) listed stream segment.

Additional Considerations

Flow Monitoring

Flow monitoring is recommended by the permit guidance and is also required by 25 Pa. Code §§ 92a.27 and 92a.61.

Influent Monitoring

As a result of negotiation with EPA, influent monitoring of TSS and BOD₅ are required for any POTWs; therefore, influent sampling of BOD₅ and TSS will be included in the draft permit. A 24-hr composite sample type will be required to be consistent with the proposed sampling frequency for TSS and CBOD₅ in the effluent.

Total Dissolved Solids (TDS)

Total Dissolved Solids and its major constituents including Bromide, Chloride, and Sulfate have become statewide pollutants of concern and threats to DEP's mission to prevent violations of water quality standards. The requirement to monitor these pollutants is necessary under the following DEP Central Office directive:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

- *Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.*
- *Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.*

The facility has no record of monitoring these pollutants. However, the application shows a maximum influent concentration of 484 mg/L for TDS. The effluent concentration is not expected to exceed 1,000 mg/L. No monitoring is necessary.

Local TMDL

According to eMapPA (<http://www.emappa.dep.state.pa.us/emappa/viewer.htm>), the proposed discharge will be located in a stream segment listed as attaining uses. Considering nature of the discharge, the facility will not contribute to the impairment. No local TMDL has been taken into consideration during this permit review process.

Mass Loading Limitation

All mass loading effluent limitations recommended in the draft permit are concentration-based, calculated using a formula: design flow (MGD) x concentration limit (mg/L) x conversion factor of 8.34.

Compliance Schedule- Section C


A compliance schedule will be removed from the proposed permit due to the upgrade and expansion project was completed as follows.

Notice to Proceed: January 20, 2016
Substantial Completion: June 30, 2017

WQM 7.0

Node 1: Point of first use on Codorus Creek (08032)
Elevation: 434.7 ft (USGS National Map Viewer)
Drainage Area: 74.0 mi² (USGS PA StreamStats)
River Mile Index: 26.4 (PA DEP eMapPA)
Low Flow Yield: 0.12 cfs/mi²
Discharge Flow: 0.33 MGD

Node 2: Just before confluence of 08208
Elevation: 433.3 ft (USGS National Map Viewer)
Drainage Area: 74.1 mi² (USGS PA StreamStats)
River Mile Index: 25.7 (PA DEP eMapPA)
Low Flow Yield: 0.12 cfs/mi²
Discharge Flow: 0.000 MGD



**NPDES Permit Fact Sheet
Spring Grove Borough STP**

NPDES Permit No. PA0266086

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	74	square miles
BSLOPD	Mean basin slope measured in degrees	5.6435	degrees
ROCKDEP	Depth to rock	4.5	feet
URBAN	Percentage of basin with urban development	3.5294	percent

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	74	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	5.6435	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.5	feet	4.13	5.21
URBAN	Percent Urban	3.5294	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	16.2	ft ³ /s	46	46
30 Day 2 Year Low Flow	20.4	ft ³ /s	38	38
7 Day 10 Year Low Flow	8.51	ft ³ /s	51	51
30 Day 10 Year Low Flow	10.8	ft ³ /s	46	46
90 Day 10 Year Low Flow	15.3	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	74.1	square miles
BSLOPD	Mean basin slope measured in degrees	5.6404	degrees
ROCKDEP	Depth to rock	4.5	feet
URBAN	Percentage of basin with urban development	3.5465	percent

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	74.1	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	5.6404	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.5	feet	4.13	5.21
URBAN	Percent Urban	3.5465	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, SEp: Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	SEp
7 Day 2 Year Low Flow	16.2	ft ³ /s	46	46
30 Day 2 Year Low Flow	20.4	ft ³ /s	38	38
7 Day 10 Year Low Flow	8.51	ft ³ /s	51	51
30 Day 10 Year Low Flow	10.8	ft ³ /s	46	46
90 Day 10 Year Low Flow	15.3	ft ³ /s	41	41

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.

Analysis Results WQM 7.0

Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | Effluent Limitations

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
26.40	Spring Grove	PA0266086	0.3300

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	25	50	
Dissolved Oxygen			5

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

Analysis Results WQM 7.0

Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | Effluent Limitations

RMI	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
26.400	0.330	20.272	7.000
Reach Width (ft)	Reach Depth (ft)	Reach WD Ratio	Reach Velocity (fps)
50.879	0.800	63.572	0.231
Reach C-BOD5 (mg/L)	Reach Kc (1/days)	Reach NH3-N (mg/L)	Reach Kn (1/days)
3.25	0.577	1.36	0.715
Reach DO (mg/L)	Reach Kr (1/days)	Kr Equation	Reach DO Goal (mg/L)
8.067	0.835	Tsivoglou	5

Reach Travel Time (days): 0.185

Subreach Results			
TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
0.019	3.22	1.34	7.95
0.037	3.18	1.32	7.84
0.056	3.15	1.31	7.73
0.074	3.11	1.29	7.62
0.093	3.08	1.27	7.51
0.111	3.05	1.26	7.41
0.130	3.01	1.24	7.32
0.148	2.98	1.22	7.22
0.167	2.95	1.21	7.13
0.185	2.92	1.19	7.04

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

rptEffLimits

WQM 7.0 Effluent Limits

WQM No.	Stream Code	Parameter	Unit	Frequency	Method	Limit	Notes
26.02	Spring Grove	PHOSPHORUS	mg/L	30 Day Avg	0.20	0.20	
		NITRGEN	mg/L	30 Day Avg	20	20	
		Dissolved Oxygen	% Sat			2	

Wednesday, June 9, 2021 Version 1.0b Page 1 of 1

Page: 1 No Filter

rpt_WLA

WQM 7.0 Wasteload Allocations

WQM No.	Stream Code	Parameter	Unit	Frequency	Method	Limit	Notes
Non-Point Allocations							
26.02	Spring Grove	PHOSPHORUS	mg/L	30 Day Avg	0.20	0.20	
Non-Point Allocations							
26.02	Spring Grove	NITRGEN	mg/L	30 Day Avg	20	20	
Dissolved Oxygen Allocations							
26.02	Spring Grove	Dissolved Oxygen	% Sat			2	

Wednesday, June 9, 2021 Version 1.0b Page 1 of 1

Page: 1 No Filter

rptDOSim

WQM 7.0 D.O. Simulation

WQM No.	Stream Code	Parameter	Unit	Frequency	Method	Limit	Notes
26.02	Spring Grove	Dissolved Oxygen	% Sat			2	

Wednesday, June 9, 2021 Version 1.0b Page 1 of 1

Page: 1 No Filter

rptModelSpecs

WQM 7.0 Modeling Specifications

Point Load	Yes	Use Input at C1 and C20 if P1 is	<input checked="" type="checkbox"/>
WLA Method	EMPH	Use Input at WLA Ratio	<input type="checkbox"/>
C1 Input to Ratio	0.00	Use Input at Reach Travel Time	<input type="checkbox"/>
C20 Input to Ratio	1.00	Temperature Adjust K ₁	<input type="checkbox"/>
C2 Substrate	0.00%	Use Reduced Technology	<input checked="" type="checkbox"/>
C20 Load	0		

Wednesday, June 9, 2021 Version 1.0b Page 1 of 1

Page: 1 No Filter

rptHydro

WQM 7.0 Hydrodynamic Outputs

Flow	Flow Rate	Flow Area	Flow Velocity	Flow Depth	Flow Slope	Flow Velocity	Flow Depth	Flow Slope	Flow Velocity	Flow Depth	Flow Slope	Flow Velocity	Flow Depth	Flow Slope
Q1-10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Q2-10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Q3-10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Wednesday, June 9, 2021 Version 1.0b Page 1 of 1

Page: 1 No Filter

rptGeneral

Input Data WQM 7.0

WQM Basin	Flow Code	Flow Name	Flow Rate	Flow Area	Flow Velocity	Flow Depth	Flow Slope	Flow Velocity	Flow Depth	Flow Slope	Flow Velocity	Flow Depth	Flow Slope
071	WQ	COOPERATION	26.00	425.00	76.00	0.00000	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Parameter Data

Parameter Name	Flow Code	Flow Area	Flow Velocity	Flow Depth	Flow Slope	Flow Velocity	Flow Depth	Flow Slope
CH2O	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Disinfect Chlorine	0.00	8.24	0.00	0.00	0.00	0.00	0.00	0.00
NH3N	0.00	0.00	0.00	0.00	0.70	0.00	0.00	0.00

Wednesday, June 9, 2021 Version 1.0b Page 1 of 2

Page: 1 No Filter

rptGeneral

Input Data WQM 7.0

WQM Basin	Flow Code	Flow Name	Flow Rate	Flow Area	Flow Velocity	Flow Depth	Flow Slope	Flow Velocity	Flow Depth	Flow Slope	Flow Velocity	Flow Depth	Flow Slope
071	WQ	COOPERATION	26.00	425.00	76.00	0.00000	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Parameter Data

Parameter Name	Flow Code	Flow Area	Flow Velocity	Flow Depth	Flow Slope	Flow Velocity	Flow Depth	Flow Slope
CH2O	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Disinfect Chlorine	0.00	8.24	0.00	0.00	0.00	0.00	0.00	0.00
NH3N	0.00	0.00	0.00	0.00	0.70	0.00	0.00	0.00

Wednesday, June 9, 2021 Version 1.0b Page 2 of 2

Page: 2 No Filter

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD ₅	57	88	XXX	21	32	42	1/week	24-Hr Composite
TSS	82	123	XXX	30	45	60	1/week	24-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Ammonia May 1 - Oct 31	20	XXX	XXX	7.5	XXX	15	2/week	24-Hr Composite
Ammonia Nov 1 - Apr 30	61	XXX	XXX	22.5	XXX	45	2/week	24-Hr Composite
Total Phosphorus	5.5	XXX	XXX	2.0	XXX	4.0	2/week	24-Hr Composite

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/week	24-hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	24-hr Composite
Net Total Nitrogen	Report	7,306	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	974	XXX	XXX	XXX	XXX	1/month	Calculation

Proposed Effluent Limitations and Monitoring Requirements
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD ₅	57.0	88.0 Wkly Avg	XXX	21.0	32.0	42.0	1/week	24-Hr Composite
TSS	82.0	123.0 Wkly Avg	XXX	30.0	45.0	60.0	1/week	24-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/week	Grab
Ammonia May 1 - Oct 31	20.0	XXX	XXX	7.5	XXX	15.0	1/week	24-Hr Composite
Ammonia Nov 1 - Apr 30	61.0	XXX	XXX	22.5	XXX	45.0	1/week	24-Hr Composite
Total Phosphorus	5.5	XXX	XXX	2.0	XXX	4.0	1/week	24-Hr Composite

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	1/week	24-hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	1/week	24-hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/week	24-hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/week	24-hr Composite
Net Total Nitrogen	Report	7,306	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	974	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]