

|                  |                      |  |                  |   |
|------------------|----------------------|--|------------------|---|
| Application Type | <u>Renewal</u>       | <b>NPDES/WQM PERMIT FACT SHEET<br/>INDIVIDUAL SEWAGE</b> | Application No.  | <u>PA0083038 &amp;<br/>0186410 T-2<br/>WQM</u>  |
| Facility Type    | <u>Non-Municipal</u> |  | APS ID           | <u>996218<br/>1278384 &amp;<br/>1278395-WQM</u> |
| Major / Minor    | <u>Minor</u>         |  | Authorization ID | <u>1278395-WQM</u>                              |

**Applicant and Facility Information**

|                           |   |                  |   |
|---------------------------|---|------------------|---|
| Applicant Name            | <u>Tripwire Operations Group LLC</u>                | Facility Name    | <u>1685 Baltimore Pike Office Building</u>          |
| Applicant Address         | <u>1685 Baltimore Pike<br/>Gettysburg, PA 17325</u> | Facility Address | <u>1685 Baltimore Pike<br/>Gettysburg, PA 17325</u> |
| Applicant Contact         | <u>Ryan Morris</u>                                  | Facility Contact | <u>Ryan Morris</u>                                  |
| Applicant Phone           | <u>(717) 648-2792</u>                               | Facility Phone   | <u>(717) 648-2792</u>                               |
| Client ID                 | <u>299617</u>                                       | Site ID          | <u>625</u>  |
| Ch 94 Load Status         | <u>Not Overloaded</u>                               | Municipality     | <u>Mount Joy Township</u>                           |
| Connection Status         | <u></u>   | County           | <u>Adams</u>  |
| Date Application Received | <u>June 13, 2019</u>                                | EPA Waived?      | <u>Yes</u>  |
| Date Application Accepted | <u>June 27, 2019</u>                                | If No, Reason    | <u></u>   |
| Purpose of Application    | <u>NPDES permit renewal.</u>                        |                  |   |

**Summary of Review**

On October 21, 2013, an existing NPDES permit No. PA0083038 (for the sewer treatment plan (STP) issued on August 12, 2013 and expired on August 31, 2018) was transferred to Mr. Ryan J. Morris, Owner. However, Mr. Morris failed to submit an application for reissuance of the permit at least 180 days prior to the expiration of the permit (permission had not been granted for a later date by the Department). Due to the discharge of treated sewage to waters of the Commonwealth without a valid NPDES permit from August 31, 2018 to April 3<sup>rd</sup>, 2019 an "Administrative Order" was mailed by the Department, per Water & Wastewater Systems Operators Certification Act (63 P.S. §§1001-1015.1), & Sections 201 & 202 of the Clean Streams Law, 35 P.S. §§ 691.201 & 691.202. The April 3<sup>rd</sup>, 2019, Administrative Order states "Until the Department issues a renewed NPDES permit for STP, Mr. Morris shall comply with the terms and conditions included in the expired NPDES permit PA0083038."

On June 13, 2019, the Department received a NPDES permit No. PA0083038 renewal application for discharge of treated sewage located in Mount Joy Township, Adams County which was prepared by Mr. Morris in response to the April 3<sup>rd</sup>, 2019 Administrative Order. This facility formerly known as Jack Waybrant Family Limited Partnership was transferred to Ryan J. Morris on October 21, 2013. The renewal application permit also noted that the original name changed from Ryan Morris to Tripwire Operations Group LLC (owned by Mr. Morris).

WQM permit No. 0186410 was originally issued on January 7, 1987. It will be transferred in conjunction with issuance of the final NPDES permit.

Changes from the previous permit: Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml. The average monthly limit of NH<sub>3</sub>-N changed from 6.5 mg/L to 6.0 mg/L. TRC limit of 0.48 mg/L monthly average and 1.48 mg/L IMAX changed to 0.40 mg/L monthly average and 1.4 mg/L IMAX.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

| Approve | Deny | Signatures  | Date            |
|---------|------|---|-----------------|
| X       |      | Hilary H. Le / Environmental Engineering Specialist     | August 21, 2019 |
|         |      | Daniel W. Martin, P.E. / Environmental Engineer Manager |                 |
|         |      | Maria D. Bebenek, P.E. / Clean Water Program Manager    |                 |

| Discharge, Receiving Waters and Water Supply Information |                                       |                              |                      |
|--|---------------------------------------|------------------------------|----------------------|
| Outfall No.  | 001                                   | Design Flow (MGD)            | 0.005                |
| Latitude   | 39° 48' 12.56"                        | Longitude                    | -77° 12' 33.42"      |
| Quad Name  | Gettysburg                            | Quad Code                    |                      |
| Wastewater Description: Sewage Effluent                  |                                       |                              |                      |
| Receiving Waters   | Unnamed Tributary to Rock Creek (WWF) | Stream Code                  | 59139                |
| NHD Com ID   | 53320378                              | RMI                          | 0.10 mi.             |
| Drainage Area  | 0.53 mi. <sup>2</sup>                 | Yield (cfs/mi <sup>2</sup> ) | See comments below   |
| Q <sub>7-10</sub> Flow (cfs)                             | See comments below                    | Q <sub>7-10</sub> Basis      | USGS StreamStats     |
| Elevation (ft)   | 447.24 ft                             | Slope (ft/ft)                |                      |
| Watershed No.  | 13-D                                  | Chapter 93 Class.            | WWF                  |
| Existing Use   |                                       | Existing Use Qualifier       |                      |
| Exceptions to Use  |                                       | Exceptions to Criteria       |                      |
| Assessment Status  | Attaining Use(s)                      |                              |                      |
| Cause(s) of Impairment                                   |                                       |                              |                      |
| Source(s) of Impairment                                  |                                       |                              |                      |
| TMDL Status  |                                       | Name                         |                      |
| Nearest Downstream Public Water Supply Intake            | City of Frederick, MD                 |                              |                      |
| PWS Waters   | Monocacy River                        | Flow at Intake (cfs)         |                      |
| PWS RMI  |                                       | Distance from Outfall (mi)   | Approximate 40 miles |

Changes Since Last Permit Issuance: none

*Drainage Area*

The discharge is to Unnamed Tributary 59139 to Rock Creek at RMI 0.10 mile. A drainage area upstream of the discharge is estimated to be 0.53 mi.<sup>2</sup>, according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

*Streamflow*

There are no nearby stream gages with low flow data that have extensive or recent periods of record. Since USGS PA StreamStats estimated the drainage area that is below the minimum value allowed by USGS's regression equations, the USGS gage station No. 59041 on Rock Creek watershed (at the PA/MD border) will be used to calculate the Q<sub>7-10</sub> at the point of discharge using a low flow yield method. The Q<sub>7-10</sub> here is 2.52 cfs and the drainage area is 63.6 mi.<sup>2</sup> which results in a Q<sub>7-10</sub> low flow yield of 0.04 cfs/mi.<sup>2</sup>. This information is used to obtain a chronic or 30-day (Q<sub>30-10</sub>), and an acute or 1-day (Q<sub>1-10</sub>) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned} \text{Low Flow Yield} &= Q_{7-10\text{gage}} / \text{Drainage Area}_{\text{gage}} = 2.52 \text{ cfs} / 63.6 \text{ mi.}^2 = 0.04 \text{ cfs/mi.}^2 \\ Q_{7-10\text{discharge}} &= 0.04 \text{ cfs/mi.}^2 * \text{Drainage Area}_{\text{discharge}} = 0.04 \text{ cfs/mi.}^2 * 0.53 \text{ mi.}^2 = 0.021 \text{ cfs} \\ Q_{30-10} &= 1.36 * Q_{7-10\text{discharge}} = 1.36 * 0.021 \text{ cfs} = 0.029 \text{ cfs} \\ Q_{1-10} &= 0.64 * Q_{7-10\text{discharge}} = 0.64 * 0.021 \text{ cfs} = 0.013 \text{ cfs} \end{aligned}$$

*Potable Water Supply Intake*

The nearest downstream public water supply intake is the City of Frederick, MD intake on the Monocacy River, approximately 40 miles from the point of discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

| Treatment Facility Summary   |                                  |                      |                     |                        |
|--|----------------------------------|----------------------|---------------------|------------------------|
| <b>Treatment Facility Name:</b> 1685 Baltimore Pike Office Building WWTP |                                  |                      |                     |                        |
| <b>WQM Permit No.</b>  |                                  | <b>Issuance Date</b> |                     |                        |
| 0186410  |                                  | 1/7/1987             |                     |                        |
| 0186410 T-1  |                                  | 10/21/2013           |                     |                        |
| Waste Type   | Degree of Treatment              | Process Type         | Disinfection        | Avg Annual Flow (MGD)  |
| Sewage   | Secondary With Ammonia Reduction | Extended Aeration    | Hypochlorite        | 0.005                  |
| Hydraulic Capacity (MGD)   | Organic Capacity (lbs/day)       | Load Status          | Biosolids Treatment | Biosolids Use/Disposal |
| 0.005  |                                  | Not Overloaded       | Anaerobic Digestion | Other WWTP             |

Changes Since Last Permit Issuance: none

The WWTP train is as follows:

The treatment process is as follows: Bar Screen (1) – Aeration Tanks (2) – Settling Tank (1) – Tablet Chlorinator (1) – Chlorination Contact Tank (1) – Post Aeration Tank (1) – Sludge Holding Tank (1) - Discharge (Outfall to Unnamed Tributary to Rock Creek).

Calcium hypochlorite tablets are used for disinfection. Soda ash is used to control pH. A sludge holding tank is used for solids storage.

| <b>Compliance History</b>      |  |
|--------------------------------|--|
| <b>Summary of DMRs:</b>        | A summary of past 12-month DMR is presented on the next page.  |
| <b>Summary of Inspections:</b> | <p>2/14/19: Department conducted a follow up on a previous inspection on 11/13/18. No records for November 2018 through February 2019. No DMRs for November 2018 through February 2019 received by the Department. A change of operator notice has not been received by the Department since the resignation of the previous certified operator on October 31, 2018. There were violations identified during inspection such as: the NPDES permit No. PA0083038 expired on August 31, 2018, thus an unauthorized and unpermitted discharge of sewage to waters of the Commonwealth is in violation of the Clean Stream Law, Sections 201 &amp; 202.</p> <p>11/13/18: Department conducted an inspection. The effluent had a slight haze and a yellow tint in appearance. The results of grab sample were pH = 7.73 S.U., D.O. = 10.67 mg/L, and TRC = 0.31 mg/L with a temperature of 10.0 degree Celsius. They indicated under permit limit. There were violations identified during inspection such as (1) failure to retain records as required by NPDES permit No. PA0083038 Part A.III.A.2, (2) failure to employ a certified wastewater treatment operator in violation of NPDES permit No. PA0083038 Part B Section I.E.1., and (3) NPDES permit No. PA0083038 expired on August 31, 2018 without renewal. And requested Mr. Morris to correspond to a NOV dated 11/2/18 by 12/1/18.</p> <p>11/2/18: Department conducted an administrative review of its files for the STP and NPDES permit. During the inspection, the Department noted that Mr. Morris allowed the NPDES permit No. PA0083038 to expire on August 31, 2018, without submitting to the Department an application for permit reissuance.</p> |
| <b>Notice of Violations:</b>   | <ul style="list-style-type: none"> <li>- 3/19/18 NOV: Grab sample on 2/26/18 exceeded the IMAX limit for TSS contained in NPDES permit, such as TSS reported 74 mg/L while IMAX limit is 60 mg/L in NPDES permit.</li> <li>- 4/23/18 NOV: NPDES permit renewal application was not received.</li> <li>- 11/2/18 NOV: NPDES-Discharge of pollutants from a point source into surface waters without an NPDES permit.</li> <li>- 11/28/18 NOV: Failed to employ a certified wastewater treatment operator since 11/1/18, and to retain all monitoring records at the facility for a period of three (3) years.</li> </ul>  |
| <b>Other Comments:</b>         | <p>DEP's database; there are four (4) open violations associated with this facility. Based on a conversation with DEP Operations Section, these violations will be closed/resolved in the near future.</p> <p>Additionally, the April 3<sup>rd</sup>, 2019 Administrative Order document was mailed by the Department; pursuant to Sections 5, 402, and 610 of the Clean Stream Law, 35 P.S. §§ 691.5, 691.402, &amp; 691.610, Section 1917-A of the Administrative Code, 71 P.S. § 510-7, 63 P.S. §§ 1001-1015.1, and 25 Pa Code § 302.1202(a)(1)-(5); the NPDES permit No. PA0083038 had expired on August 31, 2018, the discharge from STP to waters of the Commonwealth without authorization since August 31, 2018, and failure to employ certified operator at STP since November 1, 2018.</p>   |

Compliance History

DMR Data for Outfall 001 (from July 1, 2018 to June 30, 2019)

| Parameter  | JUN-19  | MAY-19  | APR-19       | MAR-19       | FEB-19 | JAN-19 | DEC-18 | NOV-18 | OCT-18       | SEP-18       | AUG-18       | JUL-18       |
|--|---------|---------|--------------|--------------|--------|--------|--------|--------|--------------|--------------|--------------|--------------|
| Flow (MGD)<br>Average Monthly                              | 0.00028 | 0.00028 | 0.00016<br>6 | 0.00027<br>5 |        |        |        |        | 0.00026      | 0.00023<br>6 | 0.00019<br>5 | 0.00030<br>3 |
| Flow (MGD)<br>Daily Maximum                                | 0.00075 | 0.00102 | 0.00049      | 0.00034<br>8 |        |        |        |        | 0.00051<br>3 | 0.00028<br>7 | 0.00035<br>7 | 0.00041<br>8 |
| pH (S.U.)<br>Minimum                                       | 6.3     | 6.72    | 6.7          | 6.7          |        |        |        |        | 6.3          | 6.9          | 6.4          | 6.7          |
| pH (S.U.)<br>Maximum                                       | 6.98    | 7.18    | 7.71         | 6.8          |        |        |        |        | 7.9          | 7.8          | 8.2          | 8.3          |
| DO (mg/L)<br>Minimum                                       | 8.58    | 8.27    | 6.9          | 7.1          |        |        |        |        | 9.8          | 9.1          | 8.1          | 10.0         |
| TRC (mg/L)<br>Average Monthly                              | 0.20    | 0.07    | 0.10         | < 0.04       |        |        |        |        | 0.14         | 0.16         | 0.23         | 0.28         |
| TRC (mg/L)<br>Instantaneous<br>Maximum                     | 0.46    | 0.14    | 0.19         | 0.08         |        |        |        |        | 0.31         | 0.34         | 0.54         | 0.61         |
| CBOD5 (mg/L)<br>Average Monthly                            | < 2     | < 2     | 3            | < 2          |        |        |        |        | < 3.0        | < 3          | < 3          | < 2.9        |
| CBOD5 (mg/L)<br>Instantaneous<br>Maximum                   | < 2     | 2       | 3.7          | < 2          |        |        |        |        | < 3.0        | 3            | < 3          | 3.7          |
| TSS (mg/L)<br>Average Monthly                              | < 9     | 12      | < 5          | < 9          |        |        |        |        | 8            | 16           | 7            | 7            |
| TSS (mg/L)<br>Instantaneous<br>Maximum                     | 13      | 15      | < 5          | 13           |        |        |        |        | 10           | 23           | 7            | 9            |
| Fecal Coliform<br>(CFU/100 ml)<br>Geometric Mean           | 12      | 211     | < 1          | 374          |        |        |        |        | 78           | 29           | < 6          | < 10         |
| Fecal Coliform<br>(CFU/100 ml)<br>Instantaneous<br>Maximum | 28      | 240     | < 1          | 1470         |        |        |        |        | 84           | 32           | 38           | 94           |
| Ammonia (mg/L)<br>Average Monthly                          | 0.43    | < 0.1   | 0.632        | 0.275        |        |        |        |        | < 0.1        | < 0.1        | < 0.1        | 0.27         |
| Ammonia (mg/L)<br>Instantaneous<br>Maximum                 | 0.535   | < 0.1   | 0.863        | 0.344        |        |        |        |        | < 0.1        | < 0.1        | < 0.1        | 0.281        |

**Development of Effluent Limitations**

|   |   |
|---|---|
| <b>Outfall No.</b> <u>001</u>                         | <b>Design Flow (MGD)</b> <u>0.005</u>   |
| <b>Latitude</b> <u>39° 48' 12.35"</u>                 | <b>Longitude</b> <u>-77° 12' 33.27"</u> |
| <b>Wastewater Description:</b> <u>Sewage Effluent</u> |   |

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant                    | Limit (mg/l)    | SBC             | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD <sub>5</sub>            | 25              | Average Monthly | 133.102(a)(4)(i)   | 92a.47(a)(1)     |
|                              | 40              | Average Weekly  | 133.102(a)(4)(ii)  | 92a.47(a)(2)     |
| Total Suspended Solids       | 30              | Average Monthly | 133.102(b)(1)      | 92a.47(a)(1)     |
|                              | 45              | Average Weekly  | 133.102(b)(2)      | 92a.47(a)(2)     |
| pH                           | 6.0 – 9.0 S.U.  | Min – Max       | 133.102(c)         | 95.2(1)          |
| Fecal Coliform (5/1 – 9/30)  | 200 / 100 ml    | Geo Mean        | -                  | 92a.47(a)(4)     |
| Fecal Coliform (5/1 – 9/30)  | 1,000 / 100 ml  | IMAX            | -                  | 92a.47(a)(4)     |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml  | Geo Mean        | -                  | 92a.47(a)(5)     |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX            | -                  | 92a.47(a)(5)     |
| Total Residual Chlorine      | 0.5             | Average Monthly | -                  | 92a.48(b)(2)     |

**Water Quality-Based Limitations**

**Receiving Stream**

The receiving stream is an unnamed tributary of Rock Creek. According to 25 Pa. Code § 93.9z, this stream is protected for Warm Water (WWF) and Migratory Fishes (MF). It is located in Drainage List Z and State Watershed 13-D. It has been assigned stream code 59139. The 2012 PA Integrated Water Quality Report indicates that the Unnamed Tributary to Rock Creek is not impaired and there is no TMDL associated with this discharge.

**Flow**

Flow monitoring remains unchanged in the proposed permit and is recommended by the Table 6-3 of the permit manual (ID No. 362-0400-001) & required by 25 Pa. Code §§ 92a.27 & 92a.61.

**pH**

pH limits and daily grab sample remain unchanged in the proposed permit and are required by 40 CFR §133.102 & recommended by the Table 6-3 of the permit manual (ID No. 362-0400-001).

**NH<sub>3</sub>-N Calculations**

NH<sub>3</sub>-N calculations will be based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the instream NH<sub>3</sub>-N criteria used in the attached computer model of the stream:

- STP Temp = 25°C (Default)
- Stream pH = 7.0
- Stream Temp = 25°C
- Background NH<sub>3</sub>-N = 0 mg/L (Assumed)

**CBOD<sub>5</sub> & NH<sub>3</sub>-N**

WQM7.0 is a steady state model that simplifies many natural processes into a reach-by-reach simulation that was used for the analysis. The attached computer printout of the WQM 7.0 stream model indicates secondary treatment is adequate to protect the water quality of the stream. CBOD<sub>5</sub> limits remain unchanged in the proposed permit and are required by 25 Pa. Code § 92a.47(a)(1). The instantaneous maximum limitation is determined by multiplying the average monthly by a factor of two to account for variability. Past DMRs and inspection reports show that the STP has been consistently achieving below this limitation.

The attached computer printout of the WQM 7.0 stream model also indicates that a summer limitation of 6.0 mg/L NH<sub>3</sub>-N as a monthly average is necessary to protect the aquatic life from toxicity effects. This limit is slightly more stringent than the existing limit of 6.5 mg/L, however past DMR and inspection report indicate the facility is capable of meeting the new

limitation. Therefore, an average monthly limit of 6.0 mg/L NH<sub>3</sub>-N will be written in the proposed permit. Winter limit is 3 times the summer limit.

**Fecal Coliform**

Fecal Coliform limits and 2/month grab sample remain unchanged in the proposed permit as per 25 Pa. Code § 92a.47(a)(4) & (5).

**Dissolved Oxygen (D.O.)**

The existing permit contains a limit of 5.0 mg/L for D.O. DEP's Technical Guidance for the Development and Specification of Effluent Limitations (ID No. 362-0400-001, 10/97) suggests that either the adopted minimum stream D.O. criteria for the receiving stream or the effluent level determined through water quality modeling be used for the limit. Since the WQM 7.0 model was run using a minimum D.O. of 5.0 mg/L, this limit will be continued in the renewed permit with a daily monitoring requirement per DEP guidance.

**Total Residual Chlorine (TRC)**

The attached computer printout utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for TRC (ID No. 391-2000-015) for developing chlorine limitations. The Guidance references 25 Pa. Code § 92.2d(3) which establishes a standard BAT limit of 0.5 mg/l unless a facility-specific BAT has been developed. The attached printout indicates that a water quality limit of 0.4 mg/L monthly average and 1.3 mg/L IMAX would be needed to prevent toxicity concerns. This limit is slightly more stringent than the existing limit. Past DMR and inspection data indicates the facility has capability to meet the limit with some adjustment in operation. Therefore, it is recommended that a TRC limit of 0.40 mg/L monthly average and 1.40 mg/L IMAX be applied for the proposed permit.

**Total Suspended Solids (TSS)**

There are no water quality criteria for TSS. A limit of 30 mg/L is the required minimum level of effluent quality attainable by secondary treatment as defined in EPA's 40 CFR Chapter 1, Part 133, Section 133.102(b), in the existing permit will remain. 2/month grab sample will remain in the proposed permit.

**Toxics**

The facility treats mainly domestic sewage, there are no parameters of concern associated with this discharge.

**Chesapeake Bay Strategy**

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized based on their delivered TN and TP loadings to the Bay. The highest priority (Phases I, II, and III) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6.0 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets if approved by DEP. Phase IV (0.2 - 0.4 MGD) and Phase V (below 0.2 MGD) will be required to monitor and report TN and TP during permit renewal. Any facility in Phases IV and V that undergoes expansion is subjected to cap load right away. This facility is 0.005 MGD plant, classified as a Phase V, and will be required to monitor and report TN and TP throughout next permit cycle. Consistent with SOP for establishing effluent limitation for individual sewage permit, annual monitoring frequency for nutrients is required for this discharge. Annual monitoring and report, and sample type will remain in the proposed permit.

**Anti-backsliding**

Not applicable to this permit.

**Class A Wild Trout Fisheries**

No Class A Wild Trout Fisheries are impacted by this discharge.

**Antidegradation (93.4)**

The effluent limits for this discharge have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**Attachment**

It is a WQM7.0 data.



20190819144958252  
.pdf

WQM 7.0 MODEL INPUT

1. Outfall 001 on Trib 59139 to Rock Creek
  - a. Elevation: 447.24 ft
  - b. RMI: 9.96 miles to Monocacy River located at PA & MD boundaries
  - c. Drainage Area: 0.53 mi<sup>2</sup>
  - d. Low Flow Yield: 0.04 cfs/mi<sup>2</sup>
  - e. Discharge Flow: 0.005 MGD
2. Just before 59041 to Rock Creek
  - a. Elevation: 405.64 ft
  - b. RMI: 8.31 miles to Monocacy River located at PA & MD boundaries
  - c. Drainage Area: 24.7 mi<sup>2</sup>
  - d. Low Flow Yield: 0.04 cfs/mi<sup>2</sup>
  - e. Discharge Flow: 0.000 MGD

| TRC EVALUATION                              |   |                                |     |                                      |                     |
|---|---|--------------------------------|-----|--------------------------------------|---------------------|
| Input appropriate values in A3:A9 and D3:D9 |   |                                |     |                                      |                     |
| 3   | 0.021   | = Q stream (cfs)               | 0.5 | = CV Daily                           |                     |
| 4   | 0.005   | = Q discharge (MGD)            | 0.5 | = CV Hourly                          |                     |
| 5   | 30  | = no. samples                  | 1   | = AFC_Partial Mix Factor             |                     |
| 6   | 0.3   | = Chlorine Demand of Stream    | 1   | = CFC_Partial Mix Factor             |                     |
| 7   | 0   | = Chlorine Demand of Discharge | 15  | = AFC_Criteria Compliance Time (min) |                     |
| 8   | 0.5   | = BAT/BPJ Value                | 720 | = CFC_Criteria Compliance Time (min) |                     |
| 9   | 0   | = % Factor of Safety (FOS)     |     | = Decay Coefficient (K)              |                     |
| Source                                      | Reference   | AFC Calculations               |     | Reference                            | CFC Calculations    |
| TRC   | 1.3.2.iii   | WLA_afc = 0.885                |     | 1.3.2.iii                            | WLA_cfc = 0.855     |
| PENTOXSD TRG                                | 5.1a  | LTAMULT_afc = 0.373            |     | 5.1c                                 | LTAMULT_cfc = 0.581 |
| PENTOXSD TRG                                | 5.1b  | LTA_afc = 0.330                |     | 5.1d                                 | LTA_cfc = 0.497     |
| Source                                      | Effluent Limit Calculations   |                                |     |                                      |                     |
| PENTOXSD TRG                                | 5.1f  | AML_MULT = 1.231               |     |                                      |                     |
| PENTOXSD TRG                                | 5.1g  | AVG MON LIMIT (mg/l) = 0.406   |     | AFC                                  |                     |
|   |   | INST MAX LIMIT (mg/l) = 1.328  |     |                                      |                     |
| WLA_afc                                     | (.019/e <sup>-k*AFC_tc</sup> ) + [(AFC_Yc*Qs*.019/Qd*e <sup>-k*AFC_tc</sup> )]...<br>...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) |                                |     |                                      |                     |
| LTAMULT_afc                                 | EXP((0.5*LN(cvh <sup>2</sup> +1))-2.326*LN(cvh <sup>2</sup> +1) <sup>0.5</sup> )  |                                |     |                                      |                     |
| LTA_afc                                     | wla_afc*LTAMULT_afc   |                                |     |                                      |                     |
| WLA_cfc                                     | (.011/e <sup>-k*CFC_tc</sup> ) + [(CFC_Yc*Qs*.011/Qd*e <sup>-k*CFC_tc</sup> )]...<br>...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100) |                                |     |                                      |                     |
| LTAMULT_cfc                                 | EXP((0.5*LN(cvd <sup>2</sup> /no_samples+1))-2.326*LN(cvd <sup>2</sup> /no_samples+1) <sup>0.5</sup> )                        |                                |     |                                      |                     |
| LTA_cfc                                     | wla_cfc*LTAMULT_cfc   |                                |     |                                      |                     |
| AML_MULT                                    | EXP(2.326*LN((cvd <sup>2</sup> /no_samples+1) <sup>0.5</sup> )-0.5*LN(cvd <sup>2</sup> /no_samples+1))                        |                                |     |                                      |                     |
| AVG MON LIMIT                               | MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc)*AML_MULT)  |                                |     |                                      |                     |
| INST MAX LIMIT                              | 1.5*(av_mon_limit/AML_MULT)/LTAMULT_afc   |                                |     |                                      |                     |



**Existing Effluent Limitations and Monitoring Requirements**

| Parameter                                     | Effluent Limitations                |                        |                       |                    |                  |                     | Monitoring Requirements                            |                            |
|---|-------------------------------------|------------------------|-----------------------|--------------------|------------------|---------------------|--|----------------------------|
|   | Mass Units (lbs/day) <sup>(1)</sup> |                        | Concentrations (mg/L) |                    |                  |                     | Minimum <sup>(2)</sup><br>Measurement<br>Frequency | Required<br>Sample<br>Type |
|   | Average<br>Monthly                  | Daily<br>Maximum       | Minimum               | Average<br>Monthly | Daily<br>Maximum | Instant.<br>Maximum |  |                            |
| Flow (MGD)                                    | Report                              | Report                 | XXX                   | XXX                | XXX              | XXX                 | 1/week   | Weir                       |
| pH (S.U.)                                     | XXX                                 | XXX                    | 6.0                   | XXX                | XXX              | 9.0                 | 1/day  | Grab                       |
| D.O.  | XXX                                 | XXX                    | 5.0                   | XXX                | XXX              | XXX                 | 1/day  | Grab                       |
| TRC   | XXX                                 | XXX                    | XXX                   | 0.48               | XXX              | 1.58                | 1/day  | Grab                       |
| CBOD <sub>5</sub>                             | XXX                                 | XXX                    | XXX                   | 25                 | XXX              | 50                  | 2/month  | Grab                       |
| TSS   | XXX                                 | XXX                    | XXX                   | 30                 | XXX              | 60                  | 2/month  | Grab                       |
| Fecal Coliform (CFU/100 ml)<br>Oct 1 - Apr 30 | XXX                                 | XXX                    | XXX                   | 2,000<br>Geo Mean  | XXX              | 10,000              | 2/month  | Grab                       |
| Fecal Coliform (CFU/100 ml)<br>May 1 - Sep 30 | XXX                                 | XXX                    | XXX                   | 200<br>Geo Mean    | XXX              | 1,000               | 2/month  | Grab                       |
| Ammonia<br>Nov 1 - Apr 30                     | XXX                                 | XXX                    | XXX                   | 19.5               | XXX              | 39                  | 2/month  | Grab                       |
| Ammonia<br>May 1 - Oct 31                     | XXX                                 | XXX                    | XXX                   | 6.5                | XXX              | 13                  | 2/month  | Grab                       |
| Total Nitrogen                                | Report<br>Annl Avg                  | Report<br>Total Annual | XXX                   | Report<br>Annl Avg | XXX              | XXX                 | 1/year   | Calculation                |
| Total Phosphorus                              | Report<br>Annl Avg                  | Report<br>Total Annual | XXX                   | Report<br>Annl Avg | XXX              | XXX                 | 1/year   | 8-Hr<br>Composite          |

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

| Parameter                                     | Effluent Limitations                |                        |                       |                    |         |                  | Monitoring Requirements                      |                      |
|---|-------------------------------------|------------------------|-----------------------|--------------------|---------|------------------|--|----------------------|
|   | Mass Units (lbs/day) <sup>(1)</sup> |                        | Concentrations (mg/L) |                    |         |                  | Minimum <sup>(2)</sup> Measurement Frequency | Required Sample Type |
|   | Average Monthly                     | Average Weekly         | Minimum               | Average Monthly    | Maximum | Instant. Maximum |  |                      |
| Flow (MGD)                                    | Report                              | Report Daily Max       | XXX                   | XXX                | XXX     | XXX              | 1/week                                       | Weir                 |
| pH (S.U.)                                     | XXX                                 | XXX                    | 6.0                   | XXX                | XXX     | 9.0              | 1/day  | Grab                 |
| D.O.  | XXX                                 | XXX                    | 5.0                   | XXX                | XXX     | XXX              | 1/day  | Grab                 |
| TRC   | XXX                                 | XXX                    | XXX                   | 0.40               | XXX     | 1.40             | 1/day  | Grab                 |
| CBOD <sub>5</sub>                             | XXX                                 | XXX                    | XXX                   | 25                 | XXX     | 50               | 2/month                                      | Grab                 |
| TSS   | XXX                                 | XXX                    | XXX                   | 30                 | XXX     | 60               | 2/month                                      | Grab                 |
| Fecal Coliform (No./100 ml)<br>Oct 1 - Apr 30 | XXX                                 | XXX                    | XXX                   | 2,000<br>Geo Mean  | XXX     | 10,000           | 2/month                                      | Grab                 |
| Fecal Coliform (No./100 ml)<br>May 1 - Sep 30 | XXX                                 | XXX                    | XXX                   | 200<br>Geo Mean    | XXX     | 1,000            | 2/month                                      | Grab                 |
| Ammonia<br>Nov 1 - Apr 30                     | XXX                                 | XXX                    | XXX                   | 18.0               | XXX     | 36.0             | 2/month                                      | Grab                 |
| Ammonia<br>May 1 - Oct 31                     | XXX                                 | XXX                    | XXX                   | 6.0                | XXX     | 12.0             | 2/month                                      | Grab                 |
| Total Nitrogen                                | Report<br>Annl Avg                  | Report<br>Total Annual | XXX                   | Report<br>Annl Avg | XXX     | XXX              | 1/year                                       | Calculation          |
| Total Phosphorus                              | Report<br>Annl Avg                  | Report<br>Total Annual | XXX                   | Report<br>Annl Avg | XXX     | XXX              | 1/year                                       | 8-Hr<br>Composite    |

Compliance Sampling Location:

Other Comments:

| Tools and References Used to Develop Permit |  |
|---|--|
| <input checked="" type="checkbox"/>         | WQM for Windows Model (see Attachment [redacted])  |
| <input type="checkbox"/>                    | PENTOXSD for Windows Model (see Attachment [redacted])   |
| <input checked="" type="checkbox"/>         | TRC Model Spreadsheet (see Attachment [redacted])  |
| <input type="checkbox"/>                    | Temperature Model Spreadsheet (see Attachment [redacted])  |
| <input type="checkbox"/>                    | Toxics Screening Analysis Spreadsheet (see Attachment [redacted])  |
| <input checked="" type="checkbox"/>         | Water Quality Toxics Management Strategy, 361-0100-003, 4/06.  |
| <input type="checkbox"/>                    | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.   |
| <input type="checkbox"/>                    | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.  |
| <input type="checkbox"/>                    | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.  |
| <input type="checkbox"/>                    | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.   |
| <input type="checkbox"/>                    | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.  |
| <input type="checkbox"/>                    | Pennsylvania CSO Policy, 385-2000-011, 9/08.   |
| <input type="checkbox"/>                    | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.  |
| <input type="checkbox"/>                    | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.   |
| <input checked="" type="checkbox"/>         | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.  |
| <input type="checkbox"/>                    | Implementation Guidance Design Conditions, 391-2000-006, 9/97.   |
| <input type="checkbox"/>                    | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.  |
| <input type="checkbox"/>                    | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.   |
| <input type="checkbox"/>                    | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.   |
| <input type="checkbox"/>                    | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.  |
| <input type="checkbox"/>                    | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.  |
| <input type="checkbox"/>                    | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.   |
| <input checked="" type="checkbox"/>         | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.   |
| <input type="checkbox"/>                    | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.  |
| <input type="checkbox"/>                    | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.   |
| <input type="checkbox"/>                    | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.       |
| <input type="checkbox"/>                    | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.   |
| <input type="checkbox"/>                    | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/>                    | Design Stream Flows, 391-2000-023, 9/98.   |
| <input type="checkbox"/>                    | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.                                     |
| <input type="checkbox"/>                    | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.   |
| <input checked="" type="checkbox"/>         | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.   |
| <input checked="" type="checkbox"/>         | SOP: Establishing effluent limitations for individual sewage permit.   |
| <input type="checkbox"/>                    | Other: [redacted]  |