

Application Type New
Wastewater Type Sewage
Facility Type SFTF

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0267325
APS ID 1024872
Authorization ID 1329930

Applicant, Facility and Project Information

Applicant Name	<u>Sunnyside Trail LLC</u>	Facility Name	<u>Sunnyside Trails</u>
Applicant Address	<u>996 Ridge Road</u> <u>Shippensburg, PA 17257-9782</u>	Facility Address	<u>9 Woods Drive</u> <u>Newville, PA 17241</u>
Applicant Contact	<u>Walter Nolt</u>	Facility Contact	<u>Walter Nolt</u>
Applicant Phone	<u>(717) 423-6300</u>	Facility Phone	<u>(717) 423-6300</u>
Client ID	<u>358905</u>	Site ID	<u>843778</u>
SIC Code	<u>1521</u>	Municipality	<u>Upper Mifflin Township</u>
SIC Description	<u>Construction - Single-Family Housing</u> <u>Construction</u>	County	<u>Cumberland</u>
Date Application Received	<u>October 7, 2020</u>	WQM Required	<u>Yes (Submitted)</u>
Date Application Accepted	<u>January 26, 2021</u>	WQM App. No.	<u>2120402</u>
Project Description	<u>Sunnyside Trails LLC has submitted an application for an SFTF permit for their proposed treatment system for their existing cabin and home.</u>		

Summary of Review

Sunnyside Trails LLC has submitted an application for a new permit for their proposed Small Flow Treatment Facility located in Cumberland County. Sunnyside Trails LLC will utilize a system to treat sewage generated by the facility. DEP received the new NPDES and WQM permit applications on October 7, 2020 by Marshall Engineering. The Department has reviewed the application in order to ensure that the facility does not receive or discharge a flow greater than 800 GPD or exceed the specified limits of CBOD5, pH, Total Suspended Solids, TRC, and Fecal Coliform prescribed in the permit. As per 25 Pa. Code § 92a.53, all applicable effluent limits and standards are considered in development of the permit. The limits noted in the permit suggest that any applicable water quality standards will not be violated.

The limits discussed in the permit are based off of several factors that were determined by the Standard Operating Procedure for Small Flow Treatment Facilities (SOP No. BCW-PMT-003).

The TSS limits were prescribed based on The Department's Water Quality Antidegradation Implementation Guidance ID No. 391-0300-002

The Fecal Coliform limits listed in the permit were required by the Bureau of Clean Water, as stated in Chapter 92.2c.b(2) and 93.7.

Based on the review outlined in this fact sheet, it is recommended that the NPDES permit be drafted. Also, it is recommended that the WQM permit be issued upon issuance of the NPDES permit.

Approve	Deny	Signatures	Date
X		<i>Jared B. Lescavage</i> Jared Lescavage / Environmental Engineering Specialist	January 26, 2021
X		<i>Scott M. Arwood</i> Scott M. Arwood, P.E. / Environmental Engineer Manager	January 27, 2021

Summary of Review

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0008</u>
Latitude	<u>40° 13' 30.93"</u>	Longitude	<u>-77° 30' 54.11"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary of Whisky Run (TSF, MF)</u>	Stream Code	<u>11088</u>
NHD Com ID	<u>56407165</u>	RMI	<u>0.5700</u>
Drainage Area	<u>0.0367</u>	Yield (cfs/mi ²)	<u></u>
Q ₇₋₁₀ Flow (cfs)	<u>0.0564</u>	Q ₇₋₁₀ Basis	<u>StreamStats</u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>7-B</u>	Chapter 93 Class.	<u>TSF, MF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Carlisle Water Treatment Plant</u>		
PWS Waters	<u>Conodoguinet Creek</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>31</u>

Changes Since Last Permit Issuance: N/A

Other Comments: N/A

Compliance History	
Summary of DMRs:	N/A
Summary of Inspections:	N/A

Other Comments: **N/A**

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Average Monthly	Average Monthly	Maximum	Instant. Maximum		
Flow (GPD)	Report	XXX	XXX	XXX	XXX	XXX	1/month	Measured
pH (S.U.)	XXX	XXX	5.0 Inst Min	XXX	XXX	9.0	1/month	Grab
TRC	XXX	XXX	XXX	0.02	XXX	0.02	1/month	Grab
CBOD5	XXX	XXX	10.0	XXX	XXX	20.0	1/month	Grab
TSS	XXX	XXX	10.0	XXX	XXX	20.0	1/month	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200.0 Geo Mean	XXX	XXX	1/month	Grab

Compliance Sampling Location: Outfall 001

Other Comments: N/A