

Application Type New
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0267520
APS ID 1043838
Authorization ID 1362563

Applicant, Facility and Project Information

Applicant Name	<u>Arlin Weaver</u>	Facility Name	<u>Weaver SRSTP</u>
Applicant Address	<u>184 Bulls Head Road</u> <u>Newville, PA 17241-9613</u>	Facility Address	<u>184 Bulls Head Road</u> <u>Newville, PA 17241-9613</u>
Applicant Contact	<u>Arlin Weaver</u>	Facility Contact	<u>Arlin Weaver</u>
Applicant Phone	<u>(717) 448-0551</u>	Facility Phone	<u>(717) 448-0551</u>
Client ID	<u>364364</u>	Site ID	<u>850877</u>
SIC Code	<u>8800</u>	Municipality	<u>North Newton Township</u>
SIC Description	<u>Private Households</u>	County	<u>Cumberland</u>
Date Application Received	<u>July 22, 2021</u>	WQM Required	<u>Yes</u>
Date Application Accepted	<u>July 29, 2021</u>	WQM App. No.	<u>2121404</u>
Project Description	<u>New NPDES Permit.</u>		

Summary of Review

This report supports the issuance of an NPDES permit for discharge of treated sewage from a new single residence sewage treatment plant (SRSTP) expected to be located in North Newton Township, Cumberland County. The WQM permit application is also received and the IRR has been prepared separately for the WQM permit.

Based on the review, it is recommended that the NPDES permit be drafted.

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist	July 29, 2021
X		Maria D. Bebenek for Daniel W. Martin Daniel W. Martin, P.E. / Environmental Engineer Manager	August 4 2021
X		Maria D. Bebenek Maria D. Bebenek P.E. / Program Manager	August 4, 2021

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	0.0005
Latitude	40° 9' 39"	Longitude	-77° 27' 1"
Quad Name		Quad Code	
Wastewater Description: Treated Sewage			
Receiving Waters	Green Spring Creek (CWF, MF)	Stream Code	10430
NHD Com ID	56408239	RMI	1.4
Drainage Area	26	Yield (cfs/mi ²)	
Q ₇₋₁₀ Flow (cfs)	22.6	Q ₇₋₁₀ Basis	
Elevation (ft)		Slope (ft/ft)	
Watershed No.	7-B	Chapter 93 Class.	
Existing Use	None	Existing Use Qualifier	None
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Impaired		
Cause(s) of Impairment	NUTRIENTS		
Source(s) of Impairment	AGRICULTURE		
TMDL Status	FINAL	Name	Conodoguinet Creek Watershed
Nearest Downstream Public Water Supply Intake	Carlisle Borough WTP		
PWS Waters	Conodoguinet Creek	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	23

Drainage Area

The discharge will be to Green Spring Creek at RM 1.4. A drainage area upstream of the proposed discharge point is estimated to be 26 sq.mi. according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

USGS StreamStats produced a Q₇₋₁₀ flow of 22.6 cfs at the point of discharge.

Green Spring Creek

The receiving stream, Green Spring Creek is designated as cold water fishes and supports migratory fishes under 25 Pa Code §93.9o. No special protection water will therefore be impacted by this discharge. This stream is also a trout stocked stream but is not classified a Class Wild Trout Fishery. Based on DEP's 2020 integrated water quality report, Green Spring Creek is impaired for nutrients and sedimentation as a result of agricultural activities and organic enrichment/oxygen depletion as a result of an unknown source. A TMDL was developed for the Conodoguinet Creek watershed which includes Green Spring Creek. This TMDL only addresses impairments caused by agriculture, urban runoff, construction and storm sewers.

Public Water Supply Intake

Based on eMapPA, the nearest downstream public water supply intake is Carlisle Borough WTP located on the Conodoguinet Creek approximately 23 miles from the proposed discharge. Given the distance and nature, the proposed discharge is not expected to impact the water supply.

Compliance History

Summary of DMRs:	This is a new NPDES permit; therefore, no AMR is available for review.
Summary of Inspections:	There is no open violation associated with this facility or permittee.

Treatment Facility Summary

The proposed treatment system will be located in North Newton Township, Franklin County (184 Bulls Head Road Newville). The proposed treatment system will replace a malfunctioning on-lot sewage disposal system for the existing single family residence (500 GPD) and will be Ecoflo EC7 series system with an UV disinfection unit. The details of the proposed system are described in the Internal Review and Recommendation (IRR) report for the WQM permit application. The Official Act 537 Plan Revision was approved on June 23, 2021 (no. A3-21921-153-3S).

Development of Effluent Limitations and Monitoring Requirements

The proposed effluent limitations and monitoring requirements are derived from DEP's Standard Operating Procedure (SOP) for New and Reissuance Small Flow Treatment Facility Individual NPDES Permit Applications (SOP No. BPNPSM-PMT-003).

On February 1, 2017, DEP classified the proposed system as an alternate on-lot sewage treatment system and required this system (if installed) to meet 10 mg/L CBOD5, and 10 mg/L TSS as monthly averages. (Alternate technology no A2017-0029-0001).

Facilities that are designed based on a flow of less than 2,000 GPD or considered as SRSTPs are exempt from the Bay requirements. Accordingly, it is not necessary for the permittee to perform nutrient monitoring.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
CBOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	1000	1/year	Grab

7/29/2021

StreamStats

StreamStats Report

Region ID: PA
 Workspace ID: PA20210729143231479000
 Clicked Point (Latitude, Longitude): 40.16026, -77.45145
 Time: 2021-07-29 10:32:48 -0400



Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	26	square miles
PRECIP	Mean Annual Precipitation	38	inches
STRDEN	Stream Density -- total length of streams divided by drainage area	0.47	miles per square mile
ROCKDEP	Depth to rock	5.4	feet
CARBON	Percentage of area of carbonate rock	93.18	percent

7/29/2021

StreamStats

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	38	inches	35	50.4
STRDEN	Stream Density	0.47	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	5.4	feet	3.32	5.65
CARBON	Percent Carbonate	93.18	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	26.8	ft ³ /s
30 Day 2 Year Low Flow	26.9	ft ³ /s
7 Day 10 Year Low Flow	22.6	ft ³ /s
30 Day 10 Year Low Flow	22.7	ft ³ /s
90 Day 10 Year Low Flow	23.7	ft ³ /s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor