

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0271501
APS ID 1088845
Authorization ID 1440419

Applicant and Facility Information

Applicant Name	<u>Perry Township Mercer County</u>	Facility Name	<u>Hadley STP</u>
Applicant Address	<u>PO Box 69</u> <u>Hadley, PA 16130</u>	Facility Address	<u>Fredonia Road</u> <u>Hadley, PA 16130</u>
Applicant Contact	<u>Bonnie McCartney</u>	Facility Contact	<u>Bonnie McCartney</u>
Applicant Phone	<u>(724) 253-4300</u>	Facility Phone	<u>(724) 253-4300</u>
Client ID	<u>89762</u>	Site ID	<u>829427</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Perry Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Mercer</u>
Date Application Received	<u>May 5, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted		If No, Reason	
Purpose of Application	<u>NPDES Renewal of a municipal minor sewage facility discharge.</u>		

Summary of Review

This is a renewal of an existing discharge for a municipal minor sewage facility.

The WQM permit was amended during the previous permit term to add 5,500LF of low-pressure sanitary sewer

There are currently no open violations for this client (89762) as of 8/28/2024.

WQM modeling was redone from previous permit cycle due to updated modeling calculations for Ammonia-Nitrogen limits.

Annual monitoring for E. Coli has been added per Chapter 92.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	August 28, 2024
X		Vacant / Environmental Engineer Manager	Okay to Draft JCD 9/4/2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.047
Latitude	41° 24' 45.98"	Longitude	-80° 14' 0.70"
Quad Name	Hadley	Quad Code	41080D2
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Little Shenango River (TSF)	Stream Code	36167
NHD Com ID	130028372	RMI	0.9600
Drainage Area	29.5	Yield (cfs/mi ²)	0.053
Q ₇₋₁₀ Flow (cfs)	1.56	Q ₇₋₁₀ Basis	L. Shenango River @ Greenville Gage
Elevation (ft)	1043	Slope (ft/ft)	---
Watershed No.	20-A	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Background/Ambient Data			
pH (SU)	7.41	Data Source	WQN 913 (2000-2015)
Temperature (°F)	25		Default
Hardness (mg/L)			
Other:	0.046		WQN 913 (2000-2015)
Nearest Downstream Public Water Supply Intake			
PWS Waters	Shenango River	Flow at Intake (cfs)	10.6
PWS RMI	8.0	Distance from Outfall (mi)	16.5

Changes Since Last Permit Issuance: A permit amendment was issued in February 2023 for the addition of 5,500LF of 3" low-pressure sanitary sewers.

Other Comments: None.

Treatment Facility Summary				
Treatment Facility Name: Hadley STP				
WQM Permit No.		Issuance Date		
4318410 A-1		February 21, 2023		
4318410		October 24, 2018		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Ultraviolet	0.04625
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.04625		Not Overloaded		

Changes Since Last Permit Issuance: A permit amendment was issued in February 2023 for the addition of 5,500LF of 3" low-pressure sanitary sewers.

Other Comments: None.

Compliance History

DMR Data for Outfall 001 (from July 1, 2023 to June 30, 2024)

Parameter	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23
Flow (MGD) Average Monthly	0.011	0.011	0.018	0.014	0.013	0.013	0.009	0.006	0.003			
Flow (MGD) Daily Maximum	0.022	0.015	0.048	0.031	0.020	0.027	0.016	0.012	0.007			
pH (S.U.) Daily Minimum	7.2	7.0	6.9	7.2	7.3	7.3	7.4	7.3	7.3			
pH (S.U.) Instantaneous Maximum	7.6	7.7	7.6	7.6	7.7	7.8	7.9	8.1	8.8			
DO (mg/L) Daily Minimum	7.1	6.8	8.3	8.6	9.4	9.1	9.3	5.9	4.4			
CBOD5 (lbs/day) Average Monthly	0.4	0.5	< 1.1	0.8	1.0	0.4	0.2	0.7	0.4			
CBOD5 (lbs/day) Weekly Average	0.5	0.7	2.0	0.9	1.3	0.6	0.2	1.0	0.5			
CBOD5 (mg/L) Average Monthly	4.1	5.6	< 3.8	6.5	8.2	4.5	3.1	10.4	17.4			
CBOD5 (mg/L) Weekly Average	5.3	8.8	5.6	8.0	10.9	6.2	3.6	10.9	18.3			
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	30	19	32	24	27	17	13	14	4			
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	35	21	51	27	35	17	13	22	7			
BOD5 (mg/L) Raw Sewage Influent Average Monthly	264	229	144	182	208	176	209	186	129			
TSS (lbs/day) Average Monthly	0.8	0.9	3.6	1.6	1.8	1.0	0.6	1.6	0.6			
TSS (lbs/day) Raw Sewage Influent Average Monthly	7	7	15	8	5	5	3	4	4			

NPDES Permit Fact Sheet
Hadley STP

NPDES Permit No. PA0271501

TSS (lbs/day) Raw Sewage Influent Daily Maximum	10	10	22	11	8	6	3	6	7			
TSS (lbs/day) Weekly Average	1.1	1.0	6.7	1.7	1.8	1.0	0.7	2.3	0.6			
TSS (mg/L) Average Monthly	7.0	10.5	12.5	12.0	14.0	10.5	10.5	22.5	19.0			
TSS (mg/L) Raw Sewage Influent Average Monthly	55	84	76	55	40	52	52	55	130			
TSS (mg/L) Weekly Average	8.0	12.0	19.0	15.0	15.0	11.0	14.0	23.0	20.0			
Fecal Coliform (No./100 ml) Geometric Mean	17	8	< 2	47	486	175	< 2	314	132			
Fecal Coliform (No./100 ml) Instantaneous Maximum	22	15	4	278	1414	201	< 5	1454	866			
UV Intensity (mW/cm ²) Daily Maximum	3.2	3.0	2.8	3.4	0.9	1.1	1.8	3.3	4.3			
Total Nitrogen (lbs/day) Annual Average							3					
Total Nitrogen (mg/L) Annual Average							63.9					
Ammonia (lbs/day) Average Monthly	0.1	0.7	< 0.1	< 0.1	< 0.1	< 0.1	0.1	0.1	1.4			
Ammonia (mg/L) Average Monthly	0.2	8.9	< 0.9	< 0.4	< 0.4	< 0.4	< 0.4	0.6	0.1			
Total Phosphorus (lbs/day) Annual Average							0.2					
Total Phosphorus (mg/L) Annual Average							4.2					

Facility start-up was around October 2023. Therefore, there is no DMR date for the months prior to October 2023.

Development of Effluent Limitations

Outfall No. 001
Latitude 41° 24' 45.79"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .047
Longitude -80° 14' 0.81"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: TRC limits are not needed because this facility uses UV disinfection, not chlorine.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
N/A	N/A	N/A	N/A

Comments: WQM 7.0b was run, and modeling did not justify any water quality-based limits.

Best Professional Judgment (BPJ) Limitations

Comments: A dissolved oxygen limit of a minimum of 4.0 mg/l, an ammonia nitrogen average monthly limit of 25 mg/l, and monitoring for total nitrogen, total phosphorus, UV intensity, influent BOD₅ and influent TSS.

Anti-Backsliding

N/A

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
CBOD5	9.5	15.0	XXX	25.0	40.0	50	2/month	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
TSS	11.0	17.0	XXX	30.0	45.0	60	2/month	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
UV Intensity (mW/cm ²)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/day	Measured
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Ammonia	9.5	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
Total Phosphorus	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
E. Coli (No./100ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: Effluent limits are technology-based limits derived from Chapter 92a and Chapter 95.2, except for Dissolved Oxygen (DO) and Ammonia-Nitrogen (Ammonia), which are Best Professional Judgment standards.

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>											
20A	36167	LITTLE SHENANGO RIVER											
NH3-N Acute Allocations													
NH3-N Chronic Allocations													
Dissolved Oxygen Allocations													
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction						
16.130 Hadley STP		4.68	50	4.68	50	0	0						
16.130 Hadley STP		1.07	25	1.07	25	0	0						
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction				
16.13 Hadley STP		25	25	25	25	4	4	0	0				

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	36167	LITTLE SHENANGO RIVER		
<u>RMI</u> 16.130	<u>Total Discharge Flow (mgd)</u> 0.046	<u>Analysis Temperature (°C)</u> 24.781	<u>Analysis pH</u> 7.414	
<u>Reach Width (ft)</u> 22.727	<u>Reach Depth (ft)</u> 0.587	<u>Reach WDRatio</u> 38.704	<u>Reach Velocity (fps)</u> 0.123	
<u>Reach CBOD5 (mg/L)</u> 3.01	<u>Reach Kc (1/days)</u> 0.152	<u>Reach NH3-N (mg/L)</u> 1.14	<u>Reach Kn (1/days)</u> 1.011	
<u>Reach DO (mg/L)</u> 7.385	<u>Reach Kr (1/days)</u> 2.801	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 2.155	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.215	2.89	0.92	6.95
	0.431	2.77	0.74	6.87
	0.646	2.66	0.59	6.95
	0.862	2.55	0.48	7.10
	1.077	2.45	0.38	7.26
	1.293	2.35	0.31	7.41
	1.508	2.26	0.25	7.54
	1.724	2.17	0.20	7.54
	1.939	2.08	0.16	7.54
	2.155	2.00	0.13	7.54

RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
16.130	Hadley STP	PA0271501	0.046	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36167	LITTLE SHENANGO RIVER			16.130	1043.00	29.50	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)
	(cfs/m)	(cfs)	(cfs)						pH	pH
Q7-10	0.053	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.41
Q1-10		0.00	0.00	0.000	0.000				0.00	0.00
Q30-10		0.00	0.00	0.000	0.000					
Discharge Data										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Hadley STP	PA0271501	0.0463	0.0000	0.0000	0.000	20.00	7.50		
Parameter Data										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		4.00	7.54	0.00	0.00				
	NH3-N		25.00	0.05	0.00	0.70				

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36167	LITTLE SHENANGO RIVER			11.810	994.00	40.00	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfs/m)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (ft)	Tributary pH (°C)	Stream pH (°C)
Q7-10	0.053	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.41
Q1-10		0.00	0.00	0.000	0.000					0.00
Q30-10		0.00	0.00	0.000	0.000					0.00
Discharge Data										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			0.0000	0.0000	0.0000	0.000	25.00	7.00		
Parameter Data										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		3.00	8.24	0.00	0.00				
	NH3-N		25.00	0.00	0.00	0.70				

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
20A		36167		LITTLE SHENANGO RIVER								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
16.130	1.56	0.00	1.56	.0715	0.00215	.587	22.73	38.7	0.12	2.155	24.78	7.41
Q1-10 Flow												
16.130	1.00	0.00	1.00	.0715	0.00215	NA	NA	NA	0.10	2.729	24.67	7.42
Q30-10 Flow												
16.130	2.13	0.00	2.13	.0715	0.00215	NA	NA	NA	0.14	1.826	24.84	7.41

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		