

Application Type Renewal  
 Wastewater Type Sewage  
 Facility Type SRSTP

**NPDES PERMIT FACT SHEET**  
**INDIVIDUAL SFTF/SRSTP**

Application No. PA0271624  
 APS ID 1110282  
 Authorization ID 1478376

**Applicant, Facility and Project Information**

Applicant Name	<u>Thomas Paluh</u>	Facility Name	<u>Thomas Paluh SRSTP</u>
Applicant Address	<u>881 Mercer Road</u>	Facility Address	<u>881 Mercer Road</u>
	<u>Greenville, PA 16125-8416</u>		<u>Greenville, PA 16125</u>
Applicant Contact	<u>Thomas Paluh</u>	Facility Contact	<u>Thomas Paluh</u>
Applicant Phone	<u>-</u>	Facility Phone	<u>-</u>
Client ID	<u>384802</u>	Site ID	<u>830046</u>
SIC Code	<u>8800</u>	Municipality	<u>Delaware Township</u>
SIC Description	<u>Private Households</u>	County	<u>Mercer</u>
Date Application Received	<u>February 16, 2024</u>	WQM Required	<u>Yes</u>
Date Application Accepted	<u>March 27, 2024</u>	WQM App. No.	<u>4318408 will be transferred concurrently</u>
Project Description	<u>Transfer of the NPDES Permit for a Single Residence Sewage Treatment Plant from Ezra Welton to Thomas Paluh.</u>		

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

**I. OTHER REQUIREMENTS:**

A. AMRs	F. Stormwater into sewers
B. DMRs	G. Right of way
C. Depth of Septage and Scum Measurement	H. Solids handling
D. Septic Tank Pumping	I. Public Sewerage Availability
E. Effluent Chlorine Optimization and Minimization	

**SPECIAL CONDITIONS:** II. Ultraviolet (UV) Disinfection.

Proposed treatment will consist of: A 1,000 gallon dual compartment septic tank with an effluent filter, a Premier Tech EC7-500 (WQM Permit no. 4318408) Coco Filter, and a Salcor 3G Ultraviolet (UV) light disinfection unit.

There are no open violations in efacts associated with the subject Client ID (384802) as of 7/11/2024.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	7/11/2024
X		Vacant / Environmental Engineer Manager	Okay to Draft JCD 7/18/2024

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	001	Design Flow (MGD)	0.0004
Latitude	41° 20' 33.51"	Longitude	-80° 20' 14.24"
Quad Name	-	Quad Code	-
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to the Lawango Run (WWF)	Stream Code	N/A
NHD Com ID	130025831	RMI	N/A
Drainage Area	-	Yield (cfs/mi <sup>2</sup> )	-
Q <sub>7-10</sub> Flow (cfs)	-	Q <sub>7-10</sub> Basis	-
Elevation (ft)	-	Slope (ft/ft)	-
Watershed No.	20-A	Chapter 93 Class.	WWF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	-		
Source(s) of Impairment	-		
TMDL Status	-	Name	-
Background/Ambient Data			
pH (SU)	-	Data Source	
Temperature (°F)	-		
Hardness (mg/L)	-		
Other:	-		
Nearest Downstream Public Water Supply Intake			
PWS Waters	-	Flow at Intake (cfs)	-
PWS RMI	-	Distance from Outfall (mi)	-

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD <sub>5</sub>	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after Ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The limits for BOD<sub>5</sub>, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47.