

Application Type New
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0272442
APS ID 997897
Authorization ID 1281236

Applicant, Facility and Project Information

Applicant Name	<u>Anna D Clifton Estate</u>	Facility Name	<u>Anna D Clifton Estate SRSTP</u>
Applicant Address	<u>116 Allegheny Center Mall</u> <u>Pittsburgh, PA 15212-5333</u>	Facility Address	<u>863 Preston Road</u> <u>Warren, PA 16365</u>
Applicant Contact	<u>Brian Morris</u>	Facility Contact	<u></u>
Applicant Phone	<u>(412) 768-3793</u>	Facility Phone	<u></u>
Client ID	<u>351335</u>	Site ID	<u>836296</u>
Municipality	<u>Conewango Township</u>	County	<u>Warren</u>
SIC Code	<u>8800</u>	SIC Code	<u>4952</u>
SIC Description	<u>Private Households</u>	SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>
Application Received	<u>July 5, 2019</u>	WQM Required	<u>Pending concurrently</u>
Application Accepted	<u>August 7, 2019</u>	WQM App. No.	<u>6219410</u>
Project Description	<u>Single Residence Sewage Treatment Plant.</u>		



Summary of Review

No violations have been reported. Proposed is a three-bedroom home malfunctioning on-lot sewage treatment facility replacement for a deceased homeowner. Upon estate settlement transfer request should be submitted for this and WQM permit 6219410.

UV radiation disinfection is proposed. UV maintenance and monitoring is monthly bulb cleaning with annual bulb replacement as stated on the Annual Maintenance Report.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
		William H. Mentzer, P.E. Environmental Engineering Specialist	August 7, 2019
		Justin C. Dickey, P.E. Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0004</u>
Latitude NHD	<u>41° 50' 56.86"</u>	Longitude NHD	<u>-79° 11' 54.70"</u>
Latitude DP	<u>41° 50' 57.20"</u>	Longitude DP	<u>-79° 11' 55.50"</u>
Quad Name	<u>Warren</u>	Quad Code	<u>0412</u>
Wastewater Description:	<u>Treated single residence domestic wastes</u>		
Receiving Waters	<u>Unnamed Tributary to Allegheny R</u>	Stream Code	<u>56305</u>
NHD Com ID	<u>112375247</u>	RMI	<u>1.0500</u>
Drainage Area	<u>0.32</u>	Yield (cfs/mi ²)	<u>0.11</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.0332</u>	Q ₇₋₁₀ Basis	<u>Brokenstraw Creek</u>
Elevation (ft)	<u>1490.11</u>	Slope (ft/ft)	<u>0.04838</u>
Watershed No.	<u>16B</u>	Chapter 93 Class.	<u>Cold Water Fish</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u></u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u>68</u>		<u>default</u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Aqua PA Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1250</u>
PWS RMI	<u>90.57</u>	Distance from Outfall (mi)	<u>97.31</u>

Changes Since Last Permit Issuance: NA

Other Comments: The intake stream flow is the minimum release flow above the intake in Franklin PA.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection