



Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. **PA0272779**  
APS ID **1110095**  
Authorization ID **1478021**

**Applicant and Facility Information**

Applicant Name	<b>Neshannock Creek Watershed Joint Municipal Authority</b>	Facility Name	<b>Neshannock Creek Watershed Joint Municipal Authority WWTP</b>
Applicant Address	369 McClelland Road	Facility Address	845 Perry Highway
	Mercer, PA 16137-6313		Mercer, PA 16137
Applicant Contact	Patrick Suhrie	Facility Contact	
Applicant Phone	(724) 748-4808	Facility Phone	
Client ID	309243	Site ID	779757
Ch 94 Load Status	Not Overloaded	Municipality	East Lackawannock Township
Connection Status	No Limitations	County	Mercer
Date Application Received	<u>February 26, 2024</u>	EPA Waived?	Yes
Date Application Accepted	<u>March 28, 2024</u>	If No, Reason	
Purpose of Application	Renewal of a NPDES Permit for an existing discharge of treated sewage from a POTW.		

**Summary of Review**

This is a publicly owned sewage treatment plant servicing portions of East Lackawannock Township and Findley Township, Mercer County. The facility does not currently accept hauled-in waste or have any industrial users.

No changes to discharge quantity or quality were proposed as part of this permit renewal.

There are currently no open violations listed in EFACTS for this permittee (2/27/2025).

Sludge use and disposal description and location(s): Sludge is hauled offsite and disposed of at Seneca Landfill in Evans City, PA.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Adam J. Pesek Adam J. Pesek, E.I.T. / Project Manager	February 27, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	March 6, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.15
Latitude	41° 11' 46"	Longitude	-80° 13' 23"
Quad Name	Mercer	Quad Code	04034
Wastewater Description:	Sewage Effluent		
Receiving Waters	Neshannock Creek	Stream Code	35515
NHD Com ID	130031795	RMI	22.93
Drainage Area	108.1	Yield (cfs/mi <sup>2</sup> )	0.0558
Q <sub>7-10</sub> Flow (cfs)	6.05	Q <sub>7-10</sub> Basis	Avg of Cool Spring Crk near Mercer and Neshannock Crk @ East Brook
Elevation (ft)	1073	Slope (ft/ft)	0.00162
Watershed No.	20-A	Chapter 93 Class.	TSF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Background/Ambient Data		Data Source	
pH (SU)	7.86	Median of Dept.-taken samples upstream between 7/11 and 8/1 of 2017	
Temperature (°C)	25	Default (TSF)	
Hardness (mg/L)			
Other: NH <sub>3</sub> -N	0.25	Used in Mercer STP modeling	
Nearest Downstream Public Water Supply Intake		PA American Water Company – Ellwood District	
PWS Waters	Beaver River	Flow at Intake (cfs)	450
PWS RMI	12.5	Distance from Outfall (mi)	34.5

Changes Since Last Permit Issuance: None

Other Comments:

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Neshannock Creek Watershed Joint Municipal Authority WWTP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
4314402	12/30/2014			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Ultraviolet	0.15
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.15	400	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: A WQM Permit Amendment was issued on 1/2/2024 for the Thompson Road Pump Station for a sewage grinder and screw conveyor.

Other Comments:

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	No effluent violations reported in the last 5 years.
<b>Summary of Inspections:</b>	A Compliance Evaluation Inspection was last conducted on 8/11/2023. No violations were noted. Non-compliance was noted however for constructing a mechanical screening system at the Thompson Road Pump Station without prior Department approval (amendment of the WQM Permit).

Other Comments: A WQM Permit Amendment was issued on 1/2/2024 for the Thompson Road Pump Station for a sewage grinder and screw conveyor.

## Compliance History

## DMR Data for Outfall 001 (from January 1, 2024 to December 31, 2024)

Parameter	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24
Flow (MGD) Average Monthly	0.084	0.082	0.068	0.074	0.079	0.067	0.064	0.094	0.110	0.102	0.086	0.104
Flow (MGD) Weekly Average	0.104	0.092	0.090	0.150	0.090	0.076	0.073	0.125	0.151	0.112	0.095	0.119
pH (S.U.) Daily Minimum	7.0	6.7	6.8	6.5	6.5	6.3	6.1	6.2	6.2	6.7	6.2	6.4
pH (S.U.) Daily Maximum	7.6	7.2	8.0	6.9	7.4	7.0	6.9	7.3	7.1	7.2	7.2	7.3
DO (mg/L) Daily Minimum	4.9	4.2	4.1	4.4	4.1	4.0	4.1	4.0	4.4	6.1	4.6	5.3
CBOD5 (lbs/day) Average Monthly	< 2.7	< 2.0	< 1.5	3.3	4.2	3.6	2.3	5.0	5.6	4.5	< 3.1	5.8
CBOD5 (lbs/day) Weekly Average	6	2	2	5	9	5	4.9	9	13	5	6	9.7
CBOD5 (mg/L) Average Monthly	< 4.0	< 3.1	< 2.6	4.4	4.8	6.3	4.6	5.9	5.0	6.5	< 4.4	6.2
CBOD5 (mg/L) Weekly Average	7.3	3.8	3.4	5.6	5.7	9.1	8.9	13.9	6.8	7.0	7.9	7.0
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	90	118	153	169	174	125	122	207	161	170	161	203
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	148	139	283	244	347	143	150	493	256	322	184	329
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	154	186	244	231	211	236	257	198	181	180	243	218
TSS (lbs/day) Average Monthly	12.9	6.6	< 3.4	10.7	10.2	< 5.5	< 3.1	< 9.1	< 11.0	< 4.7	< 5.8	12.6
TSS (lbs/day) Raw Sewage Influent   Average Monthly	57	39	81	56	54	29	39	67	51	48	116	124

## NPDES Permit Fact Sheet

## Neshannock Creek Watershed Joint Municipal Authority WWTP

## NPDES Permit No. PA0272779

TSS (lbs/day) Raw Sewage Influent   Daily Maximum	115	47	243	82	129	39	72	160	94	92	160	176
TSS (lbs/day) Weekly Average	27.6	12.4	5.7	22.5	18.2	9.2	4.1	16.9	31.2	8.2	8.8	15.9
TSS (mg/L) Average Monthly	16.5	8.3	< 5.5	13.0	13.3	< 10.0	< 6.5	< 10.3	< 8.8	< 5.3	< 8.5	14.3
TSS (mg/L) Raw Sewage Influent   Average Monthly	81	62	114	85	59	54	80	64	54	50	171	138
TSS (mg/L) Weekly Average	23.0	16.0	7.0	18.0	16.0	19.0	9.0	16.0	16.0	6.0	12.0	18.0
Fecal Coliform (No./100 ml) Geometric Mean	124	105	55	55	184	< 21	22	67	230	223	28	364
Fecal Coliform (No./100 ml) Instantaneous Maximum	387	2420	280	206	816	158	162	220	3244	548	47	7766
UV Intensity (μw/cm <sup>2</sup> ) Daily Minimum	0.9	1.1	0.8	1	1.0	1.3	0.5	1.7	1.2	1.3	1.1	0.6
UV Intensity (μw/cm <sup>2</sup> ) Average Monthly	1	1.3	1.6	2	1.8	2.2	2.1	2.1	1.7	1.4	1.2	1.0
Total Nitrogen (lbs/day) Average Quarterly	26			23			81			16		
Total Nitrogen (mg/L) Average Quarterly	32			46.9			41.6			19.4		
Ammonia (lbs/day) Average Monthly	< 0.1	< 0.1	< 0.6	< 0.2	< 0.3	< 0.2	0.1	< 0.3	< 0.4	< 0.4	< 0.5	< 0.4
Ammonia (mg/L) Average Monthly	< 0.3	< 0.1	< 1.4	< 0.2	< 0.5	< 0.4	0.2	< 0.2	< 0.3	< 0.4	< 0.7	< 0.4
Total Phosphorus (lbs/day) Average Quarterly	4			0.6			8			2		
Total Phosphorus (mg/L) Average Quarterly	4.66			1.2			4.2			2.9		

**Development of Effluent Limitations**

Outfall No.	001	Design Flow (MGD)	0.15
Latitude	41° 11' 46.00"	Longitude	-80° 13' 23.00"
<b>Wastewater Description:</b> Treated domestic sewage			

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	

Comments: TRC limits are not applicable because chlorine disinfection is not used in treatment.

Monitoring for E. Coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia Nitrogen (5/1 – 10/31)	11.5	Average Monthly	WQM 7.0 Ver. 1.1

Comments: Monitoring is placed in the permit during winter months for ammonia nitrogen because the calculated limit (3 times the summer limit) is well above the BPJ tech-based limit of 25 mg/l, which is considered easily achievable.

The Toxics Management Spreadsheet (TMS) recommended monitoring for total copper because the highest reported concentration on the application was greater than 1/10<sup>th</sup> of the calculated WQBEL. Because the reported concentrations fall just above or below a tenth of that WQBEL, Monitoring for total copper at a reduced monitoring frequency is being proposed in the draft NPDES permit of 1/Quarter.

**Best Professional Judgment (BPJ) Limitations**

Comments: A dissolved oxygen limit of a minimum of 4.0 mg/l and monitoring for UV intensity, total nitrogen, and total phosphorus is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Influent monitoring for  $BOD_5$  and total suspended solids was placed in the permit in accordance with the Department's SOP entitled "New and Reissuance Sewage Individual NPDES Permits."

**Anti-Backsliding**

N/A

### Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0	XXX	XXX	XXX	1/day	Grab
CBOD5	31.3	50	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	37.5	56.3	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Intensity ( $\mu$ w/cm <sup>2</sup> )	XXX	XXX	Report	Report	XXX	XXX	1/day	Grab
Total Nitrogen	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Ammonia Nov 1 - Apr 30	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite

## Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia May 1 - Oct 31	14.3	XXX	XXX	11.5	XXX	23	1/week	24-Hr Composite
Total Phosphorus	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Copper (ug/l)	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location: Outfall 001 (after disinfection)

Other Comments:

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35515	NESHANNOCK CREEK	25.750	1085.00	99.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)	pH
Q7-10	0.056	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.86	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Mercer Muni STP	pa0025356	1.5680	0.0000	0.0000	0.000	20.00	7.20
<b>Parameter Data</b>							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	7.54	0.00	0.00		
NH3-N		25.00	0.10	0.00	0.70		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35515	NESHANNOCK CREEK	23.500	1075.00	107.50	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)	pH
Q7-10	0.056	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.86	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Mercer Corr FAC	PA0102326	0.2800	0.0000	0.0000	0.000	20.00	7.00
<b>Parameter Data</b>							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	7.54	0.00	0.00		
NH3-N		25.00	0.10	0.00	0.70		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35515	NESHANNOCK CREEK	22.930	1073.00	108.10	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)	pH
Q7-10	0.056	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.86	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
NCWJMA WWTP	PA0272779	0.1500	0.0000	0.0000	0.000	20.00	6.50
<b>Parameter Data</b>							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	7.54	0.00	0.00		
NH3-N		25.00	0.10	0.00	0.70		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35515	NESHANNOCK CREEK	20.360	1051.00	122.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream Temp	Stream pH
	(cfs/m)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)	pH
Q7-10	0.056	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.86	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH	
		0.0000	0.0000	0.0000				
<b>Parameter Data</b>								
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5		25.00	2.00	0.00	1.50			
Dissolved Oxygen		3.00	8.24	0.00	0.00			
NH3-N		25.00	0.00	0.00	0.70			

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin			Stream Code		Stream Name							
20A			35515		NESHANNOCK CREEK							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
25.750	5.54	0.00	5.54	2.4257	0.00084	.778	48.56	62.39	0.21	0.652	23.48	7.54
23.500	6.02	0.00	6.02	2.8589	0.00066	.798	51.6	64.69	0.22	0.161	23.39	7.50
22.930	6.05	0.00	6.05	3.0909	0.00162	.778	49.87	64.13	0.24	0.666	23.31	7.41
<b>Q1-10 Flow</b>												
25.750	3.55	0.00	3.55	2.4257	0.00084	NA	NA	NA	0.18	0.766	22.97	7.47
23.500	3.85	0.00	3.85	2.8589	0.00066	NA	NA	NA	0.18	0.189	22.87	7.43
22.930	3.87	0.00	3.87	3.0909	0.00162	NA	NA	NA	0.20	0.776	22.78	7.33
<b>Q30-10 Flow</b>												
25.750	7.54	0.00	7.54	2.4257	0.00084	NA	NA	NA	0.24	0.575	23.78	7.59
23.500	8.19	0.00	8.19	2.8589	0.00066	NA	NA	NA	0.24	0.143	23.71	7.55
22.930	8.23	0.00	8.23	3.0909	0.00162	NA	NA	NA	0.27	0.591	23.64	7.47

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Uniform Treatment	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20A	35515	NESHANNOCK CREEK					

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
25.750	Mercer Muni STP	NA	50	7.54	18.42	1	63
23.500	Mercer Corr FAC	NA	50	8.07	50	0	0
22.930	NCWJMA WWTP	NA	50	9.26	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
25.750	Mercer Muni STP	NA	25	1.01	3.82	1	85
23.500	Mercer Corr FAC	NA	25	1.05	11.85	3	53
22.930	NCWJMA WWTP	NA	25	1.13	11.85	3	53

**Dissolved Oxygen Allocations**

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
25.75	Mercer Muni STP	25	8.43	3.82	2.53	4	4	2	56
23.50	Mercer Corr FAC	25	14.05	11.85	4.22	4	4	2	56
22.93	NCWJMA WWTP	25	25	11.85	11.85	4	4	0	0

**WQM 7.0 D.O.Simulation**

SWP Basin	Stream Code	Stream Name		
20A	35515	NESHANNOCK CREEK		
<u>RMI</u> 25.750	<u>Total Discharge Flow (mgd)</u> 1.568	<u>Analysis Temperature (°C)</u> 23.478	<u>Analysis pH</u> 7.541	
<u>Reach Width (ft)</u> 48.564	<u>Reach Depth (ft)</u> 0.778	<u>Reach WDRatio</u> 62.393	<u>Reach Velocity (fps)</u> 0.211	
<u>Reach CBOD5 (mg/L)</u> 3.96	<u>Reach Kc (1/days)</u> 0.305	<u>Reach NH3-N (mg/L)</u> 0.84	<u>Reach Kn (1/days)</u> 0.915	
<u>Reach DO (mg/L)</u> 6.463	<u>Reach Kr (1/days)</u> 1.831	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.652	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.065	3.87	0.79	6.37
	0.130	3.78	0.74	6.29
	0.196	3.69	0.70	6.24
	0.261	3.60	0.66	6.21
	0.326	3.52	0.62	6.20
	0.391	3.44	0.59	6.20
	0.457	3.36	0.55	6.21
	0.522	3.28	0.52	6.23
	0.587	3.21	0.49	6.26
	0.652	3.13	0.46	6.30
<u>RMI</u> 23.500	<u>Total Discharge Flow (mgd)</u> 1.848	<u>Analysis Temperature (°C)</u> 23.390	<u>Analysis pH</u> 7.502	
<u>Reach Width (ft)</u> 51.604	<u>Reach Depth (ft)</u> 0.798	<u>Reach WDRatio</u> 64.693	<u>Reach Velocity (fps)</u> 0.216	
<u>Reach CBOD5 (mg/L)</u> 3.61	<u>Reach Kc (1/days)</u> 0.370	<u>Reach NH3-N (mg/L)</u> 0.63	<u>Reach Kn (1/days)</u> 0.909	
<u>Reach DO (mg/L)</u> 6.254	<u>Reach Kr (1/days)</u> 1.476	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.161	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.016	3.58	0.62	6.23
	0.032	3.56	0.61	6.21
	0.048	3.53	0.60	6.19
	0.065	3.51	0.59	6.17
	0.081	3.48	0.58	6.15
	0.097	3.46	0.57	6.14
	0.113	3.43	0.56	6.12
	0.129	3.41	0.56	6.11
	0.145	3.39	0.55	6.10
	0.161	3.36	0.54	6.08

### WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	35515	NESHANNOCK CREEK		
<u>RMI</u> 22.930	<u>Total Discharge Flow (mgd)</u> 1.998	<u>Analysis Temperature (°C)</u> 23.310	<u>Analysis pH</u> 7.413	
<u>Reach Width (ft)</u> 49.865	<u>Reach Depth (ft)</u> 0.778	<u>Reach WDRatio</u> 64.130	<u>Reach Velocity (fps)</u> 0.236	
<u>Reach CBOD5 (mg/L)</u> 3.91	<u>Reach Kc (1/days)</u> 0.453	<u>Reach NH3-N (mg/L)</u> 0.83	<u>Reach Kn (1/days)</u> 0.903	
<u>Reach DO (mg/L)</u> 6.037	<u>Reach Kr (1/days)</u> 3.930	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.666	<b>Subreach Results</b>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.067	3.77	0.78	6.26
	0.133	3.64	0.73	6.45
	0.200	3.52	0.69	6.62
	0.266	3.39	0.65	6.76
	0.333	3.28	0.61	6.88
	0.400	3.16	0.58	6.99
	0.466	3.06	0.54	7.09
	0.533	2.95	0.51	7.18
	0.599	2.85	0.48	7.26
	0.666	2.75	0.45	7.33

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>					
20A	35515	NESHANNOCK CREEK						
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)	
25.750	Mercer Muni STP	pa0025356	1.568	CBOD5	8.43			
				NH3-N	2.53	5.06		
				Dissolved Oxygen			4	
23.500	Mercer Corr FAC	PA0102326	0.280	CBOD5	14.05			
				NH3-N	4.22	8.44		
				Dissolved Oxygen			4	
22.930	NCWJMA WWTP	PA0272779	0.150	CBOD5	25			
				NH3-N	11.85	23.7		
				Dissolved Oxygen			4	

## Discharge Information

Instructions **Discharge** Stream

Facility: NCWJMA WWTP NPDES Permit No.: PA0272779 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Domestic Sewage

Discharge Characteristics											
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)				
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>			
0.15	100	6.5									
			0 if left blank				0.5 if left blank				
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	621								
	Chloride (PWS)	mg/L	173								
	Bromide	mg/L	0.29								
	Sulfate (PWS)	mg/L	34.5								
	Fluoride (PWS)	mg/L									
Group 2	Total Aluminum	µg/L									
	Total Antimony	µg/L									
	Total Arsenic	µg/L									
	Total Barium	µg/L									
	Total Beryllium	µg/L									
	Total Boron	µg/L									
	Total Cadmium	µg/L									
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L									
	Total Cobalt	µg/L									
	Total Copper	µg/L	11.7								
	Free Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L									
	Total Iron	µg/L									
	Total Lead	µg/L	0.42								
	Total Manganese	µg/L									
	Total Mercury	µg/L									
	Total Nickel	µg/L									
	Total Phenols (Phenolics) (PWS)	µg/L									
	Total Selenium	µg/L									
	Total Silver	µg/L									
	Total Thallium	µg/L									
	Total Zinc	µg/L	69.3								
	Total Molybdenum	µg/L									
	Acrolein	µg/L	<								
	Acrylamide	µg/L	<								
	Acrylonitrile	µg/L	<								
	Benzene	µg/L	<								
	Bromoform	µg/L	<								







## Stream / Surface Water Information

NCWJMA WWTP, NPDES Permit No. PA0272779, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Neshannock Creek**

No. Reaches to Model: **1**

Statewide Criteria  
 Great Lakes Criteria  
 ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	035515	34.5	1073	108.1			Yes
End of Reach 1	035515	0.001	734	2250		1	Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	34.5	0.056										100	7.86		
End of Reach 1	0.001	0.1	450									100	7		

**Q<sub>h</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	34.5														
End of Reach 1	0.001														



## Model Results

NCWJMA WWTP, NPDES Permit No. PA0272779, Outfall 001

Instructions  Results     All  Inputs  Results  Limits

**Hydrodynamics**

**Q<sub>7-10</sub>**

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
34.5	6.05		6.05	0.232	0.002	0.746	43.589	58.455	0.193	10.902	86.954
0.001	450.00	1.547	448.453								

**Q<sub>h</sub>**

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
34.5	35.85		35.85	0.232	0.002	1.609	43.589	27.095	0.515	4.097	29.206
0.001	1548.448	1.547	1546.90								

**Wasteload Allocations**

**AFC**

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	13.439	14.0	166	Chem Translator of 0.96 applied
Total Lead	0	0		0	64.581	81.6	966	Chem Translator of 0.791 applied
Total Zinc	0	0		0	117.180	120	1,418	Chem Translator of 0.978 applied

**CFC**

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	

Sulfate (PWS)	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	8.956	9.33	253	Chem Translator of 0.96 applied
Total Lead	0	0	0	2.517	3.18	86.2	Chem Translator of 0.791 applied
Total Zinc	0	0	0	118.139	120	3,246	Chem Translator of 0.986 applied

**THH** CCT (min): **86.954** THH PMF: **1** Analysis Hardness (mg/l): **N/A** Analysis pH: **N/A** PWS PMF: **1**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	500,000	500,000	#####	WQC applied at RMI 0.001 with a design stream flow of 450 cfs
Chloride (PWS)	0	0	0	0	250,000	250,000	#####	WQC applied at RMI 0.001 with a design stream flow of 450 cfs
Sulfate (PWS)	0	0	0	0	250,000	250,000	#####	WQC applied at RMI 0.001 with a design stream flow of 450 cfs
Total Copper	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	

**CRL** CCT (min): **29.206** PMF: **1** Analysis Hardness (mg/l): **N/A** Analysis pH: **N/A**

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Copper	0	0	0	0	N/A	N/A	N/A	
Total Lead	0	0	0	0	N/A	N/A	N/A	
Total Zinc	0	0	0	0	N/A	N/A	N/A	

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: **4**

Pollutants	Mass Limits		Concentration Limits					Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units				
Total Copper	Report	Report	Report	Report	Report	µg/L	106	AFC	Discharge Conc > 10% WQBEL (no RP)	

**Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	970,119	mg/L	Discharge Conc ≤ 10% WQBEL
Chloride (PWS)	485,059	mg/L	Discharge Conc ≤ 10% WQBEL
Bromide	N/A	N/A	No WQS

**NPDES Permit Fact Sheet**  
**Neshannock Creek Watershed Joint Municipal Authority WWTP**

**NPDES Permit No. PA0272779**

Sulfate (PWS)	485,059	mg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	86.2	µg/L	Discharge Conc ≤ 10% WQBEL
Total Zinc	909	µg/L	Discharge Conc ≤ 10% WQBEL

Model Results

2/27/2025

Page 7

**Neshannock Creek Watershed Joint Municipal Authority WWTP**

East Lackawannock Township, Mercer County

PA0272779

Discharge pH

**Outfall 001**

<u>Date</u>	<u>pH min</u>	<u>pH max</u>	<u><math>10^{-\text{pH min}}</math></u>	<u><math>10^{-\text{pH max}}</math></u>	<u><math>\text{&amp; pH max}</math></u>	<u><math>\text{-Log (Ave pH)}</math></u>
Jul-22	6.1	7.0	7.94E-07	1E-07	4.47E-07	<b>6.3</b>
Aug-22	6.6	7.0	2.51E-07	1E-07	1.76E-07	<b>6.8</b>
Sep-22	6.5	7.1	3.16E-07	7.94E-08	1.98E-07	<b>6.7</b>
Jul-23	6.4	6.8	3.98E-07	1.58E-07	2.78E-07	<b>6.6</b>
Aug-23	6.3	6.9	5.01E-07	1.26E-07	3.14E-07	<b>6.5</b>
Sep-23	6.1	6.8	7.94E-07	1.58E-07	4.76E-07	<b>6.3</b>
Jul-24	6.3	7.0	5.01E-07	1E-07	3.01E-07	<b>6.5</b>
Aug-24	6.5	7.4	3.16E-07	3.98E-08	1.78E-07	<b>6.7</b>
Sep-24	6.5	6.9	3.16E-07	1.26E-07	2.21E-07	<b>6.7</b>
						Median: <b>6.5</b>