

Application Type Renewal  
Facility Type Non-Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0272795  
APS ID 1002065  
Authorization ID 1289003

**Applicant and Facility Information**

Applicant Name	<u>Matthew R. Hinkle</u>	Facility Name	<u>Majors MHP</u>
Applicant Address	<u>5137 Clayton Circle</u> <u>New Castle, PA 16101</u>	Facility Address	<u>5137 Clayton Circle</u> <u>New Castle, PA 16101</u>
Applicant Contact	<u>Matthew R. Hinkle</u>	Facility Contact	<u>Matthew R. Hinkle</u>
Applicant Phone	<u>(724) 944-8075</u>	Facility Phone	<u>(724) 944-8075</u>
Client ID	<u>298847</u>	Site ID	<u>448796</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Slippery Rock Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Lawrence County</u>
Date Application Received	<u>August 30, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 20, 2019</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater.</u>		

**Summary of Review**

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

**I. OTHER REQUIREMENTS:**

- A. Stormwater into sewers
- B. Right of way
- C. Solids handling
- D. Public Sewerage Availability
- E. Effluent Chlorine Optimization and Minimization
- F. Dry Streams

**SPECIAL CONDITIONS:**

- II. Solids Management
- III. Requirements for Total Residual Chlorine (TRC)

There are no open violations in efacts associated with the subject Client ID (298847) as of 10/15/2021.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	10/15/2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	10/18/2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.00735</u>
Latitude	<u>40° 58' 39.60"</u>	Longitude	<u>80° 12' 52.70"</u>
Quad Name	<u>Portersville</u>	Quad Code	<u>1104</u>
Wastewater Description: <u>treated sanitary wastewater</u>			
Receiving Waters	<u>Unnamed Tributary to the Brush Run (CWF)</u>	Stream Code	<u>N/A (34172)</u>
NHD Com ID	<u>126216622</u>	RMI	<u>N/A</u>
Drainage Area	<u>0.06</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.03</u>
Q7-10 Flow (cfs)	<u>0.0018</u>	Q7-10 Basis	<u>calculated</u>
Elevation (ft)	<u>1200</u>	Slope (ft/ft)	<u>0.01683</u>
Watershed No.	<u>20-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>		<u>-</u>
Temperature (°F)	<u>-</u>		<u>-</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake	<u>Pennsylvania American Water Company - Ellwood City</u>		
PWS Waters	<u>Connoquenessing Creek</u>	Flow at Intake (cfs)	<u>27.6</u>
PWS RMI	<u>0.20</u>	Distance from Outfall (mi)	<u>21.5</u>

Sludge use and disposal description and location(s): Sludge is disposed of at an approved landfill.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Narrative: This Fact Sheet details the determination of draft NPDES permit limits for an existing discharge of 0.00735 MGD of treated sewage from an existing MHP in Slippery Rock Township, Lawrence County.

Treatment permitted under WQM permit 3776402 consists of: A 1,000 gallon septic tank followed by an effluent pump tank, two 1,000 gallon septic tanks in series, a 6,000 gallon septic tank followed by an effluent pump tank discharging to a 13,500 gallon septic tank, a 500 gallon tank with a Zabel effluent filter, a 3,000 gallon dual siphon dosing tank, an intermittent 4,352 square foot (64' x 68') surface sand filter, a second 3,000 gallon dual siphon dosing tank, a second intermittent 4,352 square foot (64' x 68') surface sand filter (sand filters operating in series), and dual tablet chlorinators with a 2,853 gallon chlorine contact tank.

**1. Streamflow:**

Muddy Creek near Portersville, PA - USGS Gage 03106300 (1971-1993):

Q<sub>7-10</sub>: 1.75 cfs from StreamStats  
Drainage Area: 51.2 sq. mi. from StreamStats  
Yieldrate: 0.03 cfs/m calculated

Unnamed Tributary to the Brush Run at Outfall 001:

Yieldrate: 0.03 cfs/m calculated above  
Drainage Area: 0.06 sq. mi. from StreamStats  
% of stream allocated: 100% Basis: no nearby discharges  
Q<sub>7-10</sub>: 0.0018 cfs calculated

**2. Wasteflow: Outfall 001:**

Maximum discharge: 0.00735 MGD = 0.0113 cfs

Runoff flow period: 24 hours Basis: Runoff flow for septic tank/sand filter systems

The calculated stream flow (Q<sub>7-10</sub>) is less than 3 times the permitted discharge flow. In accordance with the SOP, since this is an existing discharge, the treatment requirements in document number 391-2000-014, titled, "Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers", dated April 12, 2008, were evaluated for this facility. Based on eDMR data, the treatment requirements are not attainable with the treatment technology in place so the requirements will not be implemented in this NPDES Permit renewal.

Flow will be required to be monitored as authorized under Chapter 92a.61, and as recommended in the SOP.

**3. Parameters:**

The following parameters were evaluated: pH, Total Suspended Solids, Fecal Coliform, E. Coli, Phosphorus, NH<sub>3</sub>-N, CBOD<sub>5</sub>, Dissolved Oxygen, and Total Residual Chlorine.

a. pH

Between 6.0 and 9.0 at all times

Basis: Application of Chapter 93.7 technology-based limits.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

b. Total Suspended Solids

Limits are 30 mg/l as a monthly average and 60 as a daily maximum.

Basis: Application of Chapter 92a47 technology-based limits.

c. Fecal Coliform

05/01 - 09/30: 200/100ml (monthly average geometric mean)  
1,000/100ml (instantaneous maximum)

10/01 - 04/30: 2,000/100ml (monthly average geometric mean)  
10,000/100ml (instantaneous maximum)

Basis: Application of Chapter 92a47 technology-based limits

d. E. Coli

Monitoring was added for E. Coli at a frequency of 1/year.

Basis: Application of Chapter 92a.61 as recommended by the SOP for flows between 0.002 MGD and 0.05 MGD.

e. Total Phosphorus

- Limit necessary due to:
- Discharge to lake, pond, or impoundment
  - Discharge to stream

Basis: N/A

- Limit not necessary

Basis: Chapter 96.5 does not apply. However, the previous monitoring for Total Phosphorus will be retained in accordance with the SOP, based on Chapter 92a.61.

f. Total Nitrogen

Monitoring for Total Nitrogen will be retained with this renewal in accordance with the SOP, based on Chapter 92a.61.

g. Ammonia-Nitrogen (NH<sub>3</sub>-N)

Median discharge pH to be used: 7.2 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background NH<sub>3</sub>-N concentration: 0.1 mg/l

Basis: Default value.

Calculated NH<sub>3</sub>-N Summer limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Calculated NH<sub>3</sub>-N Winter limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the calculated summer limits above (see Attachment 1), which are less stringent than the previous NPDES Permit. The winter limits are calculated as 3 times the summer limits per the SOP. Since the previous more restrictive limits are being attained, they will be retained with this renewal.

h. CBOD<sub>5</sub>

Median discharge pH to be used: 7.2 Standard Units (S.U.)

Basis: Average pH value from DMR summary

Discharge temperature: 25°C (default value used in the absence of data)

Median stream pH to be used: 7.0 Standard Units (S.U.)

Basis: default value used in the absence of data

Stream Temperature: 20°C (default value used for CWF modeling)

Background CBOD<sub>5</sub> concentration: 2.0 mg/l

Basis: Default value

CBOD<sub>5</sub> Summer limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

CBOD<sub>5</sub> Winter limits: 25.0 mg/l (monthly average)  
50.0 mg/l (instantaneous maximum)

Result: WQ modeling resulted in the above summer limits (see Attachment 1), which are the same as the previous permit. Since the summer limits are technology-based, the winter limits will also be technology-based. Since the summer and winter limits are technology-based, per the SOP, the previous year-round sampling for CBOD<sub>5</sub> will be retained.

i. Dissolved Oxygen (DO)

- 4.0 mg/l - minimum desired in effluent to protect all aquatic life.
- 5.0 mg/l - required in effluent for CWF, WWF, or TSF based on WQ Model.
- 6.0 mg/l - minimum required due to discharge going to a drainage swale or ditch.
- 8.0 mg/l - required due to discharge going to a naturally reproducing salmonid stream

Discussion: A Dissolved Oxygen technology-based minimum of 3.0 mg/l was calculated by the WQ Model (see Attachment 1). Based on the SOP, Chapter 93.7, and under the authority of Chapter 92a.61, the minimum of 4.0 mg/l will be retained from the previous permit.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

j. Total Residual Chlorine (TRC)

- No limit necessary

- TRC limits: 0.26 mg/l (monthly average)  
0.86 mg/l (instantaneous maximum)

Basis: The TRC limits above were calculated using the Department's TRC Calculation Spreadsheet (see Attachment 2) at the point of first use. The limits are more restrictive than in the previous NPDES Permit due largely to changes to the chlorine demand defaults in the spreadsheet. The new limits will be added with a compliance schedule to provide time for the permittee to meet them.

The measurement frequency was previously set to 1/day as recommended in the SOP, based on Table 6-3 in the "Technical Guidance for the Development and Specification of Effluent Limitations" (362-0400-001), which will be retained.

k. Anti-Backsliding

Since all the permit limits in this renewal are the same or more restrictive than the previous NPDES Permit, anti-backsliding is not applicable.

**4. Reasonable Potential Analysis:**

A Reasonable Potential Analysis was not performed in accordance with State practices using the Department's Toxics Management Spreadsheet since no sampling other than sewage-related parameters was performed for this facility with the renewal application.

**5. Reasonable Potential for Downstream Public Water Supply (PWS):**

Limits for parameters that are based on PWS criteria (TDS, Chloride, Bromide, and Sulfate) are not calculated by the Toxics Management Spreadsheet. However, since no data was provided, mass-balance calculations were not able to be performed.

Nearest Downstream potable water supply (PWS): Pennsylvania American Water Company - Ellwood City  
Distance downstream from the point of discharge: 21.5 miles (approximate)

- No limits necessary  
 Limits needed

Basis: Significant dilution available.

**6. Attachment List:**

- Attachment 1 - WQ Modeling Printouts
- Attachment 2 - TRC\_Calc Spreadsheet

Compliance History

DMR Data for Outfall 001 (from September 1, 2020 to August 31, 2021)

Parameter	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20
Flow (MGD) Average Monthly	0.0029	0.0029	0.0031	0.0032	0.0029	0.0030	0.0034	0.0030	0.0027	0.0024	0.0022	0.0028
Flow (MGD) Daily Maximum	0.0032	0.003	0.0036	0.0035	0.0032	0.0042	0.0041	0.0041	0.0031	0.0031	0.0028	0.0035
pH (S.U.) Minimum	7.2	7.2	7.2	7.3	7.0	7.0	7.0	7.1	7.1	7.2	7.1	7.2
pH (S.U.) Maximum	7.4	7.4	7.4	7.4	7.3	7.2	7.2	7.3	7.3	7.4	7.3	7.4
DO (mg/L) Minimum	7.7	7.6	7.8	8.8	10.0	11.0	13.0	12.3	12.3	10.9	9.3	8.6
TRC (mg/L) Average Monthly	0.37	0.38	0.34	0.3	0.31	0.28	0.35	0.29	0.286	0.388	0.34	0.37
TRC (mg/L) Instantaneous Maximum	0.45	0.48	0.49	0.48	0.41	0.35	0.40	0.31	0.47	0.48	0.49	0.49
CBOD5 (mg/L) Average Monthly	< 2	< 5.27	< 6.96	< 2	< 2.89	< 4	< 8.33	< 3	< 3.0	< 7.5	< 3.67	< 3
CBOD5 (mg/L) Instantaneous Maximum	< 2	< 6	7.91	< 2	3.77	< 6	< 12	< 3	< 3.0	< 12	4.33	< 3
TSS (mg/L) Average Monthly	< 5	< 5	< 5.0	< 5	< 5.0	< 5	< 5	< 5	< 5	< 5	< 5	< 14.5
TSS (mg/L) Instantaneous Maximum	< 5	< 5	< 5.0	< 5	< 5.0	< 5	< 5	< 5	< 5	< 5	< 5	24
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 1	< 2	< 1	< 1	< 1	3	< 1	< 1	< 1	< 2	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	< 1	< 1	5	< 1	< 1	1	6	< 1	1	1	3	< 1
Total Nitrogen (mg/L) Average Monthly	0.625	0.625	25.7	17.7	36.1	30.0	20.41	13.6	18.83	20.0	30.8	15.43
Ammonia (mg/L) Average Monthly	< 0.8	< 0.8	< 3.51	< 0.8	< 0.8	< 0.800	< 0.815	< 0.800	< 0.80	< 0.800	< 0.80	< 0.800
Ammonia (mg/L) Instantaneous Maximum	< 0.8	< 0.8	6.22	< 0.8	< 0.8	< 0.800	0.830	< 0.800	< 0.80	< 0.800	< 0.80	< 0.800
Total Phosphorus (mg/L) Average Monthly	1.1	1.5	1.3	1	1.1	0.87	0.90	0.77	0.79	1.1	0.86	0.92

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through December 31, 2024.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	16.6	XXX	33.2	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and DO are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limits are technology-based on Chapter 92a.47. The limits for CBOD<sub>5</sub>, Total Suspended Solids, and Fecal Coliform are technology based on Chapter 92a.47. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61.



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: January 1, 2025 through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.26	XXX	0.86	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	16.6	XXX	33.2	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab

Compliance Sampling Location: at Outfall 001, after disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH and DO are technology-based on Chapter 93.7. The Total Residual Chlorine (TRC) limit is water quality-based on Chapter 93.7. The limits for CBOD<sub>5</sub>, Total Suspended Solids, and Fecal Coliform are technology based on Chapter 92a.47. The limits for Ammonia-Nitrogen are water quality-based on Chapter 93.7. Monitoring for E. Coli, Total Nitrogen, and Total Phosphorus is based on Chapter 92a.61.

Attachment 1

**WQM 7.0 Effluent Limits** (Perennial Reach Model)

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20C	34172	BRUSH RUN					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.500	Perennial	PA0272795p	0.007	CBOD5	2		
				NH3-N	5.29	10.58	
				Dissolved Oxygen			3

Since the Perennial Reach Model limits for CBOD5 and NH3-N are the same as the limits from the Dry Reach Model, the inputs from the Dry Reach Model below are protective

CBOD5 = 25.0 mg/l

NH3-N = 25.0 mg/l

Since the Perennial Reach Model limit for DO is not the same as the limits from the Dry Reach Model, the DO limit will need to be a minimum of 3.0 mg/l to be protective.

DO = 3.0 mg/l

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	34172	BRUSH RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.500	0.007	21.824		7.063
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
3.632	0.322	11.274		0.027
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.00	0.000	1.93		0.805
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
6.330	16.238	Owens		6
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
1.147	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.115	2.00	1.76	7.97
	0.229	2.00	1.60	7.97
	0.344	2.00	1.46	7.97
	0.459	2.00	1.33	7.97
	0.573	2.00	1.22	7.97
	0.688	2.00	1.11	7.97
	0.803	2.00	1.01	7.97
	0.917	2.00	0.92	7.97
	1.032	2.00	0.84	7.97
	1.147	2.00	0.77	7.97

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34172	BRUSH RUN	0.500	1120.00	0.66	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.030	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Perennial	PA0272795p	0.0074	0.0000	0.0000	0.000	25.00	7.20

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	2.00	2.00	0.00	1.50
Dissolved Oxygen	2.00	8.24	0.00	0.00
NH3-N	5.29	0.00	0.00	0.70

(Values from Dry Reach Model)

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34172	BRUSH RUN	0.000	1119.00	0.90	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.030	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Wasteload Allocations**

SWP Basin    Stream Code                      Stream Name  
20C                      34172                                      BRUSH RUN

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.500	Perennial	12.75	10.58	12.75	10.58	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.500	Perennial	1.68	5.29	1.68	5.29	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.50	Perennial	2	2	5.29	5.29	3	3	0	0

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20C		34172				BRUSH RUN						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
0.500	0.02	0.00	0.02	.0114	0.00038	.322	3.63	11.27	0.03	1.147	21.82	7.06
<b>Q1-10 Flow</b>												
0.500	0.01	0.00	0.01	.0114	0.00038	NA	NA	NA	0.02	1.326	22.36	7.08
<b>Q30-10 Flow</b>												
0.500	0.03	0.00	0.03	.0114	0.00038	NA	NA	NA	0.03	1.022	21.48	7.05



**WQM 7.0 D.O.Simulation** (Dry Reach Model)

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20C	34172	BRUSH RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
1.400	0.007	24.317		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
1.253	0.275	4.555		0.038
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
21.86	1.362	21.58		0.976
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
3.727	29.353	Owens		2
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
1.440	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.144	17.21	18.75	2.00
	0.288	13.55	16.29	2.00
	0.432	10.67	14.16	2.00
	0.576	8.40	12.30	2.00
	0.720	6.61	10.69	2.00
	0.864	5.21	9.29	2.00
	1.008	4.10	8.07	2.00
	1.152	3.23	7.01	2.00
	1.296	2.54	6.09	2.00
	1.440	2.00	5.29	2.00

(use values above as inputs into the Perennial Reach Model)

### WQM 7.0 Modeling Specifications

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	Simulation	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34172	BRUSH RUN	1.400	1200.00	0.06	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.030	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Dry Stream	PA0272795	0.0074	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	2.00	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C	34172	BRUSH RUN	0.500	1120.00	0.66	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.030	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Perennial	PA0272795p	0.0110	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	2.75	2.00	0.00	1.50
Dissolved Oxygen	2.00	8.24	0.00	0.00
NH3-N	7.02	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>			<u>Stream Name</u>							
20C		34172			BRUSH RUN							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
<b>Q7-10 Flow</b>												
1.400	0.00	0.00	0.00	NA	0.01684	.275	1.25	4.56	0.04	1.440	24.32	7.00
<b>Q1-10 Flow</b>												
1.400	0.00	0.00	0.00	NA	0.01684	NA	NA	NA	0.00	0.000	0.00	0.00
<b>Q30-10 Flow</b>												
1.400	0.00	0.00	0.00	NA	0.01684	NA	NA	NA	0.00	0.000	0.00	0.00

Attachment 2

TRC EVALUATION				
Input appropriate values in B4:B8 and E4:E7				
0.0198	= Q stream (cfs)	0.5	= CV Daily	
0.00735	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 0.574		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.214		5.1d
				WLA_cfc = 0.553
				LTAMULT_cfc = 0.581
				LTA_cfc = 0.321
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.263		AFC
		INST_MAX_LIMIT (mg/l) = 0.862		
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST_MAX_LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)			