

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0272965
APS ID 1005789
Authorization ID 1295595

Applicant, Facility and Project Information

Applicant Name	<u>Davy J Black</u>	Facility Name	<u>Davy J Black SRSTP</u>
Applicant Address	<u>4626 Stevenson Hill Road</u> <u>Falls Creek, PA 15840-2424</u>	Facility Address	<u>4626 Stevenson Hill Road</u> <u>Falls Creek, PA 15840-2424</u>
Applicant Contact	<u>Davy J Black</u>	Facility Contact	<u>Davy J Black</u>
Applicant Phone	<u>(814) 316-6796</u>	Facility Phone	<u>(814) 316-6796</u>
Client ID	<u>321065</u>	Site ID	<u>786756</u>
SIC Code	<u>8800</u>	Municipality	<u>Washington Township</u>
SIC Description	<u>Private Households, Trans. & Utilities - Sewerage Systems</u>	County	<u>Jefferson</u>
Date Application Received	<u>October 24, 2019</u>	WQM Required	<u>no</u>
Date Application Accepted	<u>November 13, 2019</u>	WQM App. No.	<u>3314401</u>
Project Description	<u>NPDES permit renewal</u>		

Summary of Review

This is a NPDES renewal for an existing discharge.

Act 14 – Proof of Notification was submitted and received.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS

- | | |
|---|---------------------------------|
| A. AMRs | F. Stormwater into Sewers |
| B. DMRs | G. Right of Way |
| C. Depth of Septage and Scum Management | H. Solids Handling |
| D. Septic Tank Pumping | I. Public Sewerage Availability |
| E. Chlorine Optimization | |

The EPA Waiver is in effect.

A part II Water Quality Management permit is not required at this time. Existing WQM permit no. 3314401 is currently in place (Treatment facilities permitted include a 1000 gallon 2 compartment septic tank, a 500 gallon dosing tank with pump, a recirculating subsurface sand filter, an erosion feed chlorinator with a 500 gallon contact tank and de-chlorination.).

The estimated total stream flow to discharge ratio is approximately 200:1.

There are no open violations in WMS for the subject Client ID (310005) as of 11/14/2019.

Approve	Deny	Signatures	Date
		Jonathan F. Bucha / Civil Engineer Trainee	
		Justin C. Dickey, P.E. / Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude	<u>41° 10' 58"</u>	Longitude	<u>-78° 51' 8"</u>
Quad Name	<u>Falls Creek</u>	Quad Code	<u>0915</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Beaverdam Run (HQ-CWF)</u>	Stream Code	<u>48740</u>
NHD Com ID	<u>123859278</u>	RMI	<u>0.0000</u>
Drainage Area	<u>0.28</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>default</u>
Elevation (ft)	<u>1581</u>	Slope (ft/ft)	<u>0.0508</u>
Watershed No.	<u>17-C</u>	Chapter 93 Class.	<u>High Quality Waters - Cold Water Fishes</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>	<u>-</u>	
Temperature (°F)	<u>-</u>	<u>-</u>	
Hardness (mg/L)	<u>-</u>	<u>-</u>	
Other:	<u>-</u>	<u>-</u>	
Nearest Downstream Public Water Supply Intake	<u>Hawthorn Redbank Municipal Authority</u>		
PWS Waters	<u>Redbank Creek</u>	Flow at Intake (cfs)	<u>30.5</u>
PWS RMI	<u>29</u>	Distance from Outfall (mi)	<u>56.92</u>

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/month	Grab
TRC	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD5, Total Suspended Solids, and Fecal Coliform are technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7 and the monitoring frequency has been established as "upon request" due to CWF stream designation.