

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0272990
APS ID 1120772
Authorization ID 1498066

Applicant, Facility and Project Information

Applicant Name	<u>Jaclyn Rohrman</u>	Facility Name	<u>Jaclyn Rohrman SRSTP</u>
Applicant Address	<u>107 McConnell Drive</u>	Facility Address	<u>107 McConnell Drive</u>
	<u>Butler, PA 16001-8318</u>		<u>Butler, PA 16001-8318</u>
Applicant Contact	<u>Jaclyn Rohrman (jaclyn0120@aol.com)</u>	Facility Contact	<u>Jaclyn Rohrman (jaclyn0120@aol.com)</u>
Applicant Phone	<u>(724) 355-2483</u>	Facility Phone	<u>(724) 355-2483</u>
Client ID	<u>321508</u>	Site ID	<u>788624</u>
SIC Code	<u>8800</u>	Municipality	<u>Franklin Township</u>
SIC Description	<u>Private Households</u>	County	<u>Butler</u>
Date Application Received	<u>September 3, 2024</u>	WQM Required	<u>No</u>
Date Application Accepted	<u>September 4, 2024</u>	WQM App. No.	<u>-</u>
Project Description	<u>Renewal of an NPDES Permit for an existing discharge of treated sanitary wastewater.</u>		

Summary of Review

Act 14 - Proof of Notification was submitted and received.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

A. AMRs	F. Stormwater into sewers
B. DMRs	G. Right of way
C. Depth of Septage and Scum Measurement	H. Solids handling
D. Septic Tank Pumping	I. Public Sewerage Availability
E. Effluent Chlorine Optimization and Minimization	J. Ultraviolet Disinfection

SPECIAL CONDITIONS: None.

Permitted Treatment consists of: A Norweco Singular Bio-Kinetic Wastewater Treatment System Model TNT-500 consisting of a (WQM Permit no. 1015401) 250 gallon pretreatment chamber, a 600 gallon aeration chamber, and a 450 gallon final clarification chamber. Disinfection consists of a Salcor, Inc. Model 3G Ultraviolet (UV) light.

There are no open violations in efacts associated with the subject Client ID (321508) as of 4/16/2025.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Project Manager	4/16/2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	4/17/2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0004
Latitude	40° 53' 20.0"	Longitude	-79° 59' 39.0"
Quad Name	-	Quad Code	-
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to the Mulligan Run (CWF)	Stream Code	N/A
NHD Com ID	126220921	RMI	N/A
Drainage Area	-	Yield (cfs/mi ²)	-
Q ₇₋₁₀ Flow (cfs)	-	Q ₇₋₁₀ Basis	-
Elevation (ft)	-	Slope (ft/ft)	-
Watershed No.	20-C	Chapter 93 Class.	Cold Water Fishes
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	-		
Source(s) of Impairment	-		
TMDL Status	Final, 04/09/2009	Name	Little Connoquenessing Creek Watershed
Background/Ambient Data	Data Source		
pH (SU)	-	-	
Temperature (°F)	-	-	
Hardness (mg/L)	-	-	
Other:	-	-	
Nearest Downstream Public Water Supply Intake	-		
PWS Waters	-	Flow at Intake (cfs)	-
PWS RMI	-	Distance from Outfall (mi)	-

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

No modeling was performed for this NPDES Permit as the Norweco Singulair Bio-Kinetic model TNT-500 is capable of meeting CBOD₅ averages of 4 mg/l and TSS averages of 4 mg/l, which are less than the inputs of the WQ model.

Since pH was set as "upon request" in the previous NPDES Permit, and in accordance with the SOP, pH will be set as "upon request" with this renewal.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	XXX	1/year
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD ₅	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after Ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The limits for BOD₅, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47.