

Application Type Renewal
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0273074
APS ID 1047334
Authorization ID 1368774

Applicant, Facility and Project Information

Applicant Name	<u>Brian L. Trezona</u>	Facility Name	<u>Brian L. Trezona SRSTP</u>
Applicant Address	<u>10097 Mohawk Road</u> <u>Cranesville, PA 16410</u>	Facility Address	<u>10097 Mohawk Road</u> <u>Cranesville, PA 16410</u>
Applicant Contact	<u>Brian L. Trezona</u>	Facility Contact	<u>Brian L. Trezona</u>
Applicant Phone	<u>(724) 992-8404</u>	Facility Phone	<u>(724) 992-8404</u>
Client ID	<u>318316</u>	Site ID	<u>789173</u>
SIC Code	<u>8800</u>	Municipality	<u>Franklin Township</u>
SIC Description	<u>Private Households</u>	County	<u>Erie County</u>
Date Application Received	<u>September 2, 2021</u>	WQM Required	<u>No</u>
Date Application Accepted	<u>September 10, 2021</u>	WQM App. No.	<u>-</u>
Project Description	<u>Renewal of an NPDES Permit for a Single Residence Sewage Treatment Plant (SRSTP).</u>		

Summary of Review

Act 14 - Proof of Notification was submitted and received.

A Part II Water Quality Management permit is not required at this time.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS: *

- | | |
|--|---------------------------------|
| A. AMRs | F. Stormwater into sewers |
| B. DMRs | G. Right of way |
| C. Depth of Septage and Scum Measurement | H. Solids handling |
| D. Septic Tank Pumping | I. Public Sewerage Availability |
| E. Effluent Chlorine Optimization and Minimization | |

SPECIAL CONDITIONS: None.

Permitted treatment consists of: A 1,000 gallon dual compartment septic tank with an effluent filter, a 500 gallon dosing tank, an Ecoflo Peat Filter Model STB-500 Biofilter, and ultraviolet (UV) light disinfection.
(WQM Permit no. 2515402)

* - The previous condition titled, "Ultraviolet (UV) Light Disinfection Monthly Maintenance" was removed with this renewal.

There are no open violations in efacts for Client ID 318316 as of 7/19/2022.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	7/19/2022
X		Adam J. Pesek for Justin C. Dickey, P.E. / Environmental Engineer Manager	7/20/2022

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0004</u>
Latitude	<u>41° 55' 50"</u>	Longitude	<u>80° 14' 40"</u>
Quad Name	<u>-</u>	Quad Code	<u>-</u>
Wastewater Description: <u>treated sanitary wastewater</u>			

Receiving Waters	<u>Unnamed Tributary to the Little Elk Creek</u>	Stream Code	<u>N/A</u>
NHD Com ID	<u>123922403</u>	RMI	<u>N/A</u>
Drainage Area	<u>-</u>	Yield (cfs/mi ²)	<u>-</u>
Q ₇₋₁₀ Flow (cfs)	<u>-</u>	Q ₇₋₁₀ Basis	<u>-</u>
Elevation (ft)	<u>-</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>15-A</u>	Chapter 93 Class.	<u>CWF, MF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>

Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>

Background/Ambient Data		Data Source
pH (SU)	<u>-</u>	<u>-</u>
Temperature (°F)	<u>-</u>	<u>-</u>
Hardness (mg/L)	<u>-</u>	<u>-</u>
Other:	<u>-</u>	<u>-</u>

Nearest Downstream Public Water Supply Intake	<u>The Canada - Pennsylvania International Border</u>		
PWS Waters	<u>Lake Erie</u>	Flow at Intake (cfs)	<u>N/A</u>
PWS RMI	<u>N/A</u>	Distance from Outfall (mi)	<u>52.0</u>

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

This SFTF was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of an Ecoflo Peat Filter Model STB-500 Biofilter.

No modeling was performed for this NPDES Permit as the Ecoflo STB peat filter is capable of meeting CBOD5 averages of 4 mg/l and TSS averages of 4 mg/l, which are less than the inputs of the WQ model.

Monitoring for pH was added "upon request" per the SOP.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The limits for BOD5, Total Suspended Solids, and Fecal Coliform are BPJ-based on the Department's "Small Flow Treatment Facilities Manual."