



Application Type
Facility Type
Major / Minor

Renewal
Storm Water
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. **PA0276316**
APS ID **1010982**
Authorization ID **1507810**

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|--|
| Applicant Name | JFR Salvage LLC | Facility Name | JFR Salvage LLC East Stroudsburg Facility |
| Applicant Address | 6500 Sullivan Trail | Facility Address | 1318 Crowe Road |
| | Wind Gap, PA 18091 | | East Stroudsburg, PA 18301 |
| Applicant Contact | Joseph Raimo | Facility Contact | Joseph Raimo |
| Applicant Phone | (610) 863-6071 | Facility Phone | (610) 863-6071 |
| Client ID | 355087 | Site ID | 841540 |
| SIC Code | 5093 | Municipality | Stroud Township |
| SIC Description | Wholesale Trade - Scrap And Waste Materials | County | Monroe |
| Date Application Received | November 25, 2024 | EPA Waived? | Yes |
| Date Application Accepted | November 25, 2024. | If No, Reason | |
| Purpose of Application | Renewal of individual NPDES stormwater permit | | |

Summary of Review

The applicant is requesting a renewal NPDES permit to discharge stormwater associated with industrial activity to Brodhead Creek, a HQ-CWF, MF (High Quality-Cold Water Fishes, Migratory Fishes) designated receiving stream in state water plan basin 1-E (Brodhead Creek). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use. Please note that Brodhead Creek does have an existing use classification from S.R. 2022 (approximately RMI 6.6) to mouth.

The facility is a scrap processing and recycling center. The scrap metal is brought into the facility, weighed at the scale, segregated by type, and then transported offsite to an approved facility.

The facility is categorized by SIC code 5093 (Wholesale Trade – Scrap and Waste Materials) and falls under **Appendix P** monitoring requirements of the new PAG-03 General Permit. Semiannual monitoring / reporting includes Chemical Oxygen Demand (COD), Total Suspended Solids (TSS), Oil & Grease, Total Nitrogen, Total Phosphorus, Total Aluminum, Total Zinc, Total Aluminum and Total Lead. Benchmarks exist for TSS, Oil & Grease and COD.

Benchmark values are not effluent limitations, and exceedances do not constitute permit violations. However, if the permittee's sampling demonstrates exceedances of benchmark values for two or more consecutive monitoring periods, the permittee shall take action in accordance with Part C. III. F. of the permit.

A corrective action plan (CAP) must be submitted to DEP if the discharge concentration for the parameters exceeds the benchmark values for two or more consecutive monitoring periods.

A compliance evaluation inspection (CEI) was performed November 17, 2020, by the department staff and no violations were found.

| Approve | Deny | Signatures | Date |
|---------|------|---|-------------------|
| X | | Hakim Yesli (signed) Hakim Yesli / Environmental Engineering Specialist | December 29, 2025 |
| X | |  Edward Dudick, P.E. / Environmental Engineer Manager | December 31, 2025 |

Summary of Review

During the inspection, recommendations were given to the site manager that sample collection needs to follow a correct procedure to obtain representative sample of stormwater flow.

According to eDMR reports, there is a history of TSS benchmarks exceedances but return to compliance is noticed in second sampling event of 2025.

Permittee is reminded to follow the Department recommendation for obtaining representative samples. In the case TSS sampling results will again show consecutive exceedances over the next sampling events, a CAP plan must be submitted to the department.

The stormwater results submitted with this renewal application show an Iron concentration of 12.6mg/L. This is an elevated concentration which can lead to potential pollution of the discharge stream; Permittee is encouraged to investigate the source of the Iron and apply enhanced BMPs to control it.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

