

Application Type **New**  
 Facility Type **Storm Water**  
 Major / Minor **Minor**

**NPDES PERMIT FACT SHEET**

Application No. **PA0276481**  
 APS ID **1049491**  
 Authorization ID **1372513**

**Applicant and Facility Information**

Applicant Name	<u><b>Fed Express Corp</b></u>	Facility Name	<u><b>Fedex Express ABEA</b></u>
Applicant Address	<u>3620 Hacks Cross Road Building B 3rd Floor Memphis, TN 38125-8800</u>	Facility Address	<u>126 N Commerce Way Bethlehem, PA 18017-8614</u>
Applicant Contact	<u>Don Rautine</u>	Facility Contact	<u>Don Rautine</u>
Applicant Phone	<u>(901) 434-3741</u>	Facility Phone	<u>(901) 434-3741</u>
Client ID	<u>288019</u>	Site ID	<u>852594</u>
SIC Code	<u>4215</u>	Municipality	<u>Hanover Township</u>
SIC Description	<u>Trans. &amp; Utilities - Courier Services</u>	County	<u>Northampton</u>
Date Application Received	<u>October 12, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 13, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>A new NPDES permit for a new discharge of Industrial Stormwater</u>		

**Summary of Review**

The application is for a new NPDES permit for a new discharge of Industrial Stormwater. The receiving stream, Little Lehigh Creek (HQ-CWF, MF), is located in State Water Plan watershed 2-C and is classified for High Quality-Cold Water and Migratory Fish, aquatic life, water supply and recreation. Per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than the designated use. The discharge is not expected to affect public water supplies.

The facility is classified under SIC Code 4215 - Establishments primarily engaged in Trans. & Utilities - Courier Services. The PAG-03 General Permit Appendix L contains the minimal site specific best management practices (BMPs) and monitoring requirements for this industrial stormwater classification. The monitoring requirements are for pH (S.U.), Total Suspended Solids, Oil and Grease. The requirements will also include prohibition of non-stormwater discharges; Hazardous Substances Release; a PPC Plan; Comprehensive Site Compliance Inspection; and Record keeping.

PAG-03 General Stormwater Permit Appendix L has these expected Statewide Benchmark Values for this class of industry. Effective BMPs must be installed to attain these values.

The SIC Code 5093 falls under the "Appendix P" of the PAG-03 General Permit for minimal BMPs, benchmarks and monitoring :

Parameter	Benchmark Value (mg/L)
Total Suspended Solids (TSS)	100
Oil and Grease	30

Approve	Return	Deny	Signatures	Date
X			Bernard Feist (signed) Bernard Feist, P.E. / Environmental Engineer	November 16, 2021
X			Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager	11-19-21

## Summary of Review

A benchmark value is the concentration of a pollutant in stormwater discharges that serves as a threshold for the determination of whether existing site BMPs are effective in controlling stormwater pollution. In the event that stormwater discharge concentrations for a parameter exceeds the benchmark value(s) identified below at the same outfall for two or more consecutive monitoring periods, the permittee shall develop a corrective action plan to reduce the concentrations of the parameters in stormwater discharges. Utilize Pennsylvania Stormwater Best Management Practices Manual 363-0300-002 when required.

The WMS "Open Violations by Client Report" was run and there are No Open Violations.

### Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.