

Application Type New  
Facility Type Storm Water  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL INDUSTRIAL WASTE (IW)  
AND IW STORMWATER**

Application No. **PA0276880**  
APS ID **1117064**  
Authorization ID **1490906**

**Applicant and Facility Information**

Applicant Name	<u>LKQ Northeast, Inc.</u>	Facility Name	<u>LKQ Thru Way Auto Parts</u>
Applicant Address	<u>201 State Road</u> <u>Parryville, PA 18244</u>	Facility Address	<u>201 State Road</u> <u>Parryville, PA 18244</u>
Applicant Contact	<u>Mark Biello</u>	Facility Contact	<u>Mark Biello</u>
Applicant Phone	<u>(570) 249-4884</u>	Facility Phone	<u>(570) 249-4884</u>
Client ID	<u>260637</u>	Site ID	<u>699516</u>
SIC Code	<u>5015</u> <u>Wholesale Trade - Motor Vehicle Parts, Used</u>	Municipality	<u>Parryville Borough</u>
SIC Description		County	<u>Carbon</u>
Date Application Received	<u>March 23, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 23, 2023</u>	If No, Reason	<u>-</u>
Purpose of Application	New individual NPDES permit for industrial stormwater discharges previously covered under a general permit.		

**Summary of Review**

The applicant is requesting a new NPDES permit for discharges of stormwater associated with industrial activities to Pohopoco Creek, a CWF/MF designated receiving stream in state water plan basin 02-B (Middle Lehigh River). As per the Department's current existing use list, the receiving stream has a HQ-CWF/MF use and is a designated Class A Wild Trout stream. There are no impairments listed for the receiving stream.

Previously, stormwater discharges from the site were permitted through general permit PAR602243. The receiving stream's change in existing use occurred in May 2021 and, therefore, the facility is required to obtain an individual permit.

This facility is categorized by SIC code 5015 (Used Motor Vehicle Parts). The standard Appendix O monitoring requirements of the PAG-03 general permit will be required for this individual permit. Semiannual monitoring/reporting is required for TSS, Oil & Grease, COD, Total Aluminum, Total Iron, Total Lead, Total Nitrogen and Total Phosphorus. Benchmark values are included in the permit for TSS (100 mg/L), COD (120 mg/L), and Oil & Grease (30 mg/L). The benchmark values listed are not effluent limitations, and exceedances do not constitute permit violations. However, if the permittee's sampling demonstrates exceedances of benchmark values for two or more consecutive monitoring periods, the permittee shall act in accordance with Part C.III.G of the permit.

The PPC plan submitted with the application appears to include the required information and was last updated in November 2021. Outfall coordinates were updated with latitude/longitude information in the permit application. An additional outfall (Outfall 003) was identified in the application and added to the permit requirements. No PCSM BMPs were identified on the site.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held,

Approve	Deny	Signatures	Date
X		 Brian Burden, E.I.T. / Project Manager	July 3, 2024
X		Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Acting Engineer Manager	7-10-24

**Summary of Review**

notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

