



Application Type New  
Wastewater Type Sewage  
Facility Type SRSTP

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SFTF/SRSTP**

Application No. **PA0282057**  
APS ID **1144350**  
Authorization ID **1540324**

**Applicant, Facility and Project Information**

Applicant Name	<b>Steven H Kennedy</b>	Facility Name	<b>Kennedy Properties</b>
Applicant Address	4636 Cold Springs Road	Facility Address	4636 Cold Springs Road
Applicant Contact	Steven Kennedy	Facility Contact	Steven Kennedy
Applicant Phone	(814) 643-3613	Facility Phone	(814) 643-3613
Client ID	394795	Site ID	882564
SIC Code	8800	Municipality	Oneida Township
SIC Description	Private Households	County	Huntingdon
Date Application Received	August 25, 2025	WQM Required	Pending
Date Application Accepted	September 4, 2025	WQM App. No.	3125403
Project Description	Application received for the proposed construction and operation of a residential sewage treatment facility for an existing dwelling.		

**Summary of Review**

The facility located at 4636 Cold Springs Road is an existing four-bedroom residential dwelling. The proposed system will serve to treat and discharge the sewage from the above residence.

The proposed system will be a Premier Tech ECP-530-P-P-Pack Coco filter with an integrated UV and pump component. After treatment, the effluent will discharge into a drainage channel to Standing Stone Creek.

The Department has reviewed the application in order to ensure that the facility does not receive or discharge a flow greater than 2,000 GPD or exceed the specified limits of CBOD5, pH, Total Suspended Solids, and Fecal Coliform prescribed in the permit. As per 25 Pa. Code § 92a.53, all applicable effluent limits and standards are considered in development of the permit. The limits noted in the permit suggest that any applicable water quality standards will not be violated.

The limits discussed in the permit are based off of several factors that were determined by the Standard Operating Procedure for Small Flow Treatment Facilities (SOP No. BCW-PMT-003).

The TSS limits were prescribed based on The Department's Water Quality Antidegradation Implementation Guidance ID No. 391-0300-002

The Fecal Coliform limits listed in the permit were required by the Bureau of Clean Water, as stated in Chapters 92a and 93.

Based on the review outlined in this fact sheet, it is recommended that the NPDES permit be drafted. Also, it is recommended that the WQM permit be issued upon issuance of the final NPDES permit.

Approve	Deny	Signatures	Date
X		Jared Lescavage Jared Lescavage / Project Manager	September 9, 2025
X		Scott M Arwood Scott M. Arwood, P.E. / Environmental Engineer Manager	09/11/2025

**Summary of Review**

**Public Participation**

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.0005
Latitude	40° 32' 28.27"	Longitude	-77° 58' 45.42"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Unnamed Tributary to Standing Stone Creek (HQ-CWF, MF)	Stream Code	
NHD Com ID	65606134	RMI	0.0800
Drainage Area	.69	Yield (cfs/mi <sup>2</sup> )	
Q <sub>7-10</sub> Flow (cfs)	0.0474	Q <sub>7-10</sub> Basis	StreamStats
Elevation (ft)		Slope (ft/ft)	
Watershed No.	11-B	Chapter 93 Class.	HQ-CWF, MF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Background/Ambient Data		Data Source	
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake		Huntingdon Boro Water Authority	
PWS Waters	Juniata River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	6

Changes Since Last Permit Issuance: N/A

Other Comments: None

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	N/A
<b>Summary of Inspections:</b>	N/A

Other Comments: **None**

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	XXX	1/year
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments: N/A