

Application Type New
Facility Type Sewage
Major / Minor Minor

**NPDES PERMIT FACT SHEET
ADDENDUM**

Application No. PA0284947
APS ID 1066620
Authorization ID 1401670

Applicant and Facility Information

Applicant Name	<u>Trisha Woroszylo</u>	Facility Name	<u>Woroszylo Properties SRSTP</u>
Applicant Address	<u>221 Silver Spring Lane</u> <u>New Brighton, PA 15066-3585</u>	Facility Address	<u>221 Silver Spring Lane</u> <u>New Brighton, PA 15066-3585</u>
Applicant Contact	<u>Trisha Woroszylo</u>	Facility Contact	<u>Trisha Woroszylo</u>
Applicant Phone	<u>(724) 622-1340</u>	Facility Phone	<u>(724) 622-1340</u>
Client ID	<u>370904</u>	Site ID	<u>858274</u>
SIC Code	<u>8800</u>	Municipality	<u>Daugherty Township</u>
SIC Description	<u>Private Households</u>	County	<u>Beaver</u>
Date Published in PA Bulletin	<u>December 3, 2022</u>	EPA Waived?	<u>Yes</u>
Comment Period End Date	<u>January 2, 2023</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for a new NPDES permit for discharge of treated Sewage</u>		



Internal Review and Recommendations

The Department of Environmental Protection (DEP) published notice of draft Authorization to Discharge under the National Discharge Elimination System (NPDES) discharge requirements for treated sewage for Woroszylo Properties SRSTP in the *Pennsylvania Bulletin* on December 10, 2022 [52 Pa. B. 7396]. A 30-day comment period was provided during which interested parties were directed to submit comments to DEP. No comments were received in reference to this permit.

During the draft phase, it was noted that the draft permit is missing a Part C condition for monthly cleaning of the UV system. The condition is being added to the permit as Part C II and the permit is being re-drafted.

The purpose of this fact sheet is to document that no comments were received during the comment period, but a change was made to the Part C conditions of the permit.

Permit issuance is recommended.

Approve	Return	Deny	Signatures	Date
X			 Stephanie Conrad / Environmental Engineering Specialist	January 25, 2023
x			 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager	January 31, 2023

ATTACHMENT A

PA Bulletin Notice

NOTICES

DEPARTMENT OF ENVIRONMENTAL PROTECTION

Applications, Actions and Special Notices

APPLICATIONS

[52 Pa.B. 7396]
 [Saturday, December 3, 2022]

THE PENNSYLVANIA CLEAN STREAMS LAW AND THE FEDERAL CLEAN WATER ACT

APPLICATIONS FOR NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMITS AND WATER QUALITY MANAGEMENT (WQM) PERMITS UNDER THE CLEAN STREAMS LAW AND FEDERAL CLEAN WATER ACT

This notice provides information about persons who have applied to the Department of Environmental Protection (DEP) for a new, renewed, or amended NPDES or WQM permit, or a permit waiver for certain stormwater discharges, or have submitted a Notice of Intent (NOI) for coverage under a General Permit. The applications and NOIs concern, but are not limited to, effluent discharges from sewage treatment facilities and industrial facilities to surface waters or groundwater; stormwater discharges associated with industrial activity (industrial stormwater), construction activity (construction stormwater), and municipal separate storm sewer systems (MS4s); the application of pesticides; the operation of Concentrated Animal Feeding Operations (CAFOs); and the construction of sewage, industrial waste, and manure storage, collection and treatment facilities. This notice is provided in accordance with 25 Pa. Code Chapters 91 and 92a and 40 CFR Part 122, implementing The Clean Streams Law (35 P.S. §§ 691.1—691.1001) and the Federal Clean Water Act (33 U.S.C.A. §§ 1251—1376). More information on the types of NPDES and WQM permits that are available can be found on DEP's website (visit www.dep.pa.gov and select Businesses, Water, Bureau of Clean Water, Wastewater Management, and NPDES and WQM Permitting Programs).

PA0284947, Sewage, SIC Code 8800, **Trisha Woroszylo**, 221 Silver Spring Lane, New Brighton, PA 15066-3585. Facility Name: Woroszylo Properties SRSTP. This proposed facility is located in Daugherty Township, **Beaver County**.

Description of Proposed Activity: The application is for a new NPDES permit for a new discharge of treated SRSTP sewage.

The receiving stream(s), Unnamed Tributary to Blockhouse Run (WWF), is located in State Water Plan watershed 20-B and is classified for Warm Water Fishes, aquatic life, water supply and recreation. The discharge is not expected to affect public water supplies.

The proposed effluent limits for Outfall 001 are based on a design flow of .0004 MGD.—Limits.

Parameters	<i>Mass Units (lbs/day)</i>		<i>Concentrations (mg/L)</i>			
	Average Monthly Annl Avg	Average Weekly XXX	<i>Annual</i>			
			<i>Minimum</i> Inst Min	<i>Average</i>	<i>Maximum</i>	<i>IMAX</i>
Flow (MGD)	Report XXX	XXX	XXX	XXX	XXX	XXX
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0
Biochemical Oxygen Demand (BOD ₅)	XXX	XXX	XXX	10.0	XXX	20.0
Total Suspended Solids	XXX	XXX	XXX	10.0	XXX	20.0
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX

You may make an appointment to review the DEP files on this case by calling the File Review Coordinator at 412-442-4000.

The EPA Waiver is in effect.

Southwest Regional Office