

Application Type New  
Wastewater Type Sewage  
Facility Type SRSTP

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SFTF/SRSTP**

Application No. PA0288187  
APS ID 1011956  
Authorization ID 1306535

**Applicant, Facility and Project Information**

Applicant Name	<u>David H Curtis</u>	Facility Name	<u>David Curtis SRSTP</u>
Applicant Address	<u>15 Cliff Street</u> <u>Albion, PA 16401</u>	Facility Address	<u>10321 State Road</u> <u>Cranesville, PA 16410</u>
Applicant Contact	<u>David Curtis</u>	Facility Contact	<u>David Curtis</u>
Applicant Phone	<u>(814) 756-0709</u>	Facility Phone	<u>(814) 756-0709</u>
Client ID	<u>355320</u>	Site ID	<u>839385</u>
SIC Code	<u>8800</u>	Municipality	<u>Elk Creek Township</u>
SIC Description	<u>Private Households</u>	County	<u>Erie</u>
Date Application Received	<u>February 19, 2020</u>	WQM Required	<u>Yes - pending</u>
Date Application Accepted	<u></u>	WQM App. No.	<u>2520405</u>
Project Description	<u>Single Residence Sewage Treatment Plant.</u>		

**Summary of Review**

The project involves the installation of a new single residence sewage treatment plant to replace an existing malfunctioning onlot system.

Act 537 Planning was approved on December 20, 2019.

Proposed treatment will consist of: A Norweco Singulair 960-500 GDP tank and equipment followed by a Norweco Hydro-Kinetic Bio-Film Reactor, a chlorinator, and a chlorine contact tank.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Emily Voorhees Emily C. M. Voorhees / Civil Engineer	March 31, 2020
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	March 31, 2020

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude	<u>41° 54' 6.7"</u>	Longitude	<u>-80° 17' 7.1"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			

Receiving Waters	<u>Little Elk Creek (CWF, MF)</u>	Stream Code	<u>62515</u>
NHD Com ID	<u>123919655</u>	RMI	<u>0.7900</u>
Drainage Area	<u>2.04 sq. mi.</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1</u>
Q <sub>7-10</sub> Flow (cfs)	<u>2.04</u>	Q <sub>7-10</sub> Basis	<u>Default</u>
Elevation (ft)	<u>1,126</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>15A</u>	Chapter 93 Class.	<u>Cold Water Fishes, Migratory Fishes</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>

Assessment Status Attaining Use(s)

Cause(s) of Impairment

Source(s) of Impairment

TMDL Status  Name

Background/Ambient Data		Data Source
pH (SU)	<u>-</u>	<u></u>
Temperature (°F)	<u>-</u>	<u></u>
Hardness (mg/L)	<u>-</u>	<u></u>
Other:	<u>-</u>	<u></u>

Nearest Downstream Public Water Supply Intake	<u>PA/Canadian International Boundary</u>		
PWS Waters	<u>Lake Erie</u>	Flow at Intake (cfs)	<u>-</u>
PWS RMI	<u>-</u>	Distance from Outfall (mi)	<u>Approx. 17.01</u>

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
TRC	XXX	XXX	XXX	Report	XXX	XXX	1/month	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after the chlorine disinfection.

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD5, Total Suspended Solids, and Fecal Coliforms are technology- based on Chapter 92a.47.