

Application Type New
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0288268
APS ID 1013193
Authorization ID 1308717

Applicant, Facility and Project Information

Applicant Name	<u>Aldo DeSanto</u>	Facility Name	<u>Aldo DeSanto SRSTP</u>
Applicant Address	<u>1660 Headin Lane</u> <u>Southaven, MS 38672</u>	Facility Address	<u>3911 Harborsgreene Road</u> <u>Erie, PA 16510</u>
Applicant Contact	<u>Aldo DeSanto, Owner</u>	Facility Contact	<u>Aldo DeSanto, Owner</u>
Applicant Phone	<u>(662) 420-3367</u>	Facility Phone	<u>(662) 420-3367</u>
Client ID	<u>355687</u>	Site ID	<u>250767</u>
SIC Code	<u>8800</u>	Municipality	<u>Greene Township</u>
SIC Description	<u>Private Households</u>	County	<u>Erie County</u>
Date Application Received	<u>March 11, 2020</u>	WQM Required	<u>Yes</u>
Date Application Accepted	<u>March 12, 2020</u>	WQM App. No.	<u>2589409 will be transferred concurrently</u>
Project Description	<u>Single Residence Sewage Treatment Plant</u>		

Summary of Review

Act 14 - Proof of Notification was submitted and received.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIREMENTS:

- | | |
|--|---------------------------------|
| A. AMRs | F. Stormwater into sewers |
| B. DMRs | G. Right of way |
| C. Depth of Septage and Scum Measurement | H. Solids handling |
| D. Septic Tank Pumping | I. Public Sewerage Availability |
| E. Effluent Chlorine Optimization and Minimization | |

SPECIAL CONDITIONS: None.

Proposed treatment will consist of: A new 1,250 gallon dual compartment concrete septic tank with an effluent filter, an Ecoflo coco filter EC7-500-P-G-USA treatment unit, a Salcor Model 3G Ultraviolet (UV) light disinfection unit, and an effluent pump tank.

There are no open violations in effects associated with the subject Client ID (355687) as of 5/4/2020.

Approve	Deny	Signatures	Date
X		Stephen A. McCauley Stephen A. McCauley, E.I.T. / Environmental Engineering Specialist	5/4/2020
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	May 18, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.0005
Latitude	42° 05' 59.2"	Longitude	-79° 58' 32.1"
Quad Name	-	Quad Code	-
Wastewater Description:		Sewage Effluent	
Receiving Waters	Unnamed Tributary to the Fourmile Creek (WWF, MF)	Stream Code	N/A
NHD Com ID	123923484	RMI	N/A
Drainage Area	-	Yield (cfs/mi ²)	-
Q ₇₋₁₀ Flow (cfs)	-	Q ₇₋₁₀ Basis	-
Elevation (ft)	-	Slope (ft/ft)	-
Watershed No.	15-A	Chapter 93 Class.	Warm Water Fishes, Migratory Fishes
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	-		
Source(s) of Impairment	-		
TMDL Status	-	Name	-
Background/Ambient Data		Data Source	
pH (SU)	-		-
Temperature (°F)	-		-
Hardness (mg/L)	-		-
Other:	-		-
Nearest Downstream Public Water Supply Intake		-	
PWS Waters	-	Flow at Intake (cfs)	-
PWS RMI	-	Distance from Outfall (mi)	-

No modeling was performed for this NPDES Permit as the Ecoflo coco filter EC7-500 treatment unit is capable of meeting CBOD5 averages of 8 mg/l and TSS averages of 6 mg/l, which are less than the inputs of the WQ model.

This NPDES Permit will replace General Permit number PAG048308. Ownership will also be transferred from Ken D. Richter, Jr. to Aldo DeSanto.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the Pennsylvania Bulletin in accordance with 25 Pa. Code § 92a.82. Upon publication in the Pennsylvania Bulletin, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the Pennsylvania Bulletin at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (MGD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after Ultraviolet (UV) light disinfection.

Flow is monitor only based on Chapter 92a.61. The limits for pH are technology-based on Chapter 93.7. The limits for BOD5, Total Suspended Solids, and Fecal Coliforms are technology-based on Chapter 92a.47.