

Application Type New
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0288292
APS ID 1014314
Authorization ID 1310508

Applicant, Facility and Project Information

Applicant Name	<u>Susan Strohmeier</u>	Facility Name	<u>Susan Strohmeier Lot 1 SRSTP</u>
Applicant Address	<u>5906 Footemill Road</u> <u>Erie, PA 16509-3806</u>	Facility Address	<u>9831 Bliley Road</u> <u>Waterford, PA 16441</u>
Applicant Contact	<u>Susan Strohmeier</u>	Facility Contact	<u>Susan Strohmeier</u>
Applicant Phone	<u>(814) 450-6618</u>	Facility Phone	<u>(814) 450-6618</u>
Client ID	<u>355918</u>	Site ID	<u>835369</u>
SIC Code	<u>8800</u>	Municipality	<u>Greene Township</u>
SIC Description	<u>Private Households</u>	County	<u>Erie</u>
Date Application Received	<u>March 26, 2020</u>	WQM Required	<u>Yes</u>
Date Application Accepted	<u>April 14, 2020</u>	WQM App. No.	<u>2520408</u>
Project Description	<u>Single Residence Sewage Treatment Plant.</u>		

Summary of Review

This is a new discharge for an existing 3-bedroom home to a repair of an existing malfunctioning on-lot system.

Act 14 – Proof of Notification was submitted and received.

Proposed treatment will consist of (WQM Permit No. 2520408): A Norweco Singulair Model 960 aerobic unit, then through Norweco Bio Film Reactors with a Salcor 3G Ultraviolet (UV) light disinfection unit.

The EPA Waiver is in effect.

There are no open violations in WMS for the subject Client ID (355918) as of 4/14/2020.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Civil Engineer Trainee	April 15, 2020
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	April 21, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0005</u>
Latitude	<u>42° 4' 37.49"</u>	Longitude	<u>-79° 55' 28.78"</u>
Quad Name	<u>Hammett</u>	Quad Code	<u>25922</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>East Branch LeBoeuf Creek (TSF)</u>	Stream Code	<u>53537</u>
NHD Com ID	<u>127349484</u>	RMI	<u>0.8800</u>
Drainage Area	<u>0.11</u>	Yield (cfs/mi ²)	<u>0.1</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.01</u>	Q ₇₋₁₀ Basis	<u>Default</u>
Elevation (ft)	<u>1374</u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>16A</u>	Chapter 93 Class.	<u>Trout Stocking</u>
Existing Use	<u>Trout Stocking (TSF)</u>	Existing Use Qualifier	<u>---</u>
Exceptions to Use	<u>---</u>	Exceptions to Criteria	<u>---</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>---</u>		
Source(s) of Impairment	<u>---</u>		
TMDL Status	<u>---</u>	Name	<u>---</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	
Temperature (°F)	<u>20</u>	Default	
Hardness (mg/L)	<u>100</u>	Default	
Other:	<u>---</u>	---	
Nearest Downstream Public Water Supply Intake	<u>Cambridge Springs Borough</u>		
PWS Waters	<u>French Creek</u>	Flow at Intake (cfs)	<u>51.45</u>
PWS RMI	<u>48.35</u>	Distance from Outfall (mi)	<u>>50 mi</u>

Changes Since Last Permit Issuance: N/A – This is a proposed discharge (Planning was approved on March 13, 2020).

Other Comments:

This SRSTP was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of a Norweco Singlair Model 960. The proposed discharge is to resolve a repair of a malfunctioning on-lot system.

The Norweco Singlair Model 960 treatment tank is reportedly capable of meeting CBOD₅ averages of 10 mg/l and TSS averages of 10 mg/l.

In accordance with the SOP, no water quality modeling was performed since this is a SRSTP.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (GPD)	Report	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	Report Inst Min	XXX	XXX	Report	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD₅, Total Suspended Solids, and Fecal Coliform are technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7.

Attachment 1
eMap – Location Map



Attachment 2
Google Earth Imagery

