

Application Type New  
Wastewater Type Sewage  
Facility Type SRSTP

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SFTF/SRSTP**

Application No. PA0288411  
APS ID 1017070  
Authorization ID 1315554

**Applicant, Facility and Project Information**

Applicant Name	<u>David M Carroll Jr</u>	Facility Name	<u>David M Carroll Jr SRSTP</u>
Applicant Address	<u>9705 Bliley Road</u> <u>Waterford, PA 16441-7309</u>	Facility Address	<u>9705 Bliley Road</u> <u>Waterford, PA 16441-7309</u>
Applicant Contact	<u>David Carroll</u>	Facility Contact	<u>David Carroll</u>
Applicant Phone	<u>(814) 825-7305</u>	Facility Phone	<u>(814) 825-7305</u>
Client ID	<u>356676</u>	Site ID	<u>839165</u>
SIC Code	<u>8800</u>	Municipality	<u>Greene Township</u>
SIC Description	<u>Private Households</u>	County	<u>Erie</u>
Date Application Received	<u>May 12, 2020</u>	WQM Required	<u>Yes</u>
Date Application Accepted	<u>May 28, 2020</u>	WQM App. No.	<u>25204013</u>
Project Description	<u>Single Residence Sewage Treatment Plant.</u>		

**Summary of Review**

The project involves the installation of a new 400 gallon per day single residence sewage treatment plant to replace an existing malfunctioning onlot system for a 3-bedroom home.

Act 14 – Proof of notification was submitted and received.

The applicant should be able to meet the limits of this permit, which will protect the uses of the receiving stream.

I. OTHER REQUIRMENTS

- |   |                                 |
|---|---------------------------------|
| A. AMRs                                 | F. Stormwater into Sewers       |
| B. DMRs                                 | G. Right of Way                 |
| C. Depth of Septage and Scum Management | H. Solids Handling              |
| D. Septic Tank Pumping                  | I. Public Sewerage Availability |
| E. Chlorine Optimization                |                                 |

SPECIAL CONDITIONS: None

Proposed treatment will consist of (WQM Permit No. 2520413): A 1,00-gallon concrete septic tank, a Premier Tech EC7-500-C-GDV Coco Filter Unit, and a Salcor 3G ultraviolet disinfection unit, where the treated effluent will discharge into a roadside ditch from a riprap channel on owners property to unnamed tributary 53568 (TSF), to East Branch Le Boeuf Creek (TSF).

There are no open violations in WMS for the subject client ID (356676) as of 6/15/2020.

Approve	Deny	Signatures	Date
X		Jon F. Bucha Jonathan F. Bucha / Civil Engineer Trainee	June 15, 2020
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	June 16, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.0004
Latitude	42° 4' 57.6"	Longitude	-79° 55' 52.4"
Quad Name	Hammett	Quad Code	0206
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to East Branch LeBoeuf Creek (TSF)	Stream Code	53568
NHD Com ID	127349428	RMI	1.58
Drainage Area	1.29 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.0436
Q <sub>7-10</sub> Flow (cfs)	0.0563	Q <sub>7-10</sub> Basis	Streamstats
Elevation (ft)	1415 (Google Earth)	Slope (ft/ft)	-
Watershed No.	16-A	Chapter 93 Class.	Trout Stocking
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	-		
Source(s) of Impairment	-		
TMDL Status	-	Name	-
Background/Ambient Data		Data Source	
pH (SU)	-		-
Temperature (°F)	-		-
Hardness (mg/L)	-		-
Other:	-		-
Nearest Downstream Public Water Supply Intake	Cambridge Springs Borough		
PWS Waters	French Creek	Flow at Intake (cfs)	51.45
PWS RMI	48.35	Distance from Outfall (mi)	39.87

Changes Since Last Permit Issuance: N/A

Other Comments: This treatment system is capable of meeting effluent limits.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection.

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD5, Total Suspended Solids, and Fecal Coliform are technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7 and the monitoring frequency has been established as "upon request" due to CWF stream designation.



