

Application Type New
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0288497
APS ID 1017476
Authorization ID 1316323

Applicant, Facility and Project Information

Applicant Name	<u>Judith Gosnell-Lamb & Roy Lamb</u>	Facility Name	<u>Judith Gosnell-Lamb & Roy Lamb SRSTP</u>
Applicant Address	<u>33 W Methodist Road Greenville, PA 16125-9712</u>	Facility Address	<u>33 W Methodist Road Greenville, PA 16125-9712</u>
Applicant Contact	<u>Roy Lamb</u>	Facility Contact	<u>Judith Gosnell-Lamb & Roy Lamb</u>
Applicant Phone	<u>(724) 588-2456</u>	Facility Phone	<u>(724) 588-2456</u>
Client ID	<u>356782</u>	Site ID	<u>842049</u>
SIC Code	<u>8800</u>	Municipality	<u>Hempfield Township</u>
SIC Description	<u>Private Households</u>	County	<u>Mercer</u>
Date Application Received	<u>May 12, 2020</u>	WQM Required	<u>Yes</u>
Date Application Accepted	<u>June 19, 2020</u>	WQM App. No.	<u>4320409</u>
Project Description	<u>Single Residence Sewage Treatment Plant.</u>		

Summary of Review

This is a new discharge for an existing 4-bedroom home to a repair of an existing malfunctioning on-lot system.

Act 14 – Proof of Notification was submitted and received.

Proposed treatment will consist of (WQM Permit No. 4320409): An existing Norweco Singulair Bio-Kinetic Treatment System followed by a new Norweco Hydro-Kinetic Bio-Film Reactor unit with a Norweco AT1500 Ultraviolet (UV) light disinfection unit.

The EPA Waiver is in effect.

There are no open violations in WMS for the subject Client ID (356782) as of 6/22/2020.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Civil Engineer Trainee	June 22, 2020
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	June 29, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0005</u>
Latitude	<u>41° 22' 33.95"</u>	Longitude	<u>-80° 22' 3.17"</u>
Quad Name	<u>Greenville East</u>	Quad Code	<u>41080D3</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Shenango River (WWF)</u>	Stream Code	<u>36154</u>
NHD Com ID	<u>130026963</u>	RMI	<u>0.1700</u>
Drainage Area	<u>3.75</u>	Yield (cfs/mi ²)	<u>0.1</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.375</u>	Q ₇₋₁₀ Basis	<u>Default</u>
Elevation (ft)	<u>1048</u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>20A</u>	Chapter 93 Class.	<u>Warm Water Fishes</u>
Existing Use	<u>---</u>	Existing Use Qualifier	<u>---</u>
Exceptions to Use	<u>---</u>	Exceptions to Criteria	<u>---</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>---</u>		
Source(s) of Impairment	<u>---</u>		
TMDL Status	<u>---</u>	Name	<u>---</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	
Temperature (°F)	<u>20</u>	Default	
Hardness (mg/L)	<u>100</u>	Default	
Other:	<u>---</u>	---	
Nearest Downstream Public Water Supply Intake	<u>Sharpsville Borough Water Company</u>		
PWS Waters	<u>Shenango River</u>	Flow at Intake (cfs)	<u>94.3</u>
PWS RMI	<u>33.2</u>	Distance from Outfall (mi)	<u>24.5</u>

Changes Since Last Permit Issuance: N/A – This is a proposed discharge (Planning was approved on April 30, 2020).

Other Comments:

This SRSTP was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of a Singulair Bio-Kinetic treatment tank. The proposed discharge is to resolve a repair of a malfunctioning on-lot system.

The Singulair Bio-Kinetic treatment tank is reportedly capable of meeting CBOD₅ averages of 10 mg/l and TSS averages of 10 mg/l.

In accordance with the SOP, no water quality modeling was performed since this is a SRSTP.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD₅, Total Suspended Solids, and Fecal Coliform are technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7.

Attachment 1
eMap – Location Map



Attachment 2
Google Earth Imagery

