

Application Type New
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0289001
APS ID 1031842
Authorization ID 1342281

Applicant, Facility and Project Information

Applicant Name	<u>Stephanie & Thomas Hart</u>	Facility Name	<u>Stephanie & Thomas Hart SRSTP</u>
Applicant Address	<u>9945 Williamson Road</u> <u>Meadville, PA 16335-5157</u>	Facility Address	<u>9945 Williamson Road</u> <u>Meadville, PA 16335-5157</u>
Applicant Contact	<u>Thomas Hart</u>	Facility Contact	<u></u>
Applicant Phone	<u>(814) 671-6270</u>	Facility Phone	<u></u>
Client ID	<u>360901</u>	Site ID	<u>844912</u>
SIC Code	<u>8800</u>	Municipality	<u>West Mead Township</u>
SIC Description	<u>Private Households</u>	County	<u>Crawford</u>
Date Application Received	<u>February 2, 2021</u>	WQM Required	<u>Yes</u>
Date Application Accepted	<u>February 16, 2021</u>	WQM App. No.	<u>2021401</u>
Project Description	<u>Single Residence Sewage Treatment Plant.</u>		

Summary of Review

This is a new discharge for an existing 3-bedroom home to a repair of an existing malfunctioning on-lot system.

Act 14 – Proof of Notification was submitted and received.

Proposed treatment will consist of (WQM Permit No. 2021401): A septic tank followed by an Ecoflow Coco Filter unit with an UV disinfection unit and pump tank.

The EPA Waiver is in effect.

There are no open violations in WMS for the subject Client ID (360901) as of 04/06/2020.

Stephanie Hart called in 4/12/2021 inquiring on the status of the permit application. Ms. Hart stated that the property is being sold and is scheduled to close on May 7, 2021. The transfer application will also be sent to Ms. Hart (fourhart@zoominternet.net). JCD
4/12/2021

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Civil Engineer Trainee	April 6, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	April 12, 2021

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0005</u>
Latitude	<u>41° 36' 16.10"</u>	Longitude	<u>-80° 7' 38.85"</u>
Quad Name	<u>41080E2</u>	Quad Code	<u>Geneva</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Mud Run (WWF)</u>	Stream Code	<u>N/A</u>
NHD Com ID	<u>127348896</u>	RMI	<u>0.8900</u>
Drainage Area	<u>0.19</u>	Yield (cfs/mi ²)	<u>0.1</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.019</u>	Q ₇₋₁₀ Basis	<u>Default</u>
Elevation (ft)	<u>1398</u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>16-D</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>---</u>	Existing Use Qualifier	<u>---</u>
Exceptions to Use	<u>---</u>	Exceptions to Criteria	<u>---</u>
Assessment Status	<u>Not Assessed</u>		
Cause(s) of Impairment	<u>---</u>		
Source(s) of Impairment	<u>---</u>		
TMDL Status	<u>---</u>	Name	<u>---</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	
Temperature (°F)	<u>20</u>	Default	
Hardness (mg/L)	<u>100</u>	Default	
Other:	<u>---</u>	---	
Nearest Downstream Public Water Supply Intake	<u>Aqua Pennsylvania, Inc. - Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1,376</u>
PWS RMI	<u>90.0</u>	Distance from Outfall (mi)	<u>>25 mi</u>

Changes Since Last Permit Issuance: N/A – This is a proposed discharge (Planning was approved on February 1, 2021).

Other Comments:

This SRSTP was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of a Coco Filter. The proposed discharge is to resolve a repair of a malfunctioning on-lot system.

The Coco Filter unit is reportedly capable of meeting CBOD₅ averages of 10 mg/l and TSS averages of 10 mg/l.

In accordance with the SOP, no water quality modeling was performed since this is a SRSTP.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: None

Attachment 1
eMap – Location Map



Attachment 2
Google Earth Imagery

