

Application Type New
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0289191
APS ID 1035160
Authorization ID 1347890

Applicant, Facility and Project Information

Applicant Name	<u>Kathleen Uhrinek</u>	Facility Name	<u>Donna Connor SRSTP</u>
Applicant Address	<u>1029 West Home Road</u> <u>Emlenton, PA 16373</u>	Facility Address	<u>205 Joe Road</u> <u>Butler, PA 16002</u>
Applicant Contact	<u>Kathleen Uhrinek</u>	Facility Contact	<u></u>
Applicant Phone	<u>(814) 541-0283</u>	Facility Phone	<u></u>
Applicant E Mail	<u>mcclearykathleen@gmail.com</u>	Facility E Mail	<u></u>
Client ID	<u>361834</u>	Site ID	<u>846979</u>
Municipality	<u>Oakland Township</u>	County	<u>Butler</u>
SIC Code	<u>8800</u>	SIC Code	<u>4952</u>
SIC Description	<u>Private Households</u>	SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>
Application Received	<u>March 5, 2021</u>	WQM Required	<u>Yes, and concurrently pending</u>
Application Accepted	<u>April 7, 2021</u>	WQM App. No.	<u>1021406</u>
Project Description	<u>New treated sewage discharge.</u>		

Approve	Deny	Signatures	Date
X		William H. Mentzer William H. Mentzer, P.E. Environmental Engineering Specialist	April 7, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	April 12, 2021

Summary of Review

The applicant is an agent of the permittee with a power of attorney. (The Butler Eagle reports Donna Connor as deceased.) The proposal is to replace a malfunctioning on-lot sewage treatment facility serving a four-bedroom home.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0005</u>
Latitude DP	<u>40° 54' 21.00"</u>	Longitude DP	<u>-79° 48' 9.00"</u>
Latitude NHD	<u>40° 54' 20.17"</u>	Longitude NHD	<u>-79° 48' 9.26"</u>
Quad Name	<u>East Butler</u>	Quad Code	<u>1107</u>
Wastewater:	<u>Treated single residence domestic wastes</u>		
Receiving Waters	<u>Unnamed Tributary of Bonnie Brook</u>	Stream Code	<u>63175</u>
NHD Com ID	<u>126217892</u>	RMI	<u>0.0600</u>
Drainage Area	<u>63.07 acres (0.1 square miles)</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>dry stream</u>
Elevation (ft)	<u>1196.00</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>20-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>The receiving waters are an USGS delineated intermittent stream. The plot plan shows the stream as buried. The measured RMI is 0.05 and the NHD RMI is 0.06. Secondary waters is Tributary 63174 and are assumed perennial with a 620.20-acre drainage area, 1190.59 feet elevation and at RMI 0.60</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Impairment Cause(s)	<u></u>		
Impairment Source(s)	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake		<u>PA American</u>	
PWS Waters	<u>Connoquenessing Creek</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>0.01</u>	Distance from Outfall (mi)	<u>68.43</u>

Changes Since Last Permit Issuance: NA

Other Comments: No downstream water supply impairment is expected.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection

Other Comments: The AMR lists UV radiation maintenance, monitoring and operation requirements.