

Application Type New  
Wastewater Type Sewage  
Facility Type SRSTP

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SFTF/SRSTP**

Application No. PA0289698  
APS ID 1042745  
Authorization ID 1360914

**Applicant, Facility and Project Information**

Applicant Name	<u>Eric &amp; Janet Gadley</u>	Facility Name	<u>Eric &amp; Janet Gadley SRSTP</u>
Applicant Address	<u>411 Rice Avenue</u> <u>Girard, PA 16417-1426</u>	Facility Address	<u>Eureka Road</u> <u>Edinboro, PA 16412</u>
Applicant Contact	<u>Eric Gadley</u>	Facility Contact	<u></u>
Applicant Phone	<u>(814) 431-8123</u>	Facility Phone	<u></u>
Applicant E Mail	<u>gadleypestservices@outlook.com</u>	Facility E Mail	<u></u>
Client ID	<u>364073</u>	Site ID	<u>696329</u>
Municipality	<u>Washington Township</u>	County	<u>Erie</u>
SIC Code	<u>8800</u>	SIC Code	<u>4952</u>
SIC Description	<u>Private Households</u>	SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>
Application Received	<u>June 25, 2021</u>	WQM Required	<u>Yes, concurrent review pending</u>
Application Accepted	<u>August 9, 2021</u>	WQM App. No.	<u>2521420</u>
Project Description	<u>This is a new proposal replacing a permitted and never built sewage treatment facility.</u>		

**Summary of Review**

This proposal replaces NPDES permit PAG049396 and WQM Permit WQG018593 issued to J Algozzini that should be cancelled. A cancellation request was e mailed on August 11, 2021.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	August 11, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	August 16, 2021

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0005</u>
Latitude DP	<u>41° 51' 35.00"</u>	Longitude DP	<u>-80° 12' 18.50"</u>
Latitude NHD	<u>41° 51' 33.41"</u>	Longitude NHD	<u>-80° 12' 24.44"</u>
Quad Name	<u>Edinboro South</u>	Quad Code	<u>0404</u>
Wastewater:	<u>Treated single residence domestic wastes</u>		
Receiving Waters	<u>Unnamed Tributary to Cussewago Creek</u>	Stream Code	<u>525644</u>
NHD Com ID	<u>127348142</u>	RMI	<u>0.86</u>
Drainage Area	<u>0.1</u>	Yield (cfs/mi <sup>2</sup> )	<u>0</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0</u>	Q <sub>7-10</sub> Basis	<u>Dry stream</u>
Elevation (ft)	<u>1378.73</u>	Slope (ft/ft)	<u>0.02646</u>
Watershed No.	<u>16-D</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>Dry stream discharge with NHD confluence at RMI 0.74. Perennial stream flow at the Cussewago Creek confluence.</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°C)	<u>25</u>		<u>WWF default</u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Aqua Pa Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1450</u>
PWS RMI	<u>90.57</u>	Distance from Outfall (mi)	<u>66.82</u>

Changes Since Last Permit Issuance: NA

Other Comments: The stream flow is the revised USACOE low flow upstream at Franklin

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

\Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection

Other Comments: The Annual Maintenance Report (AMR) states the UV radiation monitoring, maintenance, and reporting requirements