

Application Type New
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0290033
APS ID 1049670
Authorization ID 1372848

Applicant, Facility and Project Information

Applicant Name	<u>Randy & Julie White</u>	Facility Name	<u>Randy White SRSTP</u>
Applicant Address	<u>4200 Neyland Road</u> <u>Edinboro, PA 16412-1182</u>	Facility Address	<u>4200 Neyland Road</u> <u>Edinboro, PA 16412-1182</u>
Applicant Contact	<u>Randy White</u>	Facility Contact	<u>Randy White</u>
Applicant Phone	<u>(814) 440-7780</u>	Facility Phone	<u>(814) 440-7780</u>
Applicant E Mail	<u>rswhite27@gmail.com</u>	Facility EMail	<u></u>
Client ID	<u>366143</u>	Site ID	<u>849509</u>
Municipality	<u>Washington Township</u>	County	<u>Erie</u>
SIC Code	<u>8811</u>	SIC Code	<u>4952</u>
SIC Description	<u>Services - Private Households</u>	SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>
Application Received	<u>October 12, 2021</u>	WQM Required	<u>pending</u>
Application Accepted	<u>October 27, 2021</u>	WQM App. No.	<u>2521429</u>
Project Description	<u>A new treated sewage discharge that is part of a malfunctioning sewage on-lot treatment facility replacement.</u>		

Summary of Review

No violations are reported. Design is for 500-gpd and 1.4-PPD BOD5 bas on four-bedrooms.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	October 28, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	November 1, 2021

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.0005</u>
Latitude DP	<u>41° 55' 17.90"</u>	Longitude DP	<u>-80° 6' 20.30"</u>
Latitude NHD	<u>41° 55' 18.21"</u>	Longitude NHD	<u>-80° 6' 48.51"</u>
Quad Name	<u>Cambridge Springs NE</u>	Quad Code	<u>0305</u>
Wastewater:	<u>Treated single residence domestic wastes</u>		
Receiving Waters	<u>Unnamed Tributary of Conneauttee Creek</u>	Stream Code	<u>unknown</u>
NHD Com ID	<u>127344823</u>	RMI	<u>0.43</u>
Drainage Area	<u>3.85 acre 0.01 sq miles</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>Dry swale</u>
Elevation (ft)	<u>1428.00</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>16-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>Statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>Discharge is to 0.43-mile multiple node dry swale to tributary 53083 node RMI 0.031 (stream RMI 1.20). Perennial stream is assumed at tributary 53083 RMI 0.891885 Elevation 1380.00-feet and Drainage 330.9 acres (0.52-square miles)</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Impairment Cause(s)	<u></u>		
Impairment Source(s)	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data	Data Source		
pH (SU)	<u></u>	<u></u>	
Temperature (°C)	<u></u>	<u></u>	
Hardness (mg/L)	<u></u>	<u></u>	
Other:	<u></u>	<u></u>	
Nearest Downstream Public Water Supply Intake	<u>Aqua Pa Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>90.57</u>	Distance from Outfall (mi)	<u>97.48</u>

Changes Since Last Permit Issuance: NA

Other Comments: No impairments are expected

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection

Other Comments: The Annual Maintenance Report (AMR) states the UV radiation requirements.