

Application Type New
Wastewater Type Sewage
Facility Type SFTF

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0290076
APS ID 1050245
Authorization ID 1373769

Applicant, Facility and Project Information

Applicant Name	<u>Evandale Farm LLC</u>	Facility Name	<u>Evandale Farm SFTF</u>
Applicant Address	<u>456 W 6th Street</u> <u>Erie, PA 16507-1216</u>	Facility Address	<u>11575 Cole Road</u> <u>North East, PA 16428-5215</u>
Applicant Contact	<u>Craig Zonna</u>	Facility Contact	<u></u>
Applicant Phone	<u>(814) 456-4000</u>	Facility Phone	<u></u>
Applicant E Mail	<u>cazonna@elderkinlaw.com</u>	Facility E Mail	<u></u>
Client ID	<u>366336</u>	Site ID	<u>850437</u>
Municipality	<u>North East Township</u>	County	<u>Erie</u>
SIC Code	<u>8800</u>	SIC Code	<u>4952</u>
SIC Description	<u>Private Households</u>	SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>
Received	<u>October 18, 2021</u>	WQM Required	<u></u>
Accepted	<u>November 1, 2021</u>	WQM App. No.	<u>2521431</u>
Project Description	<u>Replacement of a malfunctioning on-lot sewage treatment system.</u>		

Summary of Review

No violations are reported. Design is for 800-gpd and 2.2-ppd BOD5 based on two residential units (one three-bedroom home and one apartment with an office).

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	November 2, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	November 5, 2021

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0008</u>
Latitude DP	<u>42° 10' 47.00"</u>	Longitude DP	<u>-79° 48' 10.80"</u>
Latitude NHD	<u>42° 10' 53.00"</u>	Longitude NHD	<u>-79° 48' 10.84"</u>
Quad Name	<u>North East</u>	Quad Code	<u>0107</u>
Wastewater:	<u>Treated domestic wastes from a single residence, apartment, and office.</u>		
Receiving Waters	<u>Unnamed Tributary of Sixteenmile Creek</u>	Stream Code	<u>unknown</u>
NHD Com ID	<u>123924557</u>	RMI	<u>0.13</u>
Drainage Area	<u>29.1 acres 0.05 square mile</u>	Yield (cfs/mi ²)	<u>0</u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u>Dry stream</u>
Elevation (ft)	<u>1247.00</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>15-A</u>	Chapter 93 Class.	<u>CWF, MF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Exceptions to Use	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments:	<u>Confluence tributary 62276 RMI 0.28 Drainage 217.6 acres 0.34-square mile Elevation 1200.00 feet. Confluence Sixteenmile Creek 62264 RMI 6.908443</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data	Data Source		
pH (SU)	<u></u>	<u></u>	
Temperature (°F)	<u></u>	<u></u>	
Hardness (mg/L)	<u></u>	<u></u>	
Other:	<u></u>	<u></u>	
Nearest Downstream Public Water Supply Intake	<u>State of New York</u>		
PWS Waters	<u>Lake Erie</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>891.63</u>	Distance from Outfall (mi)	<u>12.06</u>

Changes Since Last Permit Issuance: NA

Other Comments: no downstream water use impairment expected

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection

Other Comments: UV radiation requirements are on the Annual Maintenance Report (AMR)

In this particular case, the Department has established the monitoring frequencies to be the same as a single residence sewage treatment plant (SRSTP) since this facility essentially serves a single residence property and the associated flows are expected to be in-line with an SRSTP. JCD