

Application Type New
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0291242
APS ID 1070596
Authorization ID 1409171

Applicant, Facility and Project Information

Applicant Name	<u>Tracy Swiderski</u>	Facility Name	<u>Tracy Swiderski SRSTP</u>
Applicant Address	<u>6 Madaket Way</u> <u>Sandwich, MA 02563-2676</u>	Facility Address	<u>8619 Ethel Drive</u> <u>Girard, PA 16417-8807</u>
Applicant Contact	<u>Tracy Swiderski</u>	Facility Contact	<u>Tracy Swiderski</u>
Applicant Phone	<u>(814) 449-2395</u>	Facility Phone	<u>(814) 449-2395</u>
Client ID	<u>372205</u>	Site ID	<u>845146</u>
SIC Code	<u>8800</u>	Municipality	<u>Girard Township</u>
SIC Description	<u>Private Households</u>	County	<u>Erie</u>
Date Application Received	<u>September 2, 2022</u>	WQM Required	<u>Yes</u>
Date Application Accepted	<u></u>	WQM App. No.	<u>2522433</u>
Project Description	<u>Single Residence Sewage Treatment Plant (SRSTP).</u>		

Summary of Review

This is a new discharge for an existing 3-bedroom home to a repair of an existing malfunctioning on-lot system.

Act 14 – Proof of Notification was submitted and received.

Act 537 Component 3s was approved on June 29, 2022.

Proposed treatment will consist of (WQM Permit No. 2522433): An existing 1000-gallon dual chambered concrete septic tank followed by a Premier Tech EC7-500-P-P/G-PACK Coco Filter unit with integrated ultraviolet (UV) disinfection unit.

The EPA Waiver is in effect.

There are no open violations in WMS for the subject Client ID (372205) as of 1/20/2023.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager	January 20, 2023
X		Chad W. Yurisc, P.E. Chad W. Yurisc, P.E. / Environmental Engineer Manager	January 31, 2023
		Justin C. Dickey, P.E. / Environmental Program Manager	

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude	<u>42° 0' 58.70"</u>	Longitude	<u>-80° 16' 56.29"</u>
Quad Name	<u>Fairview</u>	Quad Code	<u>42080A3</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Stream (HQ-CWF, MF)</u>	Stream Code	<u>62485</u>
NHD Com ID	<u>134205213</u>	RMI	<u>0.5100</u>
Drainage Area	<u>1.24</u>	Yield (cfs/mi ²)	<u>0.1</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.124</u>	Q ₇₋₁₀ Basis	<u>Default</u>
Elevation (ft)	<u>814</u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>15-A</u>	Chapter 93 Class.	<u>HQ-CWF, MF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>SILTATION</u>		
Source(s) of Impairment	<u>AGRICULTURE</u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	<u></u>
Temperature (°F)	<u>20</u>	Default	<u></u>
Hardness (mg/L)	<u>100</u>	Default	<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Erie Water Works</u>		
PWS Waters	<u>Lake Erie (Chestnut and West)</u>	Flow at Intake (cfs)	<u>N/A</u>
PWS RMI	<u>N/A</u>	Distance from Outfall (mi)	<u>5.75</u>

Changes Since Last Permit Issuance: N/A – This is a proposed discharge (Planning was approved on June 29, 2022).

Other Comments:

This SRSTP was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of a Coco Filter. The proposed discharge is to resolve a repair of a malfunctioning on-lot system.

The Coco Filter unit is reportedly capable of meeting CBOD5 averages of 10 mg/l and TSS averages of 10 mg/l.

In accordance with the SOP, no water quality modeling was performed since this is a SRSTP.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/month	Grab
BOD5	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after disinfection

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD₅ and Total Suspended Solids are BPJ limits based on the Small Flow Treatment Facilities Manual. Fecal Coliform is technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7.

Map | eFacts Query | Advanced Query | Filter Plant Source Search

ESRI Streets & Imagery
 Topographic
 National Geographic

Streets | Imagery

Locate Latitude and Longitude

Decimal Degrees
 DD/MM/SS

	Degrees	Minutes	Seconds
Latitude:	42	0	42.8
Longitude:	-80	16	47.7

PA Historic Streams (1 of 6)

Name: Trib 62485 To Lake Erie
Net Streams: 65763
Shed: 15X
Named: 0
Rec No: 65763
Seg ID: 62485_2.1343_6.7367
Seg ID Old: 62485_2.1342_6.7366
From Node: 788
To Node: 757
Down River Mile: 2.134301
Up River Mile: 6.736721
WRDS: 62485
Strahler: 1

[Zoom to](#)

Latitude: 42.011889 - I

0 0.2 0.4mi

POWERED BY **esri**

Imagery: Source: Esri, Maxar, Earthstar Geographics, and the GIS User Community; ESRI Streets: Sources: Esri, HERE, Garmin, USGS, Intermap, INCREMENT P, NRCan, Esri Japan, METI, Esri China (Hong Kong), Esri Korea, Esri (Thailand), NGCC, (c) OpenStreetMap contributors, and the GIS User Community

**Attachment 2
Google Earth Imagery**

