

Application Type New  
Wastewater Type Sewage  
Facility Type SRSTP

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SFTF/SRSTP**

Application No. PA0291773  
APS ID 1077702  
Authorization ID 1421075

**Applicant, Facility and Project Information**

Applicant Name	<u>Jessica Whorl</u>	Facility Name	<u>Whorl Residence</u>
Applicant Address	<u>11083 Sawmill Road</u> <u>Glen Rock, PA 17327-8289</u>	Facility Address	<u>11083 Sawmill Road</u> <u>Glen Rock, PA 17327-8289</u>
Applicant Contact	<u>Jessica Whorl</u>	Facility Contact	<u>Jessica Whorl</u>
Applicant Phone	<u>(717) 683-3034</u>	Facility Phone	<u>(717) 683-3034</u>
Client ID	<u>374250</u>	Site ID	<u>861690</u>
SIC Code	<u>6514</u>	Municipality	<u>Shrewsbury Borough</u>
SIC Description	<u>Fin, Ins &amp; Real Est - Dwelling Operators, Except Apartments</u>	County	<u>York</u>
Date Application Received	<u>December 9, 2022</u>	WQM Required	<u>Pending</u>
Date Application Accepted	<u>January 18, 2023</u>	WQM App. No.	<u>WQG01671905</u>
Project Description	<u>Application for a proposed SRSTP.</u>		

**Summary of Review**

Jessica Whorl has submitted an application for a new permit for her proposed Single Residence Small Flow Treatment Facility located in York County. DEP received the new NPDES and WQM permit applications on December 9, 2022 by the applicant. The Department has reviewed the application in order to ensure that the facility does not receive or discharge a flow greater than 400 GPD or exceed the specified limits of CBOD<sub>5</sub>, Total Suspended Solids, Ammonia Nitrogen, and Fecal Coliform prescribed in the permit. As per 25 Pa. Code § 92a.53, all applicable effluent limits and standards are considered in development of the permit. The limits noted in the permit suggest that any applicable water quality standards will not be violated.

The limits discussed in the permit are based off of several factors that were determined by the Standard Operating Procedure for Small Flow Treatment Facilities (SOP No. BCW-PMT-003).

The TSS limits were prescribed based on The Department's Water Quality Antidegradation Implementation Guidance ID No. 391-0300-002

The Fecal Coliform limits listed in the permit were required by the Bureau of Clean Water, as stated in Chapters 92a and 93.

Based on the review outlined in this fact sheet, it is recommended that the NPDES permit be drafted. Also, it is recommended that the WQM permit be issued upon issuance of the NPDES permit.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-

Approve	Deny	Signatures	Date
X		<i>Jared Lescavage</i> Jared Lescavage / Project Manager	January 19, 2023
x		<i>Scott M Arwood</i> Scott M. Arwood, P.E. / Environmental Engineer Manager	1/19/2023

**Summary of Review**

day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0004</u>
Latitude	<u>39° 48' 51.06"</u>	Longitude	<u>-76° 39' 44.26"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary of East Branch Codorus Creek (HQ-CWF, MF)</u>	Stream Code	<u>8141</u>
NHD Com ID	<u>57473043</u>	RMI	<u>0.1900</u>
Drainage Area	<u>0.4 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u></u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.0327</u>	Q <sub>7-10</sub> Basis	<u>StreamStats</u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>7-H</u>	Chapter 93 Class.	<u>HQ-CWF, MF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>York Water Co</u>		
PWS Waters	<u>East Branch Codorus Creek</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>8</u>

Changes Since Last Permit Issuance: N/A

Other Comments: None

Compliance History	
Summary of DMRs:	None
Summary of Inspections:	None

Other Comments: **None**

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/year	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	15.0 Avg Mo	XXX	XXX	1/year	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	5.0 Avg Mo	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments: None