

Application Type

New

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0294497

APS ID

1120588

Authorization ID

1497147

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	1845 Baltimore Pike LLC	Facility Name	1845 Baltimore Pike
Applicant Address	440 Stone Jug Road	Facility Address	1845 Baltimore Pike
	Biglerville, PA 17307-9097		Gettysburg, PA 17325-7313
Applicant Contact	Brian Long	Facility Contact	Brian Long
Applicant Phone	(704) 634-6006	Facility Phone	(704) 634-6006
Client ID	387890	Site ID	874768
Ch 94 Load Status	Not Overloaded	Municipality	Mount Joy Township
Connection Status	No Limitations	County	Adams
Date Application Received	August 28, 2024	EPA Waived?	Yes
Date Application Accepted	August 29, 2024	If No, Reason	
Purpose of Application	NPDES new permit.		

Summary of Review

This fact sheet supports the issuance of new NPDES permit for discharge of treated sewage from the minor sewer Facility less than 0.05 MGD for 12-unit apartment building, 3-unit apartment building, and laundry + commercial building located in Mountain Joy Township, Adams County.

The annual average design flow is 6,187 gallons per day (0.006187 MGD). The hydraulic design flow is 0.00761 MGD. The discharge will be to Unnamed Tributary to Rock Creek which is classified as Warm Water Fishes (WWF).

The WQM permit for the construction of the treatment system with permit No. WQM 0124401 is concurrently under review.

DEP has prepared this report for the applications for both NPDES and WQM permits.

DEP Planning for the project was approved under Code No. A3-01924-271-3 on March 25, 2024.

Based on the review outlined in this report, it is recommended that the NPDES permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilaryle Hilary H. Le / Environmental Engineering Specialist	February 21, 2025
X		/s/ Daniel W. Martin, P.E. / Environmental Engineer Manager	February 28, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.006187
Latitude	39° 48' 59.00"	Longitude	-77° 12' 17.00"
Quad Name	Gettysburg	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	UNT 59139 to Rock Creek	Stream Code	59139
NHD Com ID	53320378	RMI	0.1500
Drainage Area	0.52 mi. ²	Yield (cfs/mi ²)	See comments below
Q ₇₋₁₀ Flow (cfs)	See comments below	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	447.89	Slope (ft/ft)	Warm water fishes
Watershed No.	13-D	Chapter 93 Class.	
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	City of Frederick, MD		
PWS Waters	Monocacy River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	Approximate 9.0 miles

Changes Since Last Permit Issuance: new

Drainage Area

The discharge is to UNT 59139 to Rock Creek at RMI 0.15 miles. A drainage area upstream of the discharge is estimated to be 0.52 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

There are no nearby stream gages with low flow data that have extensive or recent periods of record. Since USGS PA StreamStats estimated the drainage area that is below the minimum value allowed by USGS's regression equations, the USGS gage station No. 59041 on Rock Creek watershed (at the PA/MD border) will be used to calculate the Q₇₋₁₀ at the point of discharge using a low flow yield method. The Q₇₋₁₀ here is 2.71 cfs and the drainage area is 63.5 mi² which results in a Q₇₋₁₀ low flow yield of 0.04 cfs/mi². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 \text{Low Flow Yield} &= Q_{7-10\text{gage}} / \text{Drainage Area}_{\text{gage}} = 2.71 \text{ cfs} / 63.5 \text{ mi}^2 = 0.04 \text{ cfs/mi}^2 \\
 Q_{7-10\text{discharge}} &= 0.04 \text{ cfs/mi}^2 * \text{Drainage Area}_{\text{discharge}} = 0.04 \text{ cfs/mi}^2 * 0.52 \text{ mi}^2 = 0.02 \text{ cfs} \\
 Q_{30-10} &= 1.36 * Q_{7-10\text{discharge}} = 1.36 * 0.02 \text{ cfs} = 0.027 \text{ cfs} \\
 Q_{1-10} &= 0.64 * Q_{7-10\text{discharge}} = 0.64 * 0.02 \text{ cfs} = 0.013 \text{ cfs}
 \end{aligned}$$

The resulting dilution ratio (under Q₇₋₁₀ conditions) is Q_{stream}/Q_{discharge} = 0.02 cfs/[0.062 MGD*(1.55 cfs/MGD)] = 0.21:1

Public Water Supply

The nearest downstream public water supply is the PA-MD State Border located on the Rock Creek, approximately 9.0 miles downstream of the discharge point. Based on the nature of discharge, the discharge is not expected to impact the public water supply standards.

1845 Baltimore Pike

Rock Creek

25 Pa Code § 93.9z classifies UNT 59139 to Rock Creek as warm water fishes and migratory fishes surface water. Based on the 2024 Integrated Water Quality Report, Rock Creek is impaired due to nutrients caused by agriculture and municipal point source (see Table 1). A TMDL does not currently exist for this stream segment.

2024 PA Integrated Water Quality Monitoring and Assessment Report Category 5 – Pollutants Requiring a TMDL			
Rock Creek (02070009)			
Aquatic Life (15114) – 20.94 miles			
Source	Cause	Date Listed	TMDL Date
Agriculture	Nutrients	2002	2015
Municipal Point Source	Nutrients	2002	2015

Table 1 Impaired for one or more designated use by any pollutant and requiring a TMDL

Class A Wild Trout Streams

The receiving stream is not a Class A Wild Trout stream; therefore, no Class A Wild Trout Fishery is impacted by this discharge.

Treatment Facility Summary				
Treatment Facility Name: 1845 Baltimore Pike LLC				
WQM Permit No.	Issuance Date			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	No Treatment		Ultraviolet	0.006187
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.00761	14.02	Not Overloaded		Other WWTP

Changes Since Last Permit Issuance: new

Other Comments:

Compliance History	
Summary of DMRs:	N/A
Summary of Inspections:	N/A

Other Comments: A file review revealed that there is no Clean Water open violation associated with this client.

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 47' 59.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.006187
Longitude -77° 12' 17.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

- The Total Residual Chlorine is not applied to this facility because UV is disinfection.
- DEP's guidance document titled "Implementation Guidance for Evaluating Wastewater Discharges to Drainage Ditches and Swales" or Dry Stream guidance, document ID 391-2000-014 will be used along with TBEL, WQBEL, and BPJ to develop effluent limits.

Dry Stream Guidance Limitations:

Dry stream guidance (391-2000-014, Final April 12, 2008, page 6) indicates advanced treatment is required "For discharges to intermittent and ephemeral streams, drainage channels and swales, and storm sewers, a high degree of treatment is required to compensate for the lack of available assimilative capacity and to minimize the potential for nuisance conditions. Effluent limits will be determined by the regional permit engineer on a case-by-case basis, but for discharges of treated sewage and similar oxygen-consuming wastes, effluent limits should include and be at least as stringent as these, or equivalent:

CBOD₅ – 10 mg/L as monthly average;
TSS – 10 mg/L as monthly average;
Total N – 5 mg/L as a monthly average;
Dissolved oxygen – minimum 6 mg/L at all times;
Phosphorus – 0.5 mg/L as a monthly average"

However, the guidance postdates the issuance of the original NPDES permit for this facility. The existing permit doesn't contain limits for TN and Phosphorous. Section I of the 2008 guidance states that the policy is for new or expanded discharges. Since this is not new or expanding the existing limits developed according to Section IV of the 1997 guidance. These limits are as follows:

CBOD₅ and TSS - 10 mg/L as a monthly average;
20 mg/L as IMAX
NH₃-N - 3 mg/L as a monthly average;
Dissolved oxygen – 3 mg/L or greater, monthly average
Bacteria – 200/100 ml summertime; 2000/100 ml wintertime

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	25°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	25°C	(Default)
*	Background NH ₃ -N	=	0 mg/L	(Default)

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.15	1845 Baltimore	PA0294497	0.0062

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD ₅	25		
NH ₃ -N	3	6	
Dissolved Oxygen			5

Record: 1 of 1 | < Back | Next > | No Filter | Search |

Print | Archive | Cancel

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a summer limit of 3.0 mg/L as a monthly average and 6.0 mg/L instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects at the point of discharge. Winter limits are calculated by multiplying summer limits with a factor of 3. The minimum monitoring frequency will be 2/month. However, these limits are same as dry stream 3.0 mg/L AML & 6.0 mg/L IMAX for summer will be in the permit.

CBOD₅ and Total Suspended Solids:

The discharge is to a dry ditch that is a tributary of Unnamed Tributary of Rock Creek. DEP has been consistently implementing advanced treatment requirements specified in DEP's technical guidance no. 391-2000-014 as effluent limits for CBOD₅ and Total Suspended Solids (TSS) in the permit. These limits are 10.0 mg/L (average monthly) and 20.0 mg/L (IMAX) and are more stringent than the secondary treatment TBELs. As the water quality analysis indicated that these limits are still adequate, DEP will include these limits in the permit.

Total Phosphorus:

Nutrient impairment was previously identified by DEP for the Rock Creek basin. DEP previously determined that local Phosphorus concentration-based effluent limits are necessary for this facility to ensure that the facility does not additionally contribute to impairment. The 2.0 mg/L average monthly & 4.0 mg/L IMAX limits requirements will be in the permit. The minimum monitoring frequency will be 2/month.

Dissolved Oxygen (D.O.):

A minimum D.O. limit of 5.0 mg/L is a D.O. water quality criterion found in 25 Pa. Code § 93.7(a). It is recommended to include this limit in the draft permit to ensure that the facility will achieve compliance with DEP water quality standards.

1845 Baltimore Pike**Fecal Coliform:**

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Best Professional Judgment (BPJ) Limitations***Ultraviolet (UV) Monitoring:***

The UV system daily monitor and report the UV light intensity ($\mu\text{W}/\text{cm}^2$) will be included in the permit.

Chesapeake Bay Strategy:

The Department formulated a strategy in April 2007, to comply with the EPA's and Chesapeake Bay Foundation's requirements to reduce point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP) to the Bay. In the Strategy, sewage dischargers have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases 1, 2, and 3) dischargers received annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/l TN and 0.8 mg/l TP. Phase 4 (0.2 -0.4mgd) and Phase 5 (below 0.2mgd) facilities were required to monitor and report TN and TP during permit renewal at a monitoring frequency following Table 6-3 of DEP's Technical Guidance for Development and Specification of effluent Limitations (No. 362-0400-001).

EPA published the Chesapeake Bay Total Maximum Daily Load (TMDL) in December of 2010. Despite extensive restoration efforts during the past 25 years, the TMDL was prompted by insufficient progress and continued poor water quality in the Chesapeake Bay and its tidal tributaries.

In order to address the TMDL, Pennsylvania developed, in addition to the Bay Strategy, a Chesapeake Watershed Implementation Plan (WIP) Phase 1 in January 2011 and Phase 2 in March 2012. In accordance with the Phase 2 WIP and its supplement, re-issuing permits for significant dischargers follow the same phased approach formulated in the original Bay strategy, whilst Phase 4 and Phase 5 will be required to monitor and report TN and TP during permit renewal.

The Phase 2 WIP categorizes this facility as a phase 5 non-significant sewage facility that has a design flow less than 0.2 MGD but greater than 0.002 MGD. The WIP recommends monitoring and reporting for Total Nitrogen and Total Phosphorus throughout the permit term at a frequency no less than annual. As mentioned above, twice monthly monitoring of these pollutants will be written in the permit as recommended by DEP's SOP.

Given that planning approval for the project was not awarded prior to 2005 and given that this is a new proposed discharge into the Chesapeake Bay Watershed, mass limits for TP and TN of 0 mg/L have been proposed in this permit. The applicant has been previously informed that they will need to purchase nutrient credits.

This plant is classified as a phase 5, will be required to monitor and report TN once a year, and the 2.0 mg/LTP average monthly & 4.0 mg/L IMAX requirements will be in the permit.

Additional Consideration***Flow Monitoring***

The requirement to monitor the volume of effluent will propose permit per 40 CFR § 122.44(i)(1)(ii).

Monitoring Frequency and Sample Type

The proposed monitoring frequencies for all pollutants are proposed as twice-per-month grab samples as recommended by PA Doc No. 362-0400-001, Table 6-3.

Antidegradation (93.4)

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303d Listed Streams

This discharge is not located on a 303d listed stream segment.

Anti-Backsliding

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as existing permit requirements in accordance with 40 CFR §122.44(l)(1).

WQM 7.0 MODEL INPUT:


• Discharge pH	=	7.0	(Default)
• Discharge Temperature	=	25°C	(Default)
• Stream pH	=	7.0	(Default)
• Stream Temperature	=	25°C	(Default for WWF)
• Background NH ₃ -N	=	0	(Default)

1. Outfall 001 to UNT 59139 Rock Creek

- Elevation: 447.69 ft
- RMI: 0.150 miles
- Drainage Area: 0.52 mi.²
- Low Flow Yield: 0.04 cfs/mi.²
- Discharge Flow: 0.00620 MGD

2. Just before Rock Creek

- Elevation: 425.15 ft
- RMI: 0.001 miles to Rock Creek
- Drainage Area: 0.53 mi.²
- Low Flow Yield: 0.04 cfs/mi.²
- Discharge Flow: 0.000 MGD



NPDES Permit Fact Sheet

1845 Baltimore Pike

NPDES Permit No. PA0294497

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	0.52	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	4.6	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	4.09	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.52	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	4.09	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.6	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.019	ft ³ /s
30 Day 2 Year Low Flow	0.0285	ft ³ /s
7 Day 10 Year Low Flow	0.00693	ft ³ /s
30 Day 10 Year Low Flow	0.0102	ft ³ /s
90 Day 10 Year Low Flow	0.0176	ft ³ /s

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	0.53	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	4.6	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	4.24	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.53	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	4.24	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.6	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0188	ft ³ /s
30 Day 2 Year Low Flow	0.0282	ft ³ /s
7 Day 10 Year Low Flow	0.00683	ft ³ /s
30 Day 10 Year Low Flow	0.01	ft ³ /s
90 Day 10 Year Low Flow	0.0174	ft ³ /s

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

NPDES Permit Fact Sheet

1845 Baltimore Pike

NPDES Permit No. PA0294497

USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built >

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button.

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Zoom In Map Scale Lat: 39.8000 Long: -76.8000

Littletown

Fort Ritchie Raven Rock Site

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	0	percent
DRNAREA	Area that drains to a point on a stream	63.5	square miles
PRECIP	Mean Annual Precipitation	41	inches
ROCKDEP	Depth to rock	4.4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.44	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	63.5	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	41	inches	35	50.4
STRDEN	Stream Density	2.44	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.4	feet	3.32	5.65
CARBON	Percent Carbonate	0	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	5.62	ft ³ /s	38	38
30 Day 2 Year Low Flow	7.65	ft ³ /s	33	33
7 Day 10 Year Low Flow	2.71	ft ³ /s	51	51
30 Day 10 Year Low Flow	3.67	ft ³ /s	46	46
90 Day 10 Year Low Flow	5.67	ft ³ /s	36	36

Batch Processor Report About ? Help

Layers

Base Maps

Application Layers

National Layers

PA Map Layers

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation Effluent Limitations

Permit Number Disc Flow (mgd)

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.15	1845 Baltimore	PA0294497	0.0062

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	3	6	
Dissolved Oxygen			5

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

NPDES Permit Fact Sheet
1845 Baltimore Pike

NPDES Permit No. PA0294497

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
13D	59139	Trib 59139 to Rock Creek					
RM	Name	Permit Number	Disc. Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
0.150	1845 Baltimore	PA0294497	0.006	CBOD5	25		
				NH3-N	3	6	
				Dissolved Oxygen	5		

Friday, February 21, 2025 Version 1.0 Page 1 of 1

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name
13D	59139	Trib 59139 to Rock Creek

NHS-N Acute Allocations

RM	Discharge Name	Baseline Creation WLA (mg/L)	Baseline WLA (mg/L)	Multiple Creation (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.150-1845 Baltimore		11.07	6	11.07	6	0	0

NHS-N Chronic Allocations

RM	Discharge Name	Baseline Creation WLA (mg/L)	Baseline WLA (mg/L)	Multiple Creation (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.150-1845 Baltimore		4.37	3	4.37	3	0	0

Dissolved Oxygen Allocations

RM	Discharge Name	CBOD5 Baseline Multiple (mg/L)	CBOD5 Baseline WLA (mg/L)	NH3-N Baseline Multiple (mg/L)	NH3-N Baseline WLA (mg/L)	Dissolved Oxygen Baseline Multiple (mg/L)	Dissolved Oxygen Baseline WLA (mg/L)	Critical Reach	Percent Reduction
0.15-1845 Baltimore		25	25	3	3	5	5	0	0

Friday, February 21, 2025 Version 1.0 Page 1 of 1

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name
13D	59139	Trib 59139 to Rock Creek

Reach Data (ft)

RM	Total Discharge Flow (mgd)	Ambient Temperature (°C)	Ambient DO
0.150	0.006	25.000	7.000
Reach Width (ft)	Reach Depth (ft)	Reach W/Ratio	Reach Velocity (fps)
2.636	0.291	9.064	0.010
Reach CBOD5 (mg/L)	Reach CBOD5 (days)	Reach NOD5 (mg/L)	Reach NOD5 (days)
0.150	1.230	0.96	0.008
Reach DO (mg/L)	Reach DO (1/day)	DO Equation	Reach DO Goal (mg/L)
2.220	27.607	0.000	5
Reach Travel Time (days)			
0.230			

Subreach Results

Travel Time	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
0.000	8.50	0.92	7.33
0.049	8.30	0.92	7.40
0.069	8.30	0.88	7.45
0.092	8.03	0.86	7.49
0.115	7.75	0.84	7.53
0.138	7.48	0.82	7.54
0.161	7.21	0.80	7.54
0.184	6.94	0.78	7.54
0.207	6.72	0.77	7.54
0.230	6.48	0.75	7.54

Friday, February 21, 2025 Version 1.0 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameter	Value	Notes
WLA Method	PMR	Use Inputted W/L Ratio
Q1:10-QT:10 Ratio	0.64	Use Inputted Reach Travel Times
Q30:10-QT:10 Ratio	1.26	Temperature Adjust N
D.O. Saturation	90.00%	Use Balanced Technology
D.O. Goal	5	

Friday, February 21, 2025 Version 1.0 Page 1 of 1

NPDES Permit Fact Sheet
1845 Baltimore Pike

NPDES Permit No. PA0294497

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name
130	59139	Trib 59139 to Rock Creek

RM	Stream Flow	PWS With Stream Flow	Net Discharge	Reach Slope	Depth	Width	WD Ratio	Velocity	Reach Trav Time	Analytic Temp	Analytic pH
(cfs)	(cfs)	(cfs)	(cfs)	(ft)	(ft)	(ft)	(ft)	(ft/s)	(days)	(°C)	
Q7-10 Flow	0.150	0.02	0.00	0.02	.0096	0.02865	.291	2.64	9.06	0.04	25.00
Q1-10 Flow	0.150	0.01	0.00	0.01	.0096	0.02865	NA	NA	NA	0.03	25.00
Q30-10 Flow	0.150	0.03	0.00	0.03	.0096	0.02865	NA	NA	NA	0.04	25.00

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RM	Elevation	Drainage Area (sq mi)	Slope	PWS Withdrawal (mgd)	Apply PC
130	59139	Trib 59139 to Rock Creek	0.150	425.15	0.53	0.00000	0.00	<input checked="" type="checkbox"/>

Design Cond.	LFY	Trib Flow	Stream Flow	Rich Trav Time (days)	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tributary pH	Stream Temp	Stream pH
(cfs)	(cfs)	(cfs)	(cfs)	(ft)	(ft)	(ft)	(ft)	(ft)	(°C)	(°C)	
Q7-10	0.040	0.00	0.00	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10	0.00	0.00	0.00	0.000	0.0	0.00	0.00	0.00	0.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.000	0.0	0.00	0.00	0.00	0.00	0.00	0.00

Discharge Data											
Name	Permit Number	Existing Discharge Flow (mgd)	Permitted Discharge Flow (mgd)	Design Discharge Flow (mgd)	Design Flow Factor	Reserve Factor	Disch Temp	Disch pH	Disch Temp	Disch pH	
1845 Baltimore	PA0294497	0.0002	0.0002	0.0002	0.0002	0.0000	25.00	7.00	25.00	7.00	

Parameter Data											
Parameter Name	Disc Conc (mg/L)	Tab Conc (mg/L)	Stream Conc (mg/L)	Rate Coef (1/day)							
CBO DS	25.00	2.00	0.00	1.50							
Dissolved Oxygen	5.00	8.24	0.00	0.00							
NH4-N	3.00	0.00	0.00	0.70							

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RM	Elevation	Drainage Area (sq mi)	Slope	PWS Withdrawal (mgd)	Apply PC
130	59139	Trib 59139 to Rock Creek	0.001	425.15	0.53	0.00000	0.00	<input checked="" type="checkbox"/>

Design Cond.	LFY	Trib Flow	Stream Flow	Rich Trav Time (days)	Rich Velocity	WD Ratio	Rich Width	Rich Depth	Tributary pH	Stream Temp	Stream pH
(cfs)	(cfs)	(cfs)	(cfs)	(ft)	(ft/s)	(ft)	(ft)	(ft)	(°C)	(°C)	
Q7-10	0.040	0.00	0.00	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10	0.00	0.00	0.00	0.000	0.0	0.00	0.00	0.00	0.00	0.00	0.00
Q30-10	0.00	0.00	0.00	0.000	0.0	0.00	0.00	0.00	0.00	0.00	0.00

Discharge Data											
Name	Permit Number	Existing Discharge Flow (mgd)	Permitted Discharge Flow (mgd)	Design Discharge Flow (mgd)	Design Flow Factor	Reserve Factor	Disch Temp	Disch pH	Disch Temp	Disch pH	
1845 Baltimore	PA0294497	0.0000	0.0000	0.0000	0.0000	0.0000	25.00	7.00	25.00	7.00	

Parameter Data											
Parameter Name	Disc Conc (mg/L)	Tab Conc (mg/L)	Stream Conc (mg/L)	Rate Coef (1/day)							
CBO DS	25.00	2.00	0.00	1.50							
Dissolved Oxygen	5.00	8.24	0.00	0.00							
NH4-N	25.00	0.00	0.00	0.70							

Friday, February 21, 2025

Version 1.1

Page 2 of 2

11

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (μ w/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD ₅	XXX	XXX	XXX	10.0	XXX	20.0	2/month	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	Grab
Total Nitrogen	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	XXX	XXX	XXX	2.0	XXX	4.0	2/month	Grab

Compliance Sampling Location: 

Other Comments: 

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]