

Application Type New
Wastewater Type Sewage
Facility Type SRSTP

**NPDES PERMIT FACT SHEET
INDIVIDUAL SFTF/SRSTP**

Application No. PA0295396
APS ID 1097893
Authorization ID 1456750

Applicant, Facility and Project Information

Applicant Name	<u>Wheeler Properties LLC</u>	Facility Name	<u>Wheeler Properties SRSTP</u>
Applicant Address	<u>1006 Millbrook Road</u> <u>Jackson Center, PA 16133-2520</u>	Facility Address	<u>9879 Kennedy Hill Road</u> <u>Meadville, PA 16335-9257</u>
Applicant Contact	<u>Kaylyn Wheeler</u>	Facility Contact	<u></u>
Applicant Phone	<u>(724) 372-4531</u>	Facility Phone	<u></u>
Applicant Email	<u>hawsty@gmail.com</u>		
Client ID	<u>380095</u>	Site ID	<u>865308</u>
SIC Code	<u>8800</u>	Municipality	<u>Union Township</u>
SIC Description	<u>Private Households</u>	County	<u>Crawford</u>
Date Application Received	<u>September 26, 2023</u>	WQM Required	<u>Yes</u>
Date Application Accepted	<u>January 18, 2024</u>	WQM App. No.	<u>2023406</u>
Project Description	<u>Installation of a new Single Residence Sewage Treatment Plant</u>		

Summary of Review

This is a new discharge for an existing 3 bedrooms dwelling with proposed construction of a single residence sewage treatment plant to replace a malfunctioning on-lot septic system. The average daily flow is projected to be 500 GPD.

Proposed treatment will consist of (WQM Permit No. 2023406): A 1,000-gallon dual compartment septic tank with an Ecoflo EC7-500-C-G-USA coco filter treatment tank with an ultraviolet disinfection unit Model AT 1500 and outfall pipe. The treated effluent will be discharged into a road ditch before discharging into Unnamed Tributary to Van Horne Creek (WWF).

Act 14 – Proof of Notification was submitted and received.

Act 537 Sewage Facilities Planning Module Component 3s was approved by the department on August 16, 2023.

SPECIAL CONDITIONS: NONE

The EPA waiver is in effect.

There are NO open violations in WMS for the subject Client ID (380095) as of January 18, 2024.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Aeshah Shameseldin Aeshah Shameseldin / Civil Engineer	January 18, 2024
		Vacant / Environmental Engineer Manager	Okay to draft JCD 1/22/2024

Discharge and Stream Data – 2 - Receiving Waters and PWS

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0005</u>
Latitude	<u>41° 36' 6.70"</u>	Longitude	<u>-80° 10' 8.00"</u>
Quad Name	<u>Geneva</u>	Quad Code	<u>41080E2</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Van Horne Creek (WWF)</u>	Stream Code	<u>52435</u>
NHD Com ID	<u>127348899</u>	RMI	<u>0.4400</u>
Drainage Area	<u></u>	Yield (cfs/mi ²)	<u></u>
Q ₇₋₁₀ Flow (cfs)	<u>0</u>	Q ₇₋₁₀ Basis	<u></u>
Elevation (ft)	<u>1293</u>	Slope (ft/ft)	<u>---</u>
Watershed No.	<u>16-D</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>---</u>	Existing Use Qualifier	<u>---</u>
Exceptions to Use	<u>---</u>	Exceptions to Criteria	<u>---</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>---</u>		
Source(s) of Impairment	<u>---</u>		
TMDL Status	<u>---</u>	Name	<u>---</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	<u></u>
Temperature (°F)	<u>77</u>	Default	<u></u>
Hardness (mg/L)	<u>100</u>	Default	<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Aqua Pennsylvania, Inc. - Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1376</u>
PWS RMI	<u>90.0</u>	Distance from Outfall (mi)	<u>---</u>

Changes Since Last Permit Issuance: N/A -This is a proposed discharge (Planning was approved on August 16, 2023).

Other Comments: This SRSTP was designed where applicable in accordance with the SFTF Manual, but it does not qualify for the PAG-04 General Permit due to the use of an Ecoflo EC7-500-C-G-USA coco filter unit.

The Ecoflo EC7-500-C-G-USA coco filter unit is reportedly capable of meeting BOD5 averages of 10 mg/L and TSS averages of 10 mg/L.

In accordance with the SOP, no water quality modeling was performed since this is an SRSTP.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Annual Average	Maximum	Instant. Maximum		
Flow (GPD)	Report Annl Avg	XXX	XXX	XXX	XXX	XXX	1/year	Estimate
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	Upon Request	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
TSS	XXX	XXX	XXX	10.0	XXX	20.0	1/year	Grab
Fecal Coliform (No./100 ml)	XXX	XXX	XXX	200	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001, after UV disinfection.

Other Comments: Flow is monitor only based on Chapter 92a.61. The limits for BOD5, Total Suspended Solids are BPJ-based on the Department’s “Small Flow Treatment Facilities Manual.” Fecal Coliform are technology-based on Chapter 92a.47. The limits for pH are technology-based on Chapter 93.7.


Outfall Location - eMap with Aerial Imagery

The screenshot displays the eMapPA web application interface. At the top, the Pennsylvania Department of Environmental Protection logo is on the left, and navigation links for 'PA STATE AGENCIES', 'ONLINE SERVICES', 'Josh Shapiro, Governor', 'Jessica Shirley, Interim Acting Secretary', and 'DEP Home' are on the right. The main map area shows aerial imagery with stream data overlaid. A legend on the left side categorizes streams into 'Regulated Facilities and Related Information', 'Surface Water Related', 'Water Quality', and 'Boundaries'. A pop-up window titled 'PA Historic Streams (1 of 4)' provides detailed information for a selected stream segment: 'Name: Trib 52435 Of Van Horne Creek', 'Net Streams: 109043', 'Shed: 16D', 'Named: 0', 'Rec No: 109043', 'Seg ID: 52435_0_0.4466', 'Seg ID Old: 52435_0_0.4467', 'From Node: 22976', 'To Node: 22843', 'Down River Mile: 0', 'Up River Mile: 0.446644', 'WRDS: 52435', and 'Strahler: 1'. A 'Locate Latitude and Longitude' panel on the right shows the coordinates: Latitude: 41° 36' 6.7" and Longitude: -80° 10' 8". The map includes a scale bar (0 to 0.2 miles) and an ESRI logo in the bottom right corner.

Drainage Area Location – StreamStats with Aerial Imagery

StreamStats Report

Region ID: PA
Workspace ID: PA20240118195801454000
Clicked Point (Latitude, Longitude): 41.60185, -80.16891
Time: 2024-01-18 14:58:25 -0500



+ Collapse All

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.0000386	square miles