

Application Type New
Facility Type MS4
Permit Type Individual

NPDES PERMIT FACT SHEET
MS4s

Application No. PAI133525
APS ID 952164
Authorization ID 1201625

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|---|
| Applicant Name | <u>South Middleton Township Cumberland County</u> | Facility Name | <u>South Middleton Township Cumberland County MS4</u> |
| Applicant Address | <u>520 Park Drive Boiling Springs, PA 17007</u> | Facility Address | <u>520 Park Drive Boiling Springs, PA 17007</u> |
| Applicant Contact | <u>Cory Adams</u> | Facility Contact | <u>Cory Adams</u> |
| Applicant Phone | <u>(717) 258-5324</u> | Facility Phone | <u>(717) 258-5324</u> |
| Client ID | <u>40843</u> | Site ID | <u>825574</u> |
| SIC Code | <u>9999</u> | Municipality | <u>South Middleton Township</u> |
| SIC Description | <u>Public Admin. - Nonclassifiable Establishment</u> | County | <u>Cumberland</u> |
| Date Application Received | <u>September 14, 2017</u> | | |
| Date Application Accepted | <u>March 13, 2018</u> | | |
| Purpose of Application | <u>Application for an individual MS4 NPDES permit for discharge of stormwater.</u> | | |

Internal Review and Recommendations

Per PA Title 25 § 92a.54, since the MS4 discharges to surface water(s) with an existing and/or designated use of EV and/or HQ-CWF, South Middleton Township must seek permit coverage under an individual permit.

South Middleton Township discharges to Alexanders Spring Creek (CWF, MF), Letort Spring Run (HQ-CWF (existing use)), Yellow Breeches Creek (HQ-CWF, MF), and Hogestown Run (CWF, MF).

According to the MS4 Requirements Table, South Middleton Township is subject to the following IP appendix requirements: Appendix D

To comply with Appendix D, South Middleton Township has submitted a Chesapeake Bay Pollutant Reduction Plan (PRP).

There are no unresolved violations associated with South Middleton Township MS4 that would affect issuance of coverage.

It is recommended that individual permit coverage is granted in accordance with 40 CFR §123.35.

DEP has reviewed the revised PRP and additional documentation received on 2/26/2021 via email. DEP offers the following comments and recommendations based on the review, which will be evaluated by DEP during the permit term:

1. The plan proposes to retrofit three (3) existing grass swales to bioswales with drainage areas of 84.3 acres, 465.6 acres, and 753.7 acres. While design details are not required at this time, please ensure that the final design adheres to the design guidelines in the Stormwater BMP Manual (or similar resource).

| Approve | Deny | Signatures | Date |
|---------|------|--|----------|
| X | | <i>Jacob Rakowsky</i> Jacob S. Rakowsky, EIT / Environmental Engineer | 3/2/2021 |
| X | | <i>Scott M. Arwood</i> Scott M. Arwood, P.E. / Environmental Engineer Manager | 3/2/2021 |

Internal Review and Recommendations

2. Please be advised that the final designs for stream restoration BMPs should be in general accordance with DEP's "Considerations of Stream Restoration Projects" document, available at www.dep.pa.gov/ms4.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.