

Application Type Renewal
Facility Type MS4
Permit Type Individual

NPDES PERMIT FACT SHEET
MS4s

Application No. PAI134807
APS ID 1128067
Authorization ID 1510746

Applicant and Facility Information

Applicant Name	<u>The Pennsylvania State University</u>	Facility Name	<u>University Park MS4</u>
Applicant Address	<u>336 Stream Dr., Steam Services Building, Suite 301</u>	Facility Address	<u>336 Stream Dr., Steam Services Building, Suite 301</u>
	<u>University Park, PA 16802-4523</u>		<u>University Park, PA 16802-4523</u>
Applicant Contact	<u>Tracey Olexa</u>	Facility Contact	<u>Tracey Olexa</u>
Applicant Phone	<u>(814) 404-1893</u>	Facility Phone	<u>(814) 404-1893</u>
Client ID	<u>81628</u>	Site ID	<u>545486</u>
SIC Code	<u>Various</u>	Municipality	<u>State College Borough</u>
SIC Description	<u>Various</u>	County	<u>Centre</u>
Date Application Received	<u>December 20, 2024</u>		
Date Application Accepted	<u>January 6, 2025</u>		
Purpose of Application	<u>Renewal of an existing MS4 NPDES permit.</u>		


Internal Review and Recommendations

The Pennsylvania State University (PSU) has submitted an application to renew the existing NPDES permit for its MS4 system.

DEP has received PSU's PRP / TMDL Plan Final Report, dated September 25, 2025. The pollutant load reduction requirement was 26,779 lbs/year total suspended solids. The Duck Pond Channel, a stream restoration project, generated 115,000 lbs/year of TSS load reduction. This project was shared between PSU (PAI134807), College Township (PAI134803), Ferguson Township (PAI134805), and Harris Township (PAI134801). Of the 115,000 lbs/year "balance", PSU was assigned exactly 26,779 lbs/yr TSS to satisfy the PRP load reduction requirement.

DEP recommends that the renewed permit is drafted so that the permittee shall continue to maintain and implement all BMPs outlined in the existing PRP in full working order to continue to meet the achieved pollutant reductions.

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		 Derek S. Garner / Project Manager	March 25, 2026
X		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	March 25, 2026