



Application Type
Facility Type
Major / Minor

Renewal
Storm Water
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. **PAS122202**
APS ID **626292**
Authorization ID **1434178**

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|-------------------------------------|
| Applicant Name | <u>Bluetriton Brands Inc.</u> | Facility Name | <u>Blue Triton-2</u> |
| Applicant Address | <u>405 Nestle Way</u> | Facility Address | <u>405 Nestle Way</u> |
| Applicant Contact | <u>Breinigsville, PA 18031-1500</u> | Facility Contact | <u>Breinigsville, PA 18031-1500</u> |
| Applicant Phone | <u>(610) 530-5951</u> | Facility Phone | <u>(484) 686-2657</u> |
| Client ID | <u>274192</u> | Site ID | <u>448625</u> |
| SIC Code | <u>2086,3085,5149</u> | Municipality | <u>Upper Macungie Township</u> |
| SIC Description | <u>Manufacturing - Bottled And Canned Soft Drinks, Manufacturing - Plastics, Bottles, Wholesale Trade - Groceries And Related Products, Nec</u> | County | <u>Lehigh</u> |
| Date Application Received | <u>April 3, 2023</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>April 5, 2023</u> | If No, Reason | |
| Purpose of Application | <u>NEW INDIVIDUAL STORMWATER PERMIT FOR FACILITY AT 405 NESTLE WAY</u> | | |

Summary of Review

The applicant is requesting renewal of their NPDES permit to discharge stormwater associated with industrial activity to Iron Run (stream code 3594), a HQ-CWF/MF designated receiving stream in state water plan basin 02-C (Lower Lehigh River). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use.

The facility is categorized by SIC codes 2086 (Manufacturing – Bottled and Canned Soft Drinks), 3085 (Manufacturing – Plastics, Bottles) and 5149 (Wholesale Trade – Groceries and Related Products). This facility falls under **Appendix S and I** of the 2023 PAG03 General Permit for sampling / reporting. It is to be noted that all pollutants included in Appendix **S** are also included in **Appendix I** beside with the exception of Total Zinc. Semiannual monitoring and reporting include Total Nitrogen, Total Phosphorus, Total suspended Solids (TSS), pH, 5 Day Biochemical Oxygen Demand (CBDO5), Chemical Oxygen Demand (COD), Oil & Grease, Nitrate +Nitrite -N and Total Zinc. Benchmarks exist for pH, TSS, COD, Oil & Grease and CBDO5.

Benchmark values are not effluent limitations, and exceedances do not constitute permit violations. However, if the permittee's sampling demonstrates exceedances of benchmark values for two or more consecutive monitoring periods, the permittee shall take action in accordance with Part C. VIII. FG. of the permit. A corrective action plan must be submitted to DEP

if the discharge concentration for the parameters exceeds the benchmark values for two or more consecutive monitoring periods.

Previous permit limits for TSS, Oil & Grease and COD are removed in this permit due to change in PAG03 General permit.

| Approve | Deny | Signatures | Date |
|---------|------|--|----------------|
| X | | Hakim Yesli (signed) Hakim Yesli / Environmental Engineering Specialist | March 12, 2025 |
| X | | Edward Dudick, P.E. / Environmental Engineer Manager | April 14, 2025 |

Summary of Review

PPC plan implementation and completion of an annual inspection and compliance evaluation are required under the permit.

An RTPT site inspection was performed September 2023 by Operations section and the facility is in compliance.

WMS Query by client report was run April 11, 2025, and there is one pending violation; see below:

| PROGRAM SPECIFIC ID | INSP ID | VIOLATION ID | INSPECTION CATEGORY | VIOLATION DATE | VIOLATION CODE | VIOLATION |
|------------------------|---------|--------------|------------------------|-------------------|----------------|---|
| PA0275794 | 3950900 | 8227556 | PF | 03/27/2025 | 92A.41(A)10C | NPDES - Failure to collect representative samples |

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

