

Application Type Renewal
Facility Type Storm Water
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PAS212216
APS ID 1040232
Authorization ID 1357435

Applicant and Facility Information

Applicant Name	<u>Frank Casilio & Sons Inc.</u>	Facility Name	<u>Frank Casilio - Nazareth Concrete Plant</u>
Applicant Address	<u>1035 Mauch Chunk Road</u> <u>Bethlehem, PA 18018-6622</u>	Facility Address	<u>3110 Bath Pike</u> <u>Nazareth, PA 18064-8943</u>
Applicant Contact	<u>Antony Medei</u>	Facility Contact	<u>Anthony Medei</u>
Applicant Phone	<u>(610) 867-5886</u>	Facility Phone	<u>(610) 867-5886</u>
Client ID	<u>84203</u>	Site ID	<u>639471</u>
SIC Code	<u>3273</u>	Municipality	<u>Upper Nazareth Township</u>
SIC Description	<u>Manufacturing - Ready-Mixed Concrete</u>	County	<u>Northampton</u>
Date Application Received	<u>May 24, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 24, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal and transfer of an existing Stormwater Permit.</u>		

Summary of Review

The applicant is requesting renewal of their NPDES permit to discharge stormwater associated with industrial activity to an unnamed tributary to East Branch Monocacy Creek (stream code 3400), a HQ-CWF/MF designated receiving stream in state water plan basin 02-C (Lower Lehigh River). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use.

The facility is categorized by SIC code 3273 (Manufacturing – Ready-Mixed Concrete) and falls under Appendix N monitoring requirements of the PAG-03 general permit. Limits for pH and TSS as well as monitoring requirements for Oil & Grease are carried over from the previous permit. PAG-03 Appendix N monitoring requirements and BMPs are added.

Permit Part C conditions include Requirements Applicable to Stormwater Outfalls, which include BMPs applicable to facilities with SIC code 3273 from Appendix J. The permit requires implementation of a PPC plan and requires completion of an annual inspection and compliance evaluation.

The existing permit expires on June 30, 2021 and the renewal application was not submitted on time. There are open violations for the previous client that may warrant withholding the issuance of this permit. EPA waiver is in effect.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Bernard Feist (signed) Bernard Feist, P.E. / Environmental Engineer	June 14, 2021
X		Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager	6-16-21

06/02/2021	92A.75(A)	NPDES - Failure to submit NPDES renewal application at least 180 days prior to expiration or later approved date	HARDING, CHRISTIAN
06/02/2021	92A.41(A)12B	NPDES - Failure to submit monitoring report(s) or properly complete monitoring reports	HARDING, CHRISTIAN
06/02/2021	92A.41(A)10C	NPDES - Failure to collect representative samples	HARDING, CHRISTIAN
06/02/2021	92A.44	NPDES - Violation of effluent limits in Part A of permit	HARDING, CHRISTIAN