



Application Type
Facility Type
Major / Minor

Renewal
Stormwater
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. **PAS802209**
APS ID **1033891**
Authorization ID **1440982**

Applicant and Facility Information

Applicant Name	<u>Jenstar Of Allentown I</u>	Facility Name	<u>Werner Enterprises Allentown</u>
Applicant Address	<u>551 Cooper Road</u>	Facility Address	<u>5422 Oakview Drive</u>
Applicant Contact	<u>West Berlin, NJ 08091-3863</u>	Facility Contact	<u>Allentown, PA 18104</u>
Applicant Phone	<u>Bernadette Davidson, General Counsel</u>	Facility Phone	<u>Bryan Crist, Branch Manager</u>
Client ID	<u>(856) 809-4434</u>	Site ID	<u>(856) 768-1330</u>
SIC Code	<u>361446</u>	Municipality	<u>603692</u>
SIC Description	<u>4213</u>	County	<u>Upper Macungie Township</u>
Date Application Received	<u>Trans. & Utilities - Trucking, Except Local</u>	EPA Waived?	<u>Lehigh</u>
Date Application Accepted	<u>May 22, 2023</u>	If No, Reason	<u>Yes</u>
Purpose of Application	<u>May 22, 2023</u>		
	<u>Renewal of NPDES Permit for discharge of industrial stormwater</u>		

Summary of Review

The applicant is requesting renewal of an existing NPDES permit to discharge stormwater associated with industrial activity to an Unnamed Tributary to Little Cedar Creek, a HQ-CWF, MF (High Quality-Cold Water Fishes, Migratory Fishes) designated receiving stream in state water plan basin 2-C (Lower Lehigh River). As per the Department's current existing use list, the receiving stream segment does not have an existing use classification that is more protective than its designated use.

The facility performs maintenance and repairs to fleet vehicles. The exterior is used to park fleet vehicles.

The site consists of a building, paved driveways/parking areas, and grass areas. Outfall 001 is located on the southwest corner of the facility. The application indicates that stormwater drains through a grass area and detention basin before outfall. The outfall coordinates provided in the application do not match the site map or what is indicated in the previous permit. The previous permit coordinates were carried over to this renewal.

No non-stormwater discharges are anticipated during the 5 years following coverage or approval.

The facility is categorized by SIC code 4213 (Transportation and Utilities – Trucking, Except Local) and falls under Appendix L monitoring requirements of the PAG-03 General Permit. The Department renewed the NPDES General Permit for Stormwater Discharges Associated with Industrial Activity (PAG-03) and it became effective on March 24, 2023. Therefore, the new monitoring requirements for Appendix L will be utilized in this permit renewal. Semi-annual monitoring and reporting for Total Suspended Solids (TSS), Oil & Grease, Total Nitrogen, and Total Phosphorous are required under this permit.

Benchmark values exist for TSS and Oil & Grease. A benchmark value is the concentration of a pollutant in stormwater discharges that serves as a threshold for the determination of whether existing site BMPs are effective in controlling stormwater pollution. The benchmark values can be found in Part C. III. F. of the permit. A corrective action plan must be

Approve	Deny	Signatures	Date
X		/s/ Allison S. Zukosky / Project Manager	August 29, 2024
X		/s/ Amy M. Bellanca, P.E. / Program Manager	8-30-24

Summary of Review

submitted to DEP if the discharge concentration for the parameters exceed the benchmark values for two or more consecutive monitoring periods.

PPC Plan implementation and completion of an annual inspection and compliance evaluation are required under the permit. The existing permit expired on March 31, 2024. The application for renewal was received on May 22, 2023.

A Water Management System Inspection query indicated that on August 24, 2020 a Compliance Evaluation was performed.

There are currently no open violations for this client that warrant withholding issuance of the permit.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

DRAFT