

Application Type Renewal
Facility Type Storm Water
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PAS802222
APS ID 632551
Authorization ID 1371032

Applicant and Facility Information

Applicant Name	<u>Male Road Ind Properties LP</u>	Facility Name	<u>Male Rd Ind Properties LP</u>
Applicant Address	<u>PO Box 160</u> <u>Wind Gap, PA 18091-0160</u>	Facility Address	<u>593 Male Road</u> <u>Wind Gap, PA 18091-8503</u>
Applicant Contact	<u>Craig Berger</u> <u>cberger@brothersautotransport.com</u>	Facility Contact	<u>Craig Berger</u> <u>(610) 863-0200</u>
Applicant Phone	<u>(610) 863-0200</u>	Facility Phone	<u>(610) 863-0200</u>
Client ID	<u>260529</u>	Site ID	<u>661049</u>
SIC Code	<u>7699</u>	Municipality	<u>Plainfield Township</u>
SIC Description	<u>Equipment/Automotive repair</u>	County	<u>Northampton</u>
Date Application Received	<u>September 28, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 28, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of existing IW Storm Water Permit</u>		

Summary of Review

The applicant is requesting renewal of an NPDES permit to discharge stormwater associated with an industrial activity to an unnamed tributary of Little Bushkill Creek, a HQ-CWF/MF (high quality cold water fishery, migratory fishery-designated) receiving stream in SWP Basin 01F (Jacoby-Bushkill Creeks). Per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than the designated use. The discharge is not expected to affect public water supplies.

The overall facility is located in three municipalities: Wind Gap Borough, Plainfield Township, and Bushkill Township, while the outfall is located in Plainfield Township.

The Sic code for the facility is 7699, Equipment/Automotive repair and maintenance and storage. Monitoring requirements will be continued from the previous permit. "Appendix L" of the PAG-03 General Permit will continue to apply to this permit.

PAG-03 General Stormwater Permit Appendix L has these expected Statewide Benchmark Values for this class of industry.

Parameter	Benchmark Value (mg/L)
TSS	100 mg/l
Oil & Grease	30 mg/l

A benchmark value is the concentration of a pollutant in stormwater discharges that serves as a threshold for the determination of whether existing site BMPs are effective in controlling stormwater pollution. In the event that stormwater discharge concentrations for a parameter exceeds the benchmark value(s) identified above at the same outfall for two or more consecutive monitoring periods, the permittee shall develop a corrective action plan to reduce the concentrations of the parameters in stormwater discharges. Utilize Pennsylvania Stormwater Best Management Practices Manual 363-0300-002 when required.

Approve	Deny	Signatures	Date
X		Bernard Feist (signed) Bernard Feist, P.E. / Environmental Engineer	January 19, 2022
X		Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager	1-25-22

Summary of Review

The Part C requirements will also include prohibition of non-stormwater discharges; hazardous Substances release; a PPC Plan; Comprehensive Site Compliance Inspection and Record keeping.

The existing permit expires on 3/31/2022 and the application was received on 9/28/2021.

The NMS query "Violations – eFACTS – Open Violations for Client" was run. There are currently no open violations.

The EPA Waiver is in effect.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

DMR Data for Outfall 001 (from December 1, 2020 to November 30, 2021)

Parameter	JUN-21	DEC-20
TSS (mg/L) Daily Maximum	298	8.8
Oil and Grease (mg/L) Daily Maximum	< 5	< 1.34
Total Iron (mg/L) Daily Maximum	7.03	0.598