

Application Type Renewal
Facility Type Storm Water
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PAS802227
APS ID 761262
Authorization ID 1389281

Applicant and Facility Information

Applicant Name	<u>Dayton Superior Corp</u>	Facility Name	<u>Dayton Superior Corp Allentown Distribution Center</u>
Applicant Address	<u>1125 Byers Road</u> <u>Miamisburg, OH 45342-5765</u>	Facility Address	<u>7130 Ambassador Drive</u> <u>Allentown, PA 18106-9254</u>
Applicant Contact	<u>Amy Morissette</u>	Facility Contact	<u>Troy Heiland</u>
Applicant Phone	<u>(610) 366-3890 x47137</u>	Facility Phone	<u>(937) 866-0711 x44138</u>
Client ID	<u>290470</u>	Site ID	<u>753358</u>
SIC Code	<u>5032</u>	Municipality	<u>Upper Macungie Township</u>
SIC Description	<u>Brick, Stone, and Related Construction Materials</u>	County	<u>Lehigh</u>
Date Application Received	<u>March 15, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 8, 2022</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal application for NPDES permit to discharge stormwater from an industrial site</u>		

Summary of Review

The applicant is requesting renewal of an NPDES permit to discharge stormwater from an industrial facility to an unnamed tributary to Iron Run, a HQ-CWF/MF-designated receiving stream in state water plan basin 02-C (Lower Lehigh River). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use. Stormwater discharges from three outfalls and enters the Mill Road drainage ditch before traveling through stormwater channels and eventually entering Iron Run a few hundred feet to the south of State Route 222.

This facility is categorized by the 423320 NAICS Code – Brick, Stone, and Related Construction Material Merchant Wholesalers. This corresponds to SIC Code 5032 - Brick, Stone, and Related Construction Materials, however this does not fall under the monitoring requirements of any PAG-03 appendix. The most closely related appendix for this applicant is Appendix N - Glass, Clay, Cement, Concrete and Gypsum Products. If this permit application is approved, the applicant will now be required to monitor semi-annually for pH, Total Suspended Solids (TSS), Total Aluminum, and Total Iron. The applicant will not have to monitor for Oil and Grease under these updated requirements. Appendix N of the latest statewide PAG-03 General Permit includes benchmark values for pH (9.0 S.U. maximum) and TSS (100 mg/L maximum). The benchmark values are not effluent limitations, and exceedances do not constitute permit violations. However, if the permittee's sampling demonstrates exceedances of benchmark values for two consecutive monitoring periods, the permittee shall submit a corrective action plan within 90 days of the end of the monitoring period triggering the plan.

According to the applicant, this is a warehouse distribution center in which all chemicals are stored indoors, and it is not expected that any process wastewater will discharge from the outfalls at this site. A non-stormwater discharge assessment and certification included as part of the application claims that a visual inspection of all three outfalls was performed 48 hours after a precipitation event to determine that there was no presence of non-stormwater discharges from the site. The most recent DEP inspection was performed on March 17, 2022, and there are currently three open violations for this client that may warrant withholding issuance of this permit renewal. The Stormwater Part C requirements include Best Management

Approve	Deny	Signatures	Date
X		<i>Rory Sgarlat</i> Rory Sgarlat, EIT / Environmental Engineering Specialist	October 3, 2022
X		Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager	10-21-22

Summary of Review

Practices (BMPs), Routine Inspections, Preparedness, Prevention, and Contingency Plan, and Stormwater Monitoring Requirements.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

